

ภาคผนวก ค

ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียน

ตารางที่ ๑.1 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 17/9/2555

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	09-17-2012	9:20:31	24.8	44.2	523
2	09-17-2012	9:25:31	24.6	46.5	492
3	09-17-2012	9:30:31	24.6	48.5	501
4	09-17-2012	9:35:31	24.5	47.9	515
5	09-17-2012	9:40:31	24.4	45.7	525
6	09-17-2012	9:45:31	24.5	46.8	558
7	09-17-2012	9:50:31	24.6	49.4	626
8	09-17-2012	9:55:31	24.6	48.3	723
9	09-17-2012	10:00:31	24.6	48.4	853
10	09-17-2012	10:05:31	24.7	48.5	968
11	09-17-2012	10:10:31	24.8	47.9	1091
12	09-17-2012	10:15:31	24.9	47	1245
13	09-17-2012	10:20:31	24.8	48.1	1365
14	09-17-2012	10:25:31	24.9	47.8	1535
15	09-17-2012	10:30:31	24.9	47.6	1640
16	09-17-2012	10:35:31	24.8	47.3	1769
17	09-17-2012	10:40:31	24.9	47.2	1861
18	09-17-2012	10:45:31	24.8	47	1984
19	09-17-2012	10:50:31	24.8	46.5	2126
20	09-17-2012	10:55:31	24.9	46.3	2219
21	09-17-2012	11:00:31	24.9	46.9	2299
22	09-17-2012	11:05:31	25	47.3	2395
23	09-17-2012	11:10:31	24.8	46.6	2500
24	09-17-2012	11:15:31	24.9	46.5	2553

ตารางที่ ๑.1 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 17/9/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
25	09-17-2012	11:20:31	25	46.8	2643
26	09-17-2012	11:25:31	25.1	50.6	2370
27	09-17-2012	11:30:31	25.2	54.5	2125
28	09-17-2012	11:35:31	25.2	53.9	2150
29	09-17-2012	11:40:31	25.3	53.6	2214
30	09-17-2012	11:45:31	25.3	52.9	2370
31	09-17-2012	11:50:31	25.3	52.5	2470
32	09-17-2012	11:55:31	25.1	51.4	2634
33	09-17-2012	12:00:31	25.2	51.3	2749
34	09-17-2012	12:05:31	25.3	50.5	2869
35	09-17-2012	12:10:31	25.2	51.1	2943
36	09-17-2012	12:15:31	25.1	50.3	3110
37	09-17-2012	12:20:31	25.2	50.2	3179
38	09-17-2012	12:25:31	25.1	50	3392
39	09-17-2012	12:30:31	25.2	49.9	3502
40	09-17-2012	12:35:31	25.3	48.9	3650
41	09-17-2012	12:40:31	25.3	49.6	3689
42	09-17-2012	12:45:31	25.2	49.8	3794
43	09-17-2012	12:50:31	25.3	48.3	3977
44	09-17-2012	12:55:31	25.2	49	4085
45	09-17-2012	13:00:31	25.3	48.5	4260
46	09-17-2012	13:05:31	25.4	49.8	4133
47	09-17-2012	13:10:31	25.3	49.2	4391
48	09-17-2012	13:15:31	25.2	48.1	4561
49	09-17-2012	13:20:31	25.3	48.2	4650

ตารางที่ ๑.1 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 17/9/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
50	09-17-2012	13:25:31	25.3	47.9	4799
51	09-17-2012	13:30:31	25.4	47.3	4899
52	09-17-2012	13:35:31	25.3	53.3	3956
53	09-17-2012	13:40:31	25.3	56.5	3403
54	09-17-2012	13:45:31	25.2	55.5	3493
55	09-17-2012	13:50:31	25.3	54.6	3454
56	09-17-2012	13:55:31	25.3	52.9	3585
57	09-17-2012	14:00:31	25.4	52.2	3606
58	09-17-2012	14:05:31	25.2	50.9	3726
59	09-17-2012	14:10:31	25.3	50.4	3722
60	09-17-2012	14:15:31	25.3	50.4	3720
61	09-17-2012	14:20:31	25.3	50.2	3720
62	09-17-2012	14:25:31	25.3	49.8	3747
63	09-17-2012	14:30:31	25.2	49.3	3776
64	09-17-2012	14:35:31	25.2	49.1	3816
65	09-17-2012	14:40:31	25.2	49.2	3793
66	09-17-2012	14:45:31	25.2	49.5	3731
67	09-17-2012	14:50:31	25.1	49.3	3629
68	09-17-2012	14:55:31	25.3	50	3567
69	09-17-2012	15:00:31	25.3	50.3	3505
70	09-17-2012	15:05:31	25.3	50.4	3475

ตารางที่ ๑.๒ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 25/9/2555

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	09-25-2012	8:16:50	27.9	58.9	557
2	09-25-2012	8:21:50	27.6	47.8	566
3	09-25-2012	8:26:50	27.3	46.3	571
4	09-25-2012	8:31:50	27.1	45.8	591
5	09-25-2012	8:36:50	26.9	45	641
6	09-25-2012	8:41:50	26.9	45.1	707
7	09-25-2012	8:46:50	26.8	46.1	803
8	09-25-2012	8:51:50	26.8	46	878
9	09-25-2012	8:56:50	26.8	46.4	989
10	09-25-2012	9:01:50	26.9	46.6	1098
11	09-25-2012	9:06:50	26.9	46.9	1212
12	09-25-2012	9:11:50	26.9	47.1	1354
13	09-25-2012	9:16:50	26.9	47.3	1467
14	09-25-2012	9:21:50	26.9	47.8	1579
15	09-25-2012	9:26:50	26.9	47.8	1721
16	09-25-2012	9:31:50	26.9	48.1	1871
17	09-25-2012	9:36:50	27	48.3	2023
18	09-25-2012	9:41:50	27.1	48.7	2205
19	09-25-2012	9:46:50	27.1	48.7	2357
20	09-25-2012	9:51:50	27.1	48.4	2494
21	09-25-2012	9:56:50	27.2	48	2679
22	09-25-2012	10:01:50	27.2	47.8	2867
23	09-25-2012	10:06:50	27.2	47.3	3041

ตารางที่ ๑.๒ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 25/9/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
24	09-25-2012	10:11:50	27.2	47.5	3158
25	09-25-2012	10:16:50	27.2	47.6	3409
26	09-25-2012	10:21:50	27.3	48.3	3596
27	09-25-2012	10:26:50	27.3	48.3	3765
28	09-25-2012	10:31:50	27.3	47.7	3982
29	09-25-2012	10:36:50	27.2	47.7	4118
30	09-25-2012	10:41:50	27.3	47	4308
31	09-25-2012	10:46:50	27.2	47.1	4495
32	09-25-2012	10:51:50	27.2	46.5	4671
33	09-25-2012	10:56:50	27.2	46.5	4832
34	09-25-2012	11:01:50	27.2	46.6	5034
35	09-25-2012	11:06:50	27.2	47	5169
36	09-25-2012	11:11:50	27.2	47.2	5305
37	09-25-2012	11:16:50	27.2	47.6	5452
38	09-25-2012	11:21:50	27.1	48.8	5301
39	09-25-2012	11:26:50	27.1	50.9	4462
40	09-25-2012	11:31:50	26.9	53.6	3761
41	09-25-2012	11:36:50	26.8	53.2	3437
42	09-25-2012	11:41:50	26.7	55.2	2939
43	09-25-2012	11:46:50	26.7	56.2	2703
44	09-25-2012	11:51:50	26.6	56.2	2431
45	09-25-2012	11:56:50	26.6	56.5	2169
46	09-25-2012	12:01:50	26.6	56.7	1986
47	09-25-2012	12:06:50	26.5	55.1	1852
48	09-25-2012	12:11:50	26.5	55.9	1691

ตารางที่ ๑.๒ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 25/9/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
49	09-25-2012	12:16:50	26.5	53.7	1594
50	09-25-2012	12:21:50	26.5	53.3	1498
51	09-25-2012	12:26:50	26.6	53	1393
52	09-25-2012	12:31:50	26.4	53.9	1271
53	09-25-2012	12:36:50	26.4	55.7	1147
54	09-25-2012	12:41:50	26.3	55.7	1083
55	09-25-2012	12:46:50	26.3	54.4	1060
56	09-25-2012	12:51:50	26.3	51.9	1065
57	09-25-2012	12:56:50	26.3	50.5	1051
58	09-25-2012	13:01:50	26.3	49.2	1039
59	09-25-2012	13:06:50	26.3	47.8	1031
60	09-25-2012	13:11:50	26.3	46.8	1018
61	09-25-2012	13:16:50	26.3	46.3	997
62	09-25-2012	13:21:50	26.3	45.8	979
63	09-25-2012	13:26:50	26.3	45.1	964
64	09-25-2012	13:31:50	26.2	44.2	948
65	09-25-2012	13:36:50	26.2	47.6	850
66	09-25-2012	13:41:50	26.1	49	850
67	09-25-2012	13:46:50	26.2	47.7	837
68	09-25-2012	13:51:50	26.2	46.4	827
69	09-25-2012	13:56:50	26.2	45.4	825
70	09-25-2012	14:01:50	26.2	44.6	816
71	09-25-2012	14:06:50	26.2	43.7	811
72	09-25-2012	14:11:50	26.2	43.5	796
73	09-25-2012	14:16:50	26.1	42.5	788

ตารางที่ ๑.๒ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 25/9/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
74	09-25-2012	14:21:50	26.1	42.3	779
75	09-25-2012	14:26:50	26.1	42.2	762
76	09-25-2012	14:31:50	26.1	42.4	761
77	09-25-2012	14:36:50	26.2	44.5	829
78	09-25-2012	14:41:50	26.3	46.4	959
79	09-25-2012	14:46:50	26.4	46.8	1120
80	09-25-2012	14:51:50	26.4	46.8	1294
81	09-25-2012	14:56:50	26.6	46.7	1459
82	09-25-2012	15:01:50	26.6	46.5	1619
83	09-25-2012	15:06:50	26.7	46.1	1775
84	09-25-2012	15:11:50	26.7	45.7	1928
85	09-25-2012	15:16:50	26.7	45.4	2055
86	09-25-2012	15:21:50	26.8	45.4	2214
87	09-25-2012	15:26:50	26.8	44.9	2335
88	09-25-2012	15:31:50	26.8	44.8	2447
89	09-25-2012	15:36:50	26.9	44.5	2578
90	09-25-2012	15:41:50	26.8	45.6	2575
91	09-25-2012	15:46:50	26.8	47.1	2295
92	09-25-2012	15:51:50	26.7	48.3	2032
93	09-25-2012	15:56:50	26.6	48.8	1865

ตารางที่ ๓.3 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 31/10/2555

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	10-31-2012	7:15:52	27.9	48.7	543
2	10-31-2012	7:20:52	27.1	49.2	549
3	10-31-2012	7:25:52	26.3	51.4	544
4	10-31-2012	7:30:52	25.7	52.4	539
5	10-31-2012	7:35:52	25.3	52.6	535
6	10-31-2012	7:40:52	25	53.3	531
7	10-31-2012	7:45:52	24.7	53.5	527
8	10-31-2012	7:50:52	24.6	54.3	539
9	10-31-2012	7:55:52	24.4	53.4	516
10	10-31-2012	8:00:52	24.4	53	514
11	10-31-2012	8:05:52	24.3	52.4	513
12	10-31-2012	8:10:52	24.2	51.3	509
13	10-31-2012	8:15:52	24.1	49.5	507
14	10-31-2012	8:20:52	24.1	48.6	507
15	10-31-2012	8:25:52	23.9	47.3	505
16	10-31-2012	8:30:52	23.9	46.4	505
17	10-31-2012	8:35:52	23.8	45.6	503
18	10-31-2012	8:40:52	23.7	44.7	504
19	10-31-2012	8:45:52	23.7	44.3	501
20	10-31-2012	8:50:52	23.6	42.5	498
21	10-31-2012	8:55:52	23.6	42.9	498
22	10-31-2012	9:00:52	23.6	40.8	496
23	10-31-2012	9:05:52	23.7	41.6	495
24	10-31-2012	9:10:52	23.7	40.2	493
25	10-31-2012	9:15:52	23.7	39.3	494

ตารางที่ ๓.3 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 31/10/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
26	10-31-2012	9:20:52	23.6	39.6	494
27	10-31-2012	9:25:52	23.6	38.5	491
28	10-31-2012	9:30:52	23.6	38.7	491
29	10-31-2012	9:35:52	23.6	38.2	488
30	10-31-2012	9:40:52	23.6	38.1	488
31	10-31-2012	9:45:52	23.6	38.2	488
32	10-31-2012	9:50:52	23.6	36.8	484
33	10-31-2012	9:55:52	23.6	37.3	486
34	10-31-2012	10:00:52	23.5	36.1	485
35	10-31-2012	10:05:52	23.5	37	484
36	10-31-2012	10:10:52	23.6	35.9	482
37	10-31-2012	10:15:52	23.5	36	482
38	10-31-2012	10:20:52	23.5	35.1	482
39	10-31-2012	10:25:52	23.4	35.6	481
40	10-31-2012	10:30:52	23.5	35.7	481
41	10-31-2012	10:35:52	23.4	35.4	480
42	10-31-2012	10:40:52	23.4	35.4	480
43	10-31-2012	10:45:52	23.4	34.5	479
44	10-31-2012	10:50:52	23.4	35	477
45	10-31-2012	10:55:52	23.4	34.4	477
46	10-31-2012	11:00:52	23.4	35.2	475
47	10-31-2012	11:05:52	23.4	35	473
48	10-31-2012	11:10:52	23.3	34.4	472
49	10-31-2012	11:15:52	23.3	34.8	471
50	10-31-2012	11:20:52	23.4	34.2	469

ตารางที่ ๓.3 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 31/10/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
51	10-31-2012	11:25:52	23.3	34.6	468
52	10-31-2012	11:30:52	23.3	34.4	468
53	10-31-2012	11:35:52	23.3	34	469
54	10-31-2012	11:40:52	23.3	34.2	470
55	10-31-2012	11:45:52	23.3	33.5	471
56	10-31-2012	11:50:52	23.3	34.2	474
57	10-31-2012	11:55:52	23.3	34.2	475
58	10-31-2012	12:00:52	23.3	35	479
59	10-31-2012	12:05:52	23.3	38.6	561
60	10-31-2012	12:10:52	23.3	43.1	663
61	10-31-2012	12:15:52	23.6	42.8	805
62	10-31-2012	12:20:52	23.6	43.1	917
63	10-31-2012	12:25:52	23.8	45.5	999
64	10-31-2012	12:30:52	23.7	47.1	1091
65	10-31-2012	12:35:52	23.7	48.5	1188
66	10-31-2012	12:40:52	23.8	47.6	1328
67	10-31-2012	12:45:52	24.1	45.9	1411
68	10-31-2012	12:50:52	24	47.3	1358
69	10-31-2012	12:55:52	24	48.3	1345
70	10-31-2012	13:00:52	23.9	50.1	1333
71	10-31-2012	13:05:52	24	50.4	1255
72	10-31-2012	13:10:52	24.4	50.5	1175
73	10-31-2012	13:15:52	24.4	51.3	1101
74	10-31-2012	13:20:52	24.3	51	1099
75	10-31-2012	13:25:52	24.3	50.8	1098

ตารางที่ ๓.3 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 31/10/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
76	10-31-2012	13:30:52	24.2	50.2	1096
77	10-31-2012	13:35:52	24.2	50.5	1113
78	10-31-2012	13:40:52	24.1	49.4	1128
79	10-31-2012	13:45:52	24.1	48	1139
80	10-31-2012	13:50:52	24.1	47	1155
81	10-31-2012	13:55:52	23.9	46.4	1169
82	10-31-2012	14:00:52	24.1	44.1	1190
83	10-31-2012	14:05:52	24.1	44.1	1206
84	10-31-2012	14:10:52	24.3	43.1	1224
85	10-31-2012	14:15:52	24.1	42.1	1243
86	10-31-2012	14:20:52	24.2	41.7	1254
87	10-31-2012	14:25:52	24.1	40.6	1272
88	10-31-2012	14:30:52	24.1	40.2	1287
89	10-31-2012	14:35:52	24	39.8	1298
90	10-31-2012	14:40:52	24.1	39.5	1313
91	10-31-2012	14:45:52	24	39.4	1324
92	10-31-2012	14:50:52	23.9	39.2	1328
93	10-31-2012	14:55:52	23.9	39.2	1339
94	10-31-2012	15:00:52	23.8	38.4	1357
95	10-31-2012	15:05:52	23.9	38.3	1366
96	10-31-2012	15:10:52	24	37.7	1386
97	10-31-2012	15:15:52	24.1	37.6	1392
98	10-31-2012	15:20:52	24	37.2	1402
99	10-31-2012	15:25:52	24	37.1	1411
100	10-31-2012	15:30:52	23.9	36.7	1426

ตารางที่ ๓.3 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 31/10/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
101	10-31-2012	15:35:52	23.9	36.4	1434
102	10-31-2012	15:40:52	23.9	36.6	1444
103	10-31-2012	15:45:52	23.9	35.9	1459
104	10-31-2012	15:50:52	23.9	36	1461
105	10-31-2012	15:55:52	24	35.5	1473
106	10-31-2012	16:00:52	24	35.9	1475
107	10-31-2012	16:05:52	23.9	35.5	1488
108	10-31-2012	16:10:52	24	35.7	1491
109	10-31-2012	16:15:52	23.9	35.8	1503
110	10-31-2012	16:20:52	23.9	36.7	1467
111	10-31-2012	16:25:52	23.8	36.9	1442
112	10-31-2012	16:30:52	23.8	37.1	1430
113	10-31-2012	16:35:52	23.8	39.8	1468
114	10-31-2012	16:40:52	23.7	40.3	1518
115	10-31-2012	16:45:52	23.7	41.4	1586
116	10-31-2012	16:50:52	23.7	42.2	1676
117	10-31-2012	16:55:52	23.7	42.5	1798
118	10-31-2012	17:00:52	23.7	44.5	1909
119	10-31-2012	17:05:52	23.7	46.7	2034
120	10-31-2012	17:10:52	23.7	47.2	2180
121	10-31-2012	17:15:52	23.8	47.9	2340
122	10-31-2012	17:20:52	23.8	47	2480
123	10-31-2012	17:25:52	23.7	46.8	2644
124	10-31-2012	17:30:52	23.7	47	2822
125	10-31-2012	17:35:52	23.7	47.5	2965

ตารางที่ ๓.3 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 31/10/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
126	10-31-2012	17:40:52	23.7	48.6	3116
127	10-31-2012	17:45:52	23.7	47.1	3229
128	10-31-2012	17:50:52	23.7	48.1	3379
129	10-31-2012	17:55:52	23.7	46.5	3493
130	10-31-2012	18:00:52	23.7	47.7	3608
131	10-31-2012	18:05:52	23.8	47.9	3750
132	10-31-2012	18:10:52	23.8	47.3	3864
133	10-31-2012	18:15:52	23.7	46.5	3957
134	10-31-2012	18:20:52	23.7	47.4	4104
135	10-31-2012	18:25:52	23.7	46.5	4214
136	10-31-2012	18:30:52	23.7	46.1	4345
137	10-31-2012	18:35:52	23.7	46.1	4467
138	10-31-2012	18:40:52	23.7	45.6	4567
139	10-31-2012	18:45:52	23.7	46.4	4714
140	10-31-2012	18:50:52	23.7	50.3	4252

ตารางที่ ๑.๔ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 5/11/2555

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	11/5/2012	7:29:19	27.6	72.6	501
2	11/5/2012	7:34:19	28.1	62.2	479
3	11/5/2012	7:39:19	27.9	55.6	473
4	11/5/2012	7:44:19	27.6	50.2	473
5	11/5/2012	7:49:19	27.2	46.4	470
6	11/5/2012	7:54:19	26.9	45	471
7	11/5/2012	7:59:19	26.7	44.2	469
8	11/5/2012	8:04:19	26.4	42.9	468
9	11/5/2012	8:09:19	26.2	41.8	468
10	11/5/2012	8:14:19	26	40.7	466
11	11/5/2012	8:19:19	25.8	39.9	465
12	11/5/2012	8:24:19	25.7	41.6	464
13	11/5/2012	8:29:19	25.5	40.8	462
14	11/5/2012	8:34:19	25.4	40	463
15	11/5/2012	8:39:19	25.3	41.6	462
16	11/5/2012	8:44:19	25.2	41.3	460
17	11/5/2012	8:49:19	25.1	42.6	462
18	11/5/2012	8:54:19	25	42.3	462
19	11/5/2012	8:59:19	24.9	42.9	460
20	11/5/2012	9:04:19	24.9	42.1	460
21	11/5/2012	9:09:19	24.9	42.8	459
22	11/5/2012	9:14:19	24.8	43.2	459
23	11/5/2012	9:19:19	24.8	42.9	459
24	11/5/2012	9:24:19	24.7	43.4	459
25	11/5/2012	9:29:19	24.7	42.5	457

ตารางที่ ๑.๔ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 5/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
26	11/5/2012	9:34:19	24.6	43.4	457
27	11/5/2012	9:39:19	24.6	43.8	455
28	11/5/2012	9:44:19	24.6	43	456
29	11/5/2012	9:49:19	24.5	43.8	456
30	11/5/2012	9:54:19	24.5	44.5	454
31	11/5/2012	9:59:19	24.4	43.5	452
32	11/5/2012	10:04:19	24.4	44.2	452
33	11/5/2012	10:09:19	24.4	44.8	450
34	11/5/2012	10:14:19	24.3	45.3	450
35	11/5/2012	10:19:19	24.3	45.5	449
36	11/5/2012	10:24:19	24.3	44.8	448
37	11/5/2012	10:29:19	24.3	45.2	449
38	11/5/2012	10:34:19	24.2	45.7	449
39	11/5/2012	10:39:19	24.2	45.8	451
40	11/5/2012	10:44:19	24.2	44.6	449
41	11/5/2012	10:49:19	24.2	45.9	448
42	11/5/2012	10:54:19	24.1	44.6	448
43	11/5/2012	10:59:19	24.1	45.6	447
44	11/5/2012	11:04:19	24.1	45.7	446
45	11/5/2012	11:09:19	24.1	46	445
46	11/5/2012	11:14:19	-	-	-
47	11/5/2012	11:19:19	24	46.7	443
48	11/5/2012	11:24:19	24.2	48.7	444
49	11/5/2012	11:29:19	24.2	47.8	443
50	11/5/2012	11:34:19	24.1	47.2	443

ตารางที่ ๑.๔ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 5/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
51	11/5/2012	11:39:19	24.1	47.1	442
52	11/5/2012	11:44:19	24.1	46.8	440
53	11/5/2012	11:49:19	24	46.8	439
54	11/5/2012	11:54:19	23.9	46.8	437
55	11/5/2012	11:59:19	23.9	47	437
56	11/5/2012	12:04:19	23.9	46.8	435
57	11/5/2012	12:09:19	23.8	46.2	433
58	11/5/2012	12:14:19	23.8	45.9	435
59	11/5/2012	12:19:19	23.8	45.8	433
60	11/5/2012	12:24:19	23.7	45.6	433
61	11/5/2012	12:29:19	23.7	45.7	432
62	11/5/2012	12:34:19	23.6	45.7	430
63	11/5/2012	12:39:19	23.6	45.8	444
64	11/5/2012	12:44:19	23.6	45.9	455
65	11/5/2012	12:49:19	23.6	45.9	466
66	11/5/2012	12:54:19	23.5	45.9	469
67	11/5/2012	12:59:19	23.7	49.2	498
68	11/5/2012	13:04:19	23.9	53.4	569
69	11/5/2012	13:09:19	24.2	57.1	648
70	11/5/2012	13:14:19	24.4	60	767
71	11/5/2012	13:19:19	24.7	64.2	981
72	11/5/2012	13:24:19	24.9	67.1	1249
73	11/5/2012	13:29:19	25	66.1	1498
74	11/5/2012	13:34:19	25.1	65.5	1737
75	11/5/2012	13:39:19	25.2	64.4	1960

ตารางที่ ๑.๔ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 5/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
76	11/5/2012	13:44:19	25.2	63.4	2178
77	11/5/2012	13:49:19	25.2	63.1	2333
78	11/5/2012	13:54:19	25.3	62.9	2483
79	11/5/2012	13:59:19	25.1	63.4	2696
80	11/5/2012	14:04:19	25.3	62	2846
81	11/5/2012	14:09:19	25.4	60.5	3044
82	11/5/2012	14:14:19	25.7	59.1	3222
83	11/5/2012	14:19:19	25.7	57.8	3407
84	11/5/2012	14:24:19	25.7	56.9	3570
85	11/5/2012	14:29:19	25.7	56.1	3723
86	11/5/2012	14:34:19	25.8	55.6	3856
87	11/5/2012	14:39:19	25.7	55	3998
88	11/5/2012	14:44:19	25.9	55	4118
89	11/5/2012	14:49:19	25.9	54.1	4230
90	11/5/2012	14:54:19	25.9	53	4373
91	11/5/2012	14:59:19	25.9	52.3	4508
92	11/5/2012	15:04:19	25.9	51.7	4602
93	11/5/2012	15:09:19	25.8	52	4576
94	11/5/2012	15:14:19	25.9	52.1	4472
95	11/5/2012	15:19:19	25.9	51.9	4492
96	11/5/2012	15:24:19	25.9	51.7	4591
97	11/5/2012	15:29:19	25.9	51.5	4698
98	11/5/2012	15:34:19	26	51.1	4797
99	11/5/2012	15:39:19	26.1	50.7	4896
100	11/5/2012	15:44:19	26	50.6	4980

ตารางที่ ๑.๔ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 5/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
101	11/5/2012	15:49:19	25.9	50.4	5101
102	11/5/2012	15:54:19	25.9	50.1	5203
103	11/5/2012	15:59:19	25.9	49.7	5341
104	11/5/2012	16:04:19	25.9	49.5	5434
105	11/5/2012	16:09:19	25.9	49.1	5441
106	11/5/2012	16:14:19	25.9	48.9	5459
107	11/5/2012	16:19:19	26.1	49.1	5363

ตารางที่ ๑.5 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 20/11/2555

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	11/20/2012	7:34:26	27.7	47.8	501
2	11/20/2012	7:39:26	26.3	43.4	492
3	11/20/2012	7:44:26	25.3	45.9	484
4	11/20/2012	7:49:26	24.9	48	483
5	11/20/2012	7:54:26	24.6	49.9	485
6	11/20/2012	7:59:26	24.3	48.6	482
7	11/20/2012	8:04:26	24.1	46.6	483
8	11/20/2012	8:09:26	23.8	45.8	482
9	11/20/2012	8:14:26	23.6	45.8	482
10	11/20/2012	8:19:26	23.4	45.6	482
11	11/20/2012	8:24:26	23.2	45.5	481
12	11/20/2012	8:29:26	23.1	45.5	479
13	11/20/2012	8:34:26	23	45.1	485
14	11/20/2012	8:39:26	22.9	45.4	497
15	11/20/2012	8:44:26	22.9	46.4	546
16	11/20/2012	8:49:26	22.8	46.1	583
17	11/20/2012	8:54:26	22.8	46.4	644
18	11/20/2012	8:59:26	22.8	46.7	700
19	11/20/2012	9:04:26	22.7	46.5	755
20	11/20/2012	9:09:26	22.7	46	807
21	11/20/2012	9:14:26	22.9	46.1	858
22	11/20/2012	9:19:26	22.9	46.4	941
23	11/20/2012	9:24:26	22.8	46.3	1023
24	11/20/2012	9:29:26	22.8	45.8	1101
25	11/20/2012	9:34:26	22.9	45.3	1165

ตารางที่ ๕.5 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 20/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
26	11/20/2012	9:39:26	22.9	45.6	1255
27	11/20/2012	9:44:26	22.8	45.6	1346
28	11/20/2012	9:49:26	22.9	45.7	1436
29	11/20/2012	9:54:26	22.9	45.3	1507
30	11/20/2012	9:59:26	23	45.4	1588
31	11/20/2012	10:04:26	23	45.6	1676
32	11/20/2012	10:09:26	23.1	44.6	1768
33	11/20/2012	10:14:26	23.1	45.2	1891
34	11/20/2012	10:19:26	23.1	43.9	1961
35	11/20/2012	10:24:26	23.1	44.2	2093
36	11/20/2012	10:29:26	23.1	43.8	2191
37	11/20/2012	10:34:26	23.1	44.2	2294
38	11/20/2012	10:39:26	23.1	44.9	2398
39	11/20/2012	10:44:26	23.1	44.3	2478
40	11/20/2012	10:49:26	23.1	44.8	2608
41	11/20/2012	10:54:26	23.2	44.9	2705
42	11/20/2012	10:59:26	23.1	44.1	2820
43	11/20/2012	11:04:26	23.1	43.2	2984
44	11/20/2012	11:09:26	23.1	42.8	3125
45	11/20/2012	11:14:26	23.1	42.7	3294
46	11/20/2012	11:19:26	23.1	42.5	3485
47	11/20/2012	11:24:26	23.1	43.3	3575
48	11/20/2012	11:29:26	23.2	49.2	3152
49	11/20/2012	11:34:26	23.1	51.2	2875
50	11/20/2012	11:39:26	23.2	50	2798

ตารางที่ ๕.5 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 20/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
51	11/20/2012	11:44:26	23.3	49.1	2897
52	11/20/2012	11:49:26	23.2	47.5	2997
53	11/20/2012	11:54:26	23.2	46.7	3115
54	11/20/2012	11:59:26	23.1	45.8	3239
55	11/20/2012	12:04:26	23.1	45.7	3308
56	11/20/2012	12:09:26	23.1	45.5	3401
57	11/20/2012	12:14:26	23.1	44.6	3500
58	11/20/2012	12:19:26	23.1	43.6	3642
59	11/20/2012	12:24:26	23.1	43.2	3734
60	11/20/2012	12:29:26	22.9	42.4	3857
61	11/20/2012	12:34:26	22.9	42	3965
62	11/20/2012	12:39:26	22.9	42.9	4110
63	11/20/2012	12:44:26	23.1	42.6	4223
64	11/20/2012	12:49:26	23.1	43.7	4312
65	11/20/2012	12:54:26	23.2	43	4443
66	11/20/2012	12:59:26	23.1	42	4507
67	11/20/2012	13:04:26	23.1	41.7	4700
68	11/20/2012	13:09:26	23	40.2	4726
69	11/20/2012	13:14:26	23.1	42.5	4840
70	11/20/2012	13:19:26	23.1	41.6	4936
71	11/20/2012	13:24:26	23.1	43	4952
72	11/20/2012	13:29:26	23.2	42.5	4971
73	11/20/2012	13:34:26	23.3	42	5018
74	11/20/2012	13:39:26	23.2	44.2	4889
75	11/20/2012	13:44:26	23.3	43.4	4925

ตารางที่ ๕.5 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 20/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
76	11/20/2012	13:49:26	23.2	44.8	4941
77	11/20/2012	13:54:26	23.1	43.9	4946
78	11/20/2012	13:59:26	23.2	43.5	4999
79	11/20/2012	14:04:26	23	43.7	5071
80	11/20/2012	14:09:26	23.2	43.4	5138
81	11/20/2012	14:14:26	23.1	42.3	5206
82	11/20/2012	14:19:26	23.3	49.5	4281
83	11/20/2012	14:24:26	23.5	49.5	3799
84	11/20/2012	14:29:26	23.4	46.4	3868
85	11/20/2012	14:34:26	23.3	46.9	3688
86	11/20/2012	14:39:26	23.3	47	3527
87	11/20/2012	14:44:26	23.3	49	3568
88	11/20/2012	14:49:26	23.1	47.9	3592
89	11/20/2012	14:54:26	23.1	47.7	3705
90	11/20/2012	14:59:26	23.1	47	3810
91	11/20/2012	15:04:26	23.4	51.2	3218
92	11/20/2012	15:09:26	23.5	53	2703
93	11/20/2012	15:14:26	23.4	48.9	2724
94	11/20/2012	15:19:26	23.2	47.8	2677
95	11/20/2012	15:24:26	23.1	47.5	2608
96	11/20/2012	15:29:26	23.1	48.4	2552
97	11/20/2012	15:34:26	23.2	48.3	2559
98	11/20/2012	15:39:26	23.1	47.7	2560
99	11/20/2012	15:44:26	23.4	48.7	2563
100	11/20/2012	15:49:26	23.6	48.1	2706

ตารางที่ ๑.5 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 80 คน
ณ วันที่ 20/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
101	11/20/2012	15:54:26	23.5	46.5	2816
102	11/20/2012	15:59:26	23.5	47.1	2927
103	11/20/2012	16:04:26	23.4	45.9	2996
104	11/20/2012	16:09:26	23.6	46.3	3135
105	11/20/2012	16:14:26	23.4	44.8	3244
106	11/20/2012	16:19:26	23.3	45.2	3407
107	11/20/2012	16:24:26	23.3	46.4	3539
108	11/20/2012	16:29:26	23.4	44.5	3637
109	11/20/2012	16:34:26	23.4	42.7	3748
110	11/20/2012	16:39:26	23.3	43.3	3891
111	11/20/2012	16:44:26	23.3	44.6	3973
112	11/20/2012	16:49:26	23.2	44.6	4098
113	11/20/2012	16:54:26	23.2	43.6	4192
114	11/20/2012	16:59:26	23.1	43.1	4337
115	11/20/2012	17:04:26	23.2	43	4376
116	11/20/2012	17:09:26	23.1	43.8	4463
117	11/20/2012	17:14:26	23.2	46.1	4370
118	11/20/2012	17:19:26	23.6	48.9	3471
119	11/20/2012	17:24:26	23.4	49	3074

ตารางที่ ๑.๖ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 16/11/2555

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	11/16/2012	7:23:25	27.4	61.8	523
2	11/16/2012	7:28:25	26.4	58.3	514
3	11/16/2012	7:33:25	24.7	61	509
4	11/16/2012	7:38:25	24.8	61.9	505
5	11/16/2012	7:43:25	25.1	61.9	499
6	11/16/2012	7:48:25	25.6	61	492
7	11/16/2012	7:53:25	25.9	58.9	492
8	11/16/2012	7:58:25	26.3	57.9	489
9	11/16/2012	8:03:25	26.4	57	492
10	11/16/2012	8:08:25	26.4	57.6	490
11	11/16/2012	8:13:25	26.6	57	486
12	11/16/2012	8:18:25	26.6	56.3	487
13	11/16/2012	8:23:25	26.8	56.2	481
14	11/16/2012	8:28:25	26.7	56.1	495
15	11/16/2012	8:33:25	26.7	56.9	544
16	11/16/2012	8:38:25	26.4	55.8	651
17	11/16/2012	8:43:25	26.9	53.4	794
18	11/16/2012	8:48:25	27	54.7	950
19	11/16/2012	8:53:25	27.1	52	1055
20	11/16/2012	8:58:25	27.1	50.7	1206
21	11/16/2012	9:03:25	27.1	49.8	1339
22	11/16/2012	9:08:25	26.9	47.8	1445
23	11/16/2012	9:13:25	26.8	47	1574
24	11/16/2012	9:18:25	26.9	46.6	1700
25	11/16/2012	9:23:25	26.8	46.1	1804

ตารางที่ ๑.๖ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 16/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
26	11/16/2012	9:28:25	26.6	45.4	1884
27	11/16/2012	9:33:25	26.5	45.3	1951
28	11/16/2012	9:38:25	26.6	46.7	2051
29	11/16/2012	9:43:25	26.6	46.1	2133
30	11/16/2012	9:48:25	26.8	46.8	2196
31	11/16/2012	9:53:25	26.7	46	2281
32	11/16/2012	9:58:25	26.5	45	2310
33	11/16/2012	10:03:25	26.5	44.5	2336
34	11/16/2012	10:08:25	26.4	44.1	2367
35	11/16/2012	10:13:25	26.7	45.6	2425
36	11/16/2012	10:18:25	26.7	44.4	2411
37	11/16/2012	10:23:25	26.6	43.6	2423
38	11/16/2012	10:28:25	26.8	46.8	2122
39	11/16/2012	10:33:25	26.9	46.4	1954
40	11/16/2012	10:38:25	26.9	48.5	1752
41	11/16/2012	10:43:25	27.1	51.4	1583
42	11/16/2012	10:48:25	27	49.9	1425
43	11/16/2012	10:53:25	27.1	50.2	1304
44	11/16/2012	10:58:25	27.2	50.8	1234
45	11/16/2012	11:03:25	27.3	51.2	1166
46	11/16/2012	11:08:25	27.2	52.9	1090
47	11/16/2012	11:13:25	27.1	53.5	1028
48	11/16/2012	11:18:25	27.1	52.6	976
49	11/16/2012	11:23:25	27.1	52.8	933
50	11/16/2012	11:28:25	27	54.6	908

ตารางที่ ๑.๖ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 16/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
51	11/16/2012	11:33:25	27.1	53.3	858
52	11/16/2012	11:38:25	27	51.5	839
53	11/16/2012	11:43:25	26.9	51.7	811
54	11/16/2012	11:48:25	26.9	53.4	796
55	11/16/2012	11:53:25	26.9	51.2	767
56	11/16/2012	11:58:25	26.9	49.1	740
57	11/16/2012	12:03:25	26.8	47.1	727
58	11/16/2012	12:08:25	26.8	51.1	715
59	11/16/2012	12:13:25	26.8	52.5	691
60	11/16/2012	12:18:25	26.8	49.4	666
61	11/16/2012	12:23:25	26.8	48.3	654
62	11/16/2012	12:28:25	26.8	50.3	640
63	11/16/2012	12:33:25	26.9	50.8	633
64	11/16/2012	12:38:25	26.8	49.6	623
65	11/16/2012	12:43:25	26.8	49.5	601
66	11/16/2012	12:48:25	26.7	49.5	593
67	11/16/2012	12:53:25	26.5	52	579
68	11/16/2012	12:58:25	26.8	50.8	573
69	11/16/2012	13:03:25	26.9	52.8	567
70	11/16/2012	13:08:25	26.9	54.3	559
71	11/16/2012	13:13:25	27	53.3	552
72	11/16/2012	13:18:25	26.9	52.1	545
73	11/16/2012	13:23:25	26.9	53.6	540
74	11/16/2012	13:28:25	26.8	54.1	535
75	11/16/2012	13:33:25	26.9	51.8	529

ตารางที่ ๘.๖ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 16/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
76	11/16/2012	13:38:25	27.1	53.3	520
77	11/16/2012	13:43:25	27	52.7	521
78	11/16/2012	13:48:25	27	52.9	515
79	11/16/2012	13:53:25	27	52.3	516
80	11/16/2012	13:58:25	27	53.3	516
81	11/16/2012	14:03:25	27	54.5	514
82	11/16/2012	14:08:25	27.1	56.2	518
83	11/16/2012	14:13:25	27	55.4	516
84	11/16/2012	14:18:25	26.9	54.3	514
85	11/16/2012	14:23:25	26.9	54.2	513
86	11/16/2012	14:28:25	26.8	53.7	512
87	11/16/2012	14:33:25	27.1	55.9	511
88	11/16/2012	14:38:25	27.2	57	511
89	11/16/2012	14:43:25	27.1	54.7	514
90	11/16/2012	14:48:25	27	56.7	519
91	11/16/2012	14:53:25	27.1	55.6	517
92	11/16/2012	14:58:25	27	55	519
93	11/16/2012	15:03:25	27	54.6	521
94	11/16/2012	15:08:25	27.1	57	519
95	11/16/2012	15:13:25	27	55.6	523
96	11/16/2012	15:18:25	26.9	53.8	527
97	11/16/2012	15:23:25	26.9	56	530
98	11/16/2012	15:28:25	27	57.8	532
99	11/16/2012	15:33:25	27	55.5	556
100	11/16/2012	15:38:25	27.1	55.8	646

ตารางที่ ๑.๖ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 16/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
101	11/16/2012	15:43:25	27.1	52.7	761
102	11/16/2012	15:48:25	27.2	53.2	880
103	11/16/2012	15:53:25	27.2	54.7	1011
104	11/16/2012	15:58:25	27.1	51.5	1160
105	11/16/2012	16:03:25	26.9	50	1354
106	11/16/2012	16:08:25	26.8	48.6	1528
107	11/16/2012	16:13:25	26.7	47	1708
108	11/16/2012	16:18:25	26.7	44.7	1895
109	11/16/2012	16:23:25	26.7	45.6	2037
110	11/16/2012	16:28:25	26.7	45.7	2178
111	11/16/2012	16:33:25	26.7	42.9	2348
112	11/16/2012	16:38:25	26.8	43.9	2485
113	11/16/2012	16:43:25	26.8	44.8	2627
114	11/16/2012	16:48:25	26.8	41.9	2792
115	11/16/2012	16:53:25	26.8	42.7	2931
116	11/16/2012	16:58:25	26.7	43.9	3077
117	11/16/2012	17:03:25	26.7	45	3176
118	11/16/2012	17:08:25	26.7	43	3266
119	11/16/2012	17:13:25	26.6	44.1	3423
120	11/16/2012	17:18:25	26.7	45.6	3556
121	11/16/2012	17:23:25	26.7	46.8	3651
122	11/16/2012	17:28:25	26.7	45.5	3742
123	11/16/2012	17:33:25	26.7	45.4	3845
124	11/16/2012	17:38:25	26.7	44.5	3929
125	11/16/2012	17:43:25	26.7	42.2	4001

ตารางที่ ๗.7 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 23/11/2555

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	11/23/2012	7:21:38	28.6	57.5	499
2	11/23/2012	7:26:38	26.5	55.2	475
3	11/23/2012	7:31:38	26.2	56.9	474
4	11/23/2012	7:36:38	26.3	56.7	472
5	11/23/2012	7:41:38	26.6	58.9	470
6	11/23/2012	7:46:38	26.7	57.8	470
7	11/23/2012	7:51:38	26.9	54.1	471
8	11/23/2012	7:56:38	27.2	54.6	474
9	11/23/2012	8:01:38	27.1	55.4	478
10	11/23/2012	8:06:38	27.1	55.6	480
11	11/23/2012	8:11:38	27.3	55.9	480
12	11/23/2012	8:16:38	27.3	54.9	497
13	11/23/2012	8:21:38	27.2	54.4	523
14	11/23/2012	8:26:38	27.2	53.3	543
15	11/23/2012	8:31:38	27.1	53.1	577
16	11/23/2012	8:36:38	27.1	54.1	642
17	11/23/2012	8:41:38	27.1	54	818
18	11/23/2012	8:46:38	27.1	52.6	973
19	11/23/2012	8:51:38	27.1	51.5	1166
20	11/23/2012	8:56:38	27.2	51.3	1386
21	11/23/2012	9:01:38	27.2	51.8	1627
22	11/23/2012	9:06:38	27.1	49.5	1797
23	11/23/2012	9:11:38	27.2	48.1	2054
24	11/23/2012	9:16:38	27.2	48.5	2297
25	11/23/2012	9:21:38	27.2	47.9	2511

ตารางที่ ๗.7 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 23/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
26	11/23/2012	9:26:38	27.2	46.8	2724
27	11/23/2012	9:31:38	27.2	46.6	2949
28	11/23/2012	9:36:38	27.2	47.3	3177
29	11/23/2012	9:41:38	27.3	47.2	3368
30	11/23/2012	9:46:38	27.2	44.9	3528
31	11/23/2012	9:51:38	27.1	44.1	3752
32	11/23/2012	9:56:38	27.2	45.3	3966
33	11/23/2012	10:01:38	27.2	44.1	4128
34	11/23/2012	10:06:38	27.1	43.6	4320
35	11/23/2012	10:11:38	27.1	43.1	4517
36	11/23/2012	10:16:38	27	42.6	4682
37	11/23/2012	10:21:38	27.1	43.5	4769
38	11/23/2012	10:26:38	27.1	43.1	4973
39	11/23/2012	10:31:38	27.1	46.4	4259
40	11/23/2012	10:36:38	27.1	47.7	3814
41	11/23/2012	10:41:38	27.1	49.3	3623
42	11/23/2012	10:46:38	27.1	49.8	3516
43	11/23/2012	10:51:38	27.1	50.8	3341
44	11/23/2012	10:56:38	27.1	52.3	3158
45	11/23/2012	11:01:38	27.1	52.8	3010
46	11/23/2012	11:06:38	27.1	54.5	2792
47	11/23/2012	11:11:38	27.1	54.3	2600
48	11/23/2012	11:16:38	27.1	54.8	2447
49	11/23/2012	11:21:38	27.1	54	2331
50	11/23/2012	11:26:38	27.1	54.9	2224

ตารางที่ ๑.๗ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 23/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
51	11/23/2012	11:31:38	27.1	57.5	2110
52	11/23/2012	11:36:38	27.1	57.6	2004
53	11/23/2012	11:41:38	27.1	58.1	1909
54	11/23/2012	11:46:38	27	55.3	1830
55	11/23/2012	11:51:38	27	57.3	1740
56	11/23/2012	11:56:38	26.9	57.9	1644
57	11/23/2012	12:01:38	27.1	57.9	1555
58	11/23/2012	12:06:38	27.1	57.7	1464
59	11/23/2012	12:11:38	27	56.2	1375
60	11/23/2012	12:16:38	26.9	54.5	1330
61	11/23/2012	12:21:38	26.9	55.8	1249
62	11/23/2012	12:26:38	26.9	56.5	1197
63	11/23/2012	12:31:38	27	56.9	1155
64	11/23/2012	12:36:38	27	56.9	1105
65	11/23/2012	12:41:38	26.9	55.6	1079
66	11/23/2012	12:46:38	26.8	54.8	1052
67	11/23/2012	12:51:38	26.9	56.9	1027
68	11/23/2012	12:56:38	26.9	57.5	989
69	11/23/2012	13:01:38	26.9	56	942
70	11/23/2012	13:06:38	26.9	57.1	904
71	11/23/2012	13:11:38	26.9	57.6	884
72	11/23/2012	13:16:38	26.9	57.5	865
73	11/23/2012	13:21:38	26.9	56.9	849
74	11/23/2012	13:26:38	26.9	56.3	840
75	11/23/2012	13:31:38	26.9	55.9	834

ตารางที่ ก.7 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 23/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
76	11/23/2012	13:36:38	26.9	55.9	823
77	11/23/2012	13:41:38	27	57.4	811
78	11/23/2012	13:46:38	26.9	57.8	802
79	11/23/2012	13:51:38	27	58.4	787
80	11/23/2012	13:56:38	27	56.9	776
81	11/23/2012	14:01:38	26.9	57	757
82	11/23/2012	14:06:38	26.9	55.9	743
83	11/23/2012	14:11:38	27	55.9	730
84	11/23/2012	14:16:38	27	56	721
85	11/23/2012	14:21:38	27	57.3	707
86	11/23/2012	14:26:38	26.9	58.3	694
87	11/23/2012	14:31:38	26.9	58.5	680
88	11/23/2012	14:36:38	26.9	56.7	671
89	11/23/2012	14:41:38	26.9	56.9	665
90	11/23/2012	14:46:38	26.9	55.8	655
91	11/23/2012	14:51:38	26.9	55.6	648
92	11/23/2012	14:56:38	26.9	56.3	645
93	11/23/2012	15:01:38	27	58.9	642
94	11/23/2012	15:06:38	27	59	635
95	11/23/2012	15:11:38	26.9	57.8	627
96	11/23/2012	15:16:38	26.9	56.5	625
97	11/23/2012	15:21:38	26.9	56	621
98	11/23/2012	15:26:38	26.9	58	620
99	11/23/2012	15:31:38	26.9	58.7	620
100	11/23/2012	15:36:38	26.9	57.4	623

ตารางที่ ๑.7 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 23/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
101	11/23/2012	15:41:38	26.9	55.1	626
102	11/23/2012	15:46:38	26.9	56	623
103	11/23/2012	15:51:38	27	58.4	622
104	11/23/2012	15:56:38	26.9	56.6	615
105	11/23/2012	16:01:38	26.9	57.1	616

ตารางที่ ๘.8 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 23/01/2556

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	1/23/2013	7:24:09	27.6	59.6	535
2	1/23/2013	7:29:09	26.6	51.7	530
3	1/23/2013	7:34:09	26	52.2	527
4	1/23/2013	7:39:09	25.8	54.9	528
5	1/23/2013	7:44:09	25.6	56.3	524
6	1/23/2013	7:49:09	25.5	58	524
7	1/23/2013	7:54:09	25.3	58.1	520
8	1/23/2013	7:59:09	25.1	58.9	517
9	1/23/2013	8:04:09	25.1	57.5	515
10	1/23/2013	8:09:09	24.9	57.2	514
11	1/23/2013	8:14:09	24.9	58.1	511
12	1/23/2013	8:19:09	24.9	59.5	514
13	1/23/2013	8:24:09	24.8	60	544
14	1/23/2013	8:29:09	24.9	60.9	620
15	1/23/2013	8:34:09	24.7	58.2	841
16	1/23/2013	8:39:09	24.9	56.4	1018
17	1/23/2013	8:44:09	25	56.2	1202
18	1/23/2013	8:49:09	24.9	55.5	1374
19	1/23/2013	8:54:09	24.8	54.1	1502
20	1/23/2013	8:59:09	24.8	53.1	1637
21	1/23/2013	9:04:09	24.7	52.7	1776
22	1/23/2013	9:09:09	24.7	51.7	1907
23	1/23/2013	9:14:09	24.7	51.1	2008
24	1/23/2013	9:19:09	24.6	51.2	2117
25	1/23/2013	9:24:09	24.7	49.6	2191

ตารางที่ ๘.๘ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 23/01/2556 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
26	1/23/2013	9:29:09	24.7	49.4	2306
27	1/23/2013	9:34:09	24.8	48.9	2416
28	1/23/2013	9:39:09	24.7	48.4	2529
29	1/23/2013	9:44:09	24.8	48.3	2623
30	1/23/2013	9:49:09	24.9	52	2717
31	1/23/2013	9:54:09	24.8	50	2853
32	1/23/2013	9:59:09	24.7	49.2	2952
33	1/23/2013	10:04:09	24.7	49	3051
34	1/23/2013	10:09:09	24.6	50.1	3033
35	1/23/2013	10:14:09	24.7	50.2	2820
36	1/23/2013	10:19:09	24.6	52.5	2757
37	1/23/2013	10:24:09	24.6	54.6	2626
38	1/23/2013	10:29:09	24.7	54.2	2645
39	1/23/2013	10:34:09	24.6	54.4	2642
40	1/23/2013	10:39:09	24.6	54.3	2746
41	1/23/2013	10:44:09	24.6	54.3	2878
42	1/23/2013	10:49:09	24.5	53.6	2992
43	1/23/2013	10:54:09	24.7	51.7	3140
44	1/23/2013	10:59:09	24.8	51.6	3252
45	1/23/2013	11:04:09	24.9	51.7	3356
46	1/23/2013	11:09:09	24.9	50	3480
47	1/23/2013	11:14:09	25	49.2	3614
48	1/23/2013	11:19:09	25.1	49.4	3745
49	1/23/2013	11:24:09	25.1	48.9	3856
50	1/23/2013	11:29:09	25.2	47.5	3967

ตารางที่ ๘.๘ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 23/01/2556 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
51	1/23/2013	11:34:09	25.2	47.5	4100
52	1/23/2013	11:39:09	25.2	47.8	4198
53	1/23/2013	11:44:09	25.2	47.9	4301
54	1/23/2013	11:49:09	25.3	47.5	4384
55	1/23/2013	11:54:09	25.2	47.9	4484
56	1/23/2013	11:59:09	25.2	47.3	4561
57	1/23/2013	12:04:09	25.2	47.5	4663
58	1/23/2013	12:09:09	25.2	47.6	4740
59	1/23/2013	12:14:09	25.3	46.8	4828
60	1/23/2013	12:19:09	25.2	46.3	4882
61	1/23/2013	12:24:09	25.3	46.7	5027
62	1/23/2013	12:29:09	25.3	47	5133
63	1/23/2013	12:34:09	25.3	45.8	5141
64	1/23/2013	12:39:09	25.2	47.7	4594

ตารางที่ ๑.๑ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 22/01/2556

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	1/22/2013	7:31:16	27.4	78	537
2	1/22/2013	7:36:16	27.2	59.6	536
3	1/22/2013	7:41:16	26.3	54.6	531
4	1/22/2013	7:46:16	25.9	55.5	528
5	1/22/2013	7:51:16	25.6	54.6	514
6	1/22/2013	7:56:16	25.3	53.5	505
7	1/22/2013	8:01:16	25.2	52.8	501
8	1/22/2013	8:06:16	24.9	53.1	496
9	1/22/2013	8:11:16	24.8	55.3	495
10	1/22/2013	8:16:16	24.8	54.7	493
11	1/22/2013	8:21:16	24.7	57.9	489
12	1/22/2013	8:26:16	24.6	58.7	488
13	1/22/2013	8:31:16	24.6	58.4	484
14	1/22/2013	8:36:16	24.6	58.4	483
15	1/22/2013	8:41:16	24.4	58.7	493
16	1/22/2013	8:46:16	24.6	61.1	527
17	1/22/2013	8:51:16	24.6	61.8	568
18	1/22/2013	8:56:16	24.6	63	669
19	1/22/2013	9:01:16	24.6	60.2	782
20	1/22/2013	9:06:16	24.6	57.8	860
21	1/22/2013	9:11:16	24.7	59.5	958
22	1/22/2013	9:16:16	24.6	59.1	1088
23	1/22/2013	9:21:16	24.7	56.7	1248
24	1/22/2013	9:26:16	24.6	55.1	1391
25	1/22/2013	9:31:16	24.5	58.6	1520

ตารางที่ ๑.๑ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 22/01/2556 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
26	1/22/2013	9:36:16	24.6	60	1647
27	1/22/2013	9:41:16	24.7	57	1796
28	1/22/2013	9:46:16	24.6	58.6	1903
29	1/22/2013	9:51:16	24.7	56.1	2019
30	1/22/2013	9:56:16	24.6	54.3	2108
31	1/22/2013	10:01:16	24.4	53.8	2200
32	1/22/2013	10:06:16	24.4	56	2298
33	1/22/2013	10:11:16	24.4	57.2	2376
34	1/22/2013	10:16:16	24.5	55.5	2468
35	1/22/2013	10:21:16	24.5	57.4	2546
36	1/22/2013	10:26:16	24.5	55.7	2648
37	1/22/2013	10:31:16	24.6	56.2	2737
38	1/22/2013	10:36:16	24.6	55.2	2844
39	1/22/2013	10:41:16	24.5	57	2902
40	1/22/2013	10:46:16	24.4	55	2974
41	1/22/2013	10:51:16	24.6	53.1	2611
42	1/22/2013	10:56:16	24.5	55.3	2672
43	1/22/2013	11:01:16	24.4	53.6	2706
44	1/22/2013	11:06:16	24.4	52	2747
45	1/22/2013	11:11:16	24.3	54.3	2753
46	1/22/2013	11:16:16	24.4	56	2802
47	1/22/2013	11:21:16	24.4	53.9	2812
48	1/22/2013	11:26:16	24.3	51.8	2860
49	1/22/2013	11:31:16	24.3	53.7	2905
50	1/22/2013	11:36:16	24.3	55.3	2939

ตารางที่ ๑.๑ ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 22/01/2556 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
51	1/22/2013	11:41:16	24.3	53.4	2931
52	1/22/2013	11:46:16	24.2	51.8	2963
53	1/22/2013	11:51:16	24.2	53.7	3008
54	1/22/2013	11:56:16	24.2	55.6	2982
55	1/22/2013	12:01:16	24.2	56.8	2976
56	1/22/2013	12:06:16	24.3	57.3	3016
57	1/22/2013	12:11:16	24.4	54.9	3067
58	1/22/2013	12:16:16	24.2	56.6	3119
59	1/22/2013	12:21:16	24.3	54.6	3162
60	1/22/2013	12:26:16	24.3	55.1	3171
61	1/22/2013	12:31:16	24.4	56.3	3081
62	1/22/2013	12:36:16	24.4	58.2	2935
63	1/22/2013	12:41:16	24.2	58	2826
64	1/22/2013	12:46:16	24.3	59.5	2742
65	1/22/2013	12:51:16	24.3	59.1	2680

ตารางที่ ๑.10 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 28/01/2556

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	1/28/2013	7:38:33	26	55.9	515
2	1/28/2013	7:43:33	24.9	49.9	424
3	1/28/2013	7:48:33	24.2	50.5	421
4	1/28/2013	7:53:33	23.6	51.9	425
5	1/28/2013	7:58:33	23.2	52.8	431
6	1/28/2013	8:03:33	23.1	53.1	437
7	1/28/2013	8:08:33	22.9	54	438
8	1/28/2013	8:13:33	22.8	53.3	434
9	1/28/2013	8:18:33	22.5	53.8	440
10	1/28/2013	8:23:33	22.5	54.2	448
11	1/28/2013	8:28:33	22.3	54.4	475
12	1/28/2013	8:33:33	22.3	54.1	510
13	1/28/2013	8:38:33	22.3	54.9	541
14	1/28/2013	8:43:33	22.3	54.8	601
15	1/28/2013	8:48:33	22.3	54.8	696
16	1/28/2013	8:53:33	22.2	57.5	755
17	1/28/2013	8:58:33	22.2	57.8	848
18	1/28/2013	9:03:33	22.2	57.9	937
19	1/28/2013	9:08:33	22.2	57.1	1101
20	1/28/2013	9:13:33	22.2	56.7	1228
21	1/28/2013	9:18:33	22.1	56.2	1306
22	1/28/2013	9:23:33	22.1	55.3	1372
23	1/28/2013	9:28:33	22	56.4	1453
24	1/28/2013	9:33:33	22.1	55.2	1522
25	1/28/2013	9:38:33	22.1	55.3	1638

ตารางที่ ๑.10 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 28/01/2556 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
26	1/28/2013	9:43:33	22.1	55.6	1714
27	1/28/2013	9:48:33	22.2	56	1771
28	1/28/2013	9:53:33	22.1	53.9	1812
29	1/28/2013	9:58:33	21.9	54.8	1875
30	1/28/2013	10:03:33	21.9	55.8	1942
31	1/28/2013	10:08:33	22.1	56.8	1975
32	1/28/2013	10:13:33	22.3	58.3	1805
33	1/28/2013	10:18:33	22.3	57.9	1789
34	1/28/2013	10:23:33	22.3	57.4	1785
35	1/28/2013	10:28:33	22.2	56.6	1843
36	1/28/2013	10:33:33	22.2	58.2	1926
37	1/28/2013	10:38:33	22.3	56.8	2072
38	1/28/2013	10:43:33	22.3	58.1	2341
39	1/28/2013	10:48:33	22.4	59.6	2507
40	1/28/2013	10:53:33	22.3	57.3	2701
41	1/28/2013	10:58:33	22.3	58.7	2885
42	1/28/2013	11:03:33	22.3	56.5	3087
43	1/28/2013	11:08:33	22.4	55.3	3257
44	1/28/2013	11:13:33	22.4	54.6	3417
45	1/28/2013	11:18:33	22.4	54.7	3580
46	1/28/2013	11:23:33	22.4	55	3677
47	1/28/2013	11:28:33	22.4	54.8	3764
48	1/28/2013	11:33:33	22.3	54	3787
49	1/28/2013	11:38:33	22.3	54	3797
50	1/28/2013	11:43:33	22.2	55.5	3872

ตารางที่ ๑.10 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 100 คน
ณ วันที่ 28/01/2556 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
51	1/28/2013	11:48:33	22.3	54.2	4034
52	1/28/2013	11:53:33	22.3	53.8	4141
53	1/28/2013	11:58:33	22.4	53.7	4340
54	1/28/2013	12:03:33	22.4	54.3	4359
55	1/28/2013	12:08:33	22.4	54.2	4456
56	1/28/2013	12:13:33	22.3	53.7	4568
57	1/28/2013	12:18:33	22.3	59.5	3477
58	1/28/2013	12:23:33	22.3	62.8	2818
59	1/28/2013	12:28:33	22.2	64.2	2346
60	1/28/2013	12:33:33	22.2	64.3	1944
61	1/28/2013	12:38:33	22.2	61	1821
62	1/28/2013	12:43:33	22.3	60.2	1789
63	1/28/2013	12:48:33	22.1	59.8	1731
64	1/28/2013	12:53:33	21.9	59	1674

ตารางที่ ก.11 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 12/11/2555

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	11/12/2012	7:16:03	26.6	43.3	463
2	11/12/2012	7:21:03	25.9	45.2	432
3	11/12/2012	7:26:03	24.9	48.8	431
4	11/12/2012	7:31:03	24.4	49.8	431
5	11/12/2012	7:36:03	23.8	51.1	434
6	11/12/2012	7:41:03	24	51.4	434
7	11/12/2012	7:46:03	24.1	50	434
8	11/12/2012	7:51:03	24.2	52.4	437
9	11/12/2012	7:56:03	24.5	50.2	438
10	11/12/2012	8:01:03	24.7	50.7	440
11	11/12/2012	8:06:03	24.8	49	437
12	11/12/2012	8:11:03	24.9	48	437
13	11/12/2012	8:16:03	24.9	47.4	434
14	11/12/2012	8:21:03	24.9	47.1	434
15	11/12/2012	8:26:03	24.8	48.7	435
16	11/12/2012	8:31:03	24.8	48.1	433
17	11/12/2012	8:36:03	24.8	47.1	433
18	11/12/2012	8:41:03	24.6	48.5	432
19	11/12/2012	8:46:03	24.7	48.3	433
20	11/12/2012	8:51:03	24.7	50.7	435
21	11/12/2012	8:56:03	24.7	50.6	434
22	11/12/2012	9:01:03	24.7	47.5	435
23	11/12/2012	9:06:03	24.5	48.1	434
24	11/12/2012	9:11:03	24.6	47.1	433
25	11/12/2012	9:16:03	24.5	48	433

ตารางที่ ก.11 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 12/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
26	11/12/2012	9:21:03	24.6	46.5	432
27	11/12/2012	9:26:03	24.5	47.6	431
28	11/12/2012	9:31:03	24.8	45.9	428
29	11/12/2012	9:36:03	24.4	45.6	430
30	11/12/2012	9:41:03	24.7	46.5	429
31	11/12/2012	9:46:03	24.5	44	428
32	11/12/2012	9:51:03	24.5	42.1	432
33	11/12/2012	9:56:03	24.6	42.3	435
34	11/12/2012	10:01:03	24.6	44.8	436
35	11/12/2012	10:06:03	24.4	46.3	435
36	11/12/2012	10:11:03	24.7	47.4	434
37	11/12/2012	10:16:03	24.3	44.8	435
38	11/12/2012	10:21:03	24.3	45.4	433
39	11/12/2012	10:26:03	24.5	48.2	435
40	11/12/2012	10:31:03	24.4	47.6	436
41	11/12/2012	10:36:03	24.4	44.3	434
42	11/12/2012	10:41:03	24.4	45.5	434
43	11/12/2012	10:46:03	24.4	47.9	434
44	11/12/2012	10:51:03	24.4	47.8	435
45	11/12/2012	10:56:03	24.3	46.2	435
46	11/12/2012	11:01:03	24.3	47.1	435
47	11/12/2012	11:06:03	24.4	48.3	434
48	11/12/2012	11:11:03	24.3	48.4	437
49	11/12/2012	11:16:03	24.6	49	443
50	11/12/2012	11:21:03	24.4	49.5	444

ตารางที่ ก.11 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 12/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
51	11/12/2012	11:26:03	24.4	49	444
52	11/12/2012	11:31:03	24.4	47.1	442
53	11/12/2012	11:36:03	24.4	47.4	441
54	11/12/2012	11:41:03	24.4	48.6	441
55	11/12/2012	11:46:03	24.4	49.3	440
56	11/12/2012	11:51:03	24.4	49.6	440
57	11/12/2012	11:56:03	24.4	50.4	438
58	11/12/2012	12:01:03	24.4	49.6	438
59	11/12/2012	12:06:03	24.3	50.4	436
60	11/12/2012	12:11:03	24.6	49.6	436
61	11/12/2012	12:16:03	24.4	46.6	436
62	11/12/2012	12:21:03	24.3	48.5	450
63	11/12/2012	12:26:03	24.4	50.1	464
64	11/12/2012	12:31:03	24.8	51.5	472
65	11/12/2012	12:36:03	24.9	47.9	489
66	11/12/2012	12:41:03	25.2	47.1	516
67	11/12/2012	12:46:03	25	48.6	513
68	11/12/2012	12:51:03	25.5	48.4	527
69	11/12/2012	12:56:03	25.2	47	589
70	11/12/2012	13:01:03	25.2	44.6	622
71	11/12/2012	13:06:03	25.5	45.6	657
72	11/12/2012	13:11:03	25.5	47.1	692
73	11/12/2012	13:16:03	25.7	48.3	739
74	11/12/2012	13:21:03	25.6	47.4	777
75	11/12/2012	13:26:03	25.4	44.9	818

ตารางที่ ก.11 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 12/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
76	11/12/2012	13:31:03	25.4	42.5	853
77	11/12/2012	13:36:03	25.3	42	924
78	11/12/2012	13:41:03	25.3	41.4	962
79	11/12/2012	13:46:03	25.3	40.8	1037
80	11/12/2012	13:51:03	25.2	40.4	1121
81	11/12/2012	13:56:03	24.9	40.2	1200
82	11/12/2012	14:01:03	24.9	40.6	1284
83	11/12/2012	14:06:03	24.8	40.6	1363
84	11/12/2012	14:11:03	24.8	40.5	1432
85	11/12/2012	14:16:03	24.7	40.1	1502
86	11/12/2012	14:21:03	24.7	40	1564
87	11/12/2012	14:26:03	24.6	39.8	1621
88	11/12/2012	14:31:03	24.6	41.9	1687
89	11/12/2012	14:36:03	24.1	44.5	1781
90	11/12/2012	14:41:03	23.5	45.6	1887
91	11/12/2012	14:46:03	23.1	46.5	2013
92	11/12/2012	14:51:03	22.8	46.6	2110
93	11/12/2012	14:56:03	22.7	46.9	2234
94	11/12/2012	15:01:03	22.4	47	2329
95	11/12/2012	15:06:03	22.2	47.5	2397
96	11/12/2012	15:11:03	22	47.8	2473
97	11/12/2012	15:16:03	21.9	47.7	2560
98	11/12/2012	15:21:03	21.7	47.9	2628
99	11/12/2012	15:26:03	21.6	47.7	2720
100	11/12/2012	15:31:03	21.4	47.9	2794

ตารางที่ ๑.11 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 12/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
101	11/12/2012	15:36:03	21.4	47.6	2900
102	11/12/2012	15:41:03	21.3	47.9	2948
103	11/12/2012	15:46:03	21.1	47.9	3000
104	11/12/2012	15:51:03	21.2	48.2	3076
105	11/12/2012	15:56:03	21	48	3152
106	11/12/2012	16:01:03	20.9	48	3234
107	11/12/2012	16:06:03	20.9	47.8	3299
108	11/12/2012	16:11:03	20.9	47.9	3369
109	11/12/2012	16:16:03	20.8	47.8	3453
110	11/12/2012	16:21:03	20.8	47.9	3516
111	11/12/2012	16:26:03	20.8	50.3	3312
112	11/12/2012	16:31:03	20.8	54.3	2905
113	11/12/2012	16:36:03	20.8	52.8	2835

ตารางที่ ๑.12 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 16/11/2555

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	11/16/2012	7:23:25	27.4	61.8	523
2	11/16/2012	7:28:25	26.4	58.3	514
3	11/16/2012	7:33:25	24.7	61	509
4	11/16/2012	7:38:25	24.8	61.9	505
5	11/16/2012	7:43:25	25.1	61.9	499
6	11/16/2012	7:48:25	25.6	61	492
7	11/16/2012	7:53:25	25.9	58.9	492
8	11/16/2012	7:58:25	26.3	57.9	489
9	11/16/2012	8:03:25	26.4	57	492
10	11/16/2012	8:08:25	26.4	57.6	490
11	11/16/2012	8:13:25	26.6	57	486
12	11/16/2012	8:18:25	26.6	56.3	487
13	11/16/2012	8:23:25	26.8	56.2	481
14	11/16/2012	8:28:25	26.7	56.1	495
15	11/16/2012	8:33:25	26.7	56.9	544
16	11/16/2012	8:38:25	26.4	55.8	651
17	11/16/2012	8:43:25	26.9	53.4	794
18	11/16/2012	8:48:25	27	54.7	950
19	11/16/2012	8:53:25	27.1	52	1055
20	11/16/2012	8:58:25	27.1	50.7	1206
21	11/16/2012	9:03:25	27.1	49.8	1339
22	11/16/2012	9:08:25	26.9	47.8	1445
23	11/16/2012	9:13:25	26.8	47	1574
24	11/16/2012	9:18:25	26.9	46.6	1700
25	11/16/2012	9:23:25	26.8	46.1	1804

ตารางที่ ก.12 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 16/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
26	11/16/2012	9:28:25	26.6	45.4	1884
27	11/16/2012	9:33:25	26.5	45.3	1951
28	11/16/2012	9:38:25	26.6	46.7	2051
29	11/16/2012	9:43:25	26.6	46.1	2133
30	11/16/2012	9:48:25	26.8	46.8	2196
31	11/16/2012	9:53:25	26.7	46	2281
32	11/16/2012	9:58:25	26.5	45	2310
33	11/16/2012	10:03:25	26.5	44.5	2336
34	11/16/2012	10:08:25	26.4	44.1	2367
35	11/16/2012	10:13:25	26.7	45.6	2425
36	11/16/2012	10:18:25	26.7	44.4	2411
37	11/16/2012	10:23:25	26.6	43.6	2423
38	11/16/2012	10:28:25	26.8	46.8	2122
39	11/16/2012	10:33:25	26.9	46.4	1954
40	11/16/2012	10:38:25	26.9	48.5	1752
41	11/16/2012	10:43:25	27.1	51.4	1583
42	11/16/2012	10:48:25	27	49.9	1425
43	11/16/2012	10:53:25	27.1	50.2	1304
44	11/16/2012	10:58:25	27.2	50.8	1234
45	11/16/2012	11:03:25	27.3	51.2	1166
46	11/16/2012	11:08:25	27.2	52.9	1090
47	11/16/2012	11:13:25	27.1	53.5	1028
48	11/16/2012	11:18:25	27.1	52.6	976
49	11/16/2012	11:23:25	27.1	52.8	933
50	11/16/2012	11:28:25	27	54.6	908

ตารางที่ ๑.12 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 16/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
51	11/16/2012	11:33:25	27.1	53.3	858
52	11/16/2012	11:38:25	27	51.5	839
53	11/16/2012	11:43:25	26.9	51.7	811
54	11/16/2012	11:48:25	26.9	53.4	796
55	11/16/2012	11:53:25	26.9	51.2	767
56	11/16/2012	11:58:25	26.9	49.1	740
57	11/16/2012	12:03:25	26.8	47.1	727
58	11/16/2012	12:08:25	26.8	51.1	715
59	11/16/2012	12:13:25	26.8	52.5	691
60	11/16/2012	12:18:25	26.8	49.4	666
61	11/16/2012	12:23:25	26.8	48.3	654
62	11/16/2012	12:28:25	26.8	50.3	640
63	11/16/2012	12:33:25	26.9	50.8	633
64	11/16/2012	12:38:25	26.8	49.6	623
65	11/16/2012	12:43:25	26.8	49.5	601
66	11/16/2012	12:48:25	26.7	49.5	593
67	11/16/2012	12:53:25	26.5	52	579
68	11/16/2012	12:58:25	26.8	50.8	573
69	11/16/2012	13:03:25	26.9	52.8	567
70	11/16/2012	13:08:25	26.9	54.3	559
71	11/16/2012	13:13:25	27	53.3	552
72	11/16/2012	13:18:25	26.9	52.1	545
73	11/16/2012	13:23:25	26.9	53.6	540
74	11/16/2012	13:28:25	26.8	54.1	535
75	11/16/2012	13:33:25	26.9	51.8	529

ตารางที่ ๑.12 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 16/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
76	11/16/2012	13:38:25	27.1	53.3	520
77	11/16/2012	13:43:25	27	52.7	521
78	11/16/2012	13:48:25	27	52.9	515
79	11/16/2012	13:53:25	27	52.3	516
80	11/16/2012	13:58:25	27	53.3	516
81	11/16/2012	14:03:25	27	54.5	514
82	11/16/2012	14:08:25	27.1	56.2	518
83	11/16/2012	14:13:25	27	55.4	516
84	11/16/2012	14:18:25	26.9	54.3	514
85	11/16/2012	14:23:25	26.9	54.2	513
86	11/16/2012	14:28:25	26.8	53.7	512
87	11/16/2012	14:33:25	27.1	55.9	511
88	11/16/2012	14:38:25	27.2	57	511
89	11/16/2012	14:43:25	27.1	54.7	514
90	11/16/2012	14:48:25	27	56.7	519
91	11/16/2012	14:53:25	27.1	55.6	517
92	11/16/2012	14:58:25	27	55	519
93	11/16/2012	15:03:25	27	54.6	521
94	11/16/2012	15:08:25	27.1	57	519
95	11/16/2012	15:13:25	27	55.6	523
96	11/16/2012	15:18:25	26.9	53.8	527
97	11/16/2012	15:23:25	26.9	56	530
98	11/16/2012	15:28:25	27	57.8	532
99	11/16/2012	15:33:25	27	55.5	556
100	11/16/2012	15:38:25	27.1	55.8	646

ตารางที่ ๑.12 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 16/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
101	11/16/2012	15:43:25	27.1	52.7	761
102	11/16/2012	15:48:25	27.2	53.2	880
103	11/16/2012	15:53:25	27.2	54.7	1011
104	11/16/2012	15:58:25	27.1	51.5	1160
105	11/16/2012	16:03:25	26.9	50	1354
106	11/16/2012	16:08:25	26.8	48.6	1528
107	11/16/2012	16:13:25	26.7	47	1708
108	11/16/2012	16:18:25	26.7	44.7	1895
109	11/16/2012	16:23:25	26.7	45.6	2037
110	11/16/2012	16:28:25	26.7	45.7	2178
111	11/16/2012	16:33:25	26.7	42.9	2348
112	11/16/2012	16:38:25	26.8	43.9	2485
113	11/16/2012	16:43:25	26.8	44.8	2627
114	11/16/2012	16:48:25	26.8	41.9	2792
115	11/16/2012	16:53:25	26.8	42.7	2931
116	11/16/2012	16:58:25	26.7	43.9	3077
117	11/16/2012	17:03:25	26.7	45	3176
118	11/16/2012	17:08:25	26.7	43	3266
119	11/16/2012	17:13:25	26.6	44.1	3423
120	11/16/2012	17:18:25	26.7	45.6	3556
121	11/16/2012	17:23:25	26.7	46.8	3651
122	11/16/2012	17:28:25	26.7	45.5	3742
123	11/16/2012	17:33:25	26.7	45.4	3845
124	11/16/2012	17:38:25	26.7	44.5	3929
125	11/16/2012	17:43:25	26.7	42.2	4001

ตารางที่ ๑.13 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 20/11/2555

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	11/20/2012	7:27:17	27.7	54.8	480
2	11/20/2012	7:32:17	26.8	55.2	476
3	11/20/2012	7:37:17	26	56.6	471
4	11/20/2012	7:42:17	26.1	55.9	469
5	11/20/2012	7:47:17	26.1	57.9	465
6	11/20/2012	7:52:17	26.2	56.9	469
7	11/20/2012	7:57:17	26.2	57.5	467
8	11/20/2012	8:02:17	26.1	56.2	467
9	11/20/2012	8:07:17	26	59.2	465
10	11/20/2012	8:12:17	26.1	57.6	467
11	11/20/2012	8:17:17	26.1	57.5	470
12	11/20/2012	8:22:17	26.1	56.7	480
13	11/20/2012	8:27:17	26.2	55.3	518
14	11/20/2012	8:32:17	26.1	54.9	592
15	11/20/2012	8:37:17	25.8	53.3	704
16	11/20/2012	8:42:17	25.7	54.8	831
17	11/20/2012	8:47:17	25.8	54.2	962
18	11/20/2012	8:52:17	25.7	53.4	1097
19	11/20/2012	8:57:17	25.8	53.3	1261
20	11/20/2012	9:02:17	25.8	52.8	1387
21	11/20/2012	9:07:17	25.8	53.6	1529
22	11/20/2012	9:12:17	25.8	57	1697
23	11/20/2012	9:17:17	25.7	52	1834
24	11/20/2012	9:22:17	25.6	51.5	1961
25	11/20/2012	9:27:17	25.7	54.5	2086

ตารางที่ ๑.13 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 20/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
26	11/20/2012	9:32:17	25.7	53.6	2188
27	11/20/2012	9:37:17	25.7	55.4	2291
28	11/20/2012	9:42:17	26	54	2422
29	11/20/2012	9:47:17	26.3	53.1	2525
30	11/20/2012	9:52:17	26.6	51.3	2671
31	11/20/2012	9:57:17	26.4	50.8	2837
32	11/20/2012	10:02:17	26.5	49.7	2958
33	11/20/2012	10:07:17	26.6	50	3072
34	11/20/2012	10:12:17	26.7	49.1	3201
35	11/20/2012	10:17:17	27	48.9	3340
36	11/20/2012	10:22:17	27.2	49.5	3363
37	11/20/2012	10:27:17	27.4	51.3	2838
38	11/20/2012	10:32:17	27.1	52.1	2648
39	11/20/2012	10:37:17	27	51.9	2637
40	11/20/2012	10:42:17	26.9	51.5	2635
41	11/20/2012	10:47:17	26.9	49.8	2632
42	11/20/2012	10:52:17	26.9	49.5	2630
43	11/20/2012	10:57:17	26.8	48.6	2624
44	11/20/2012	11:02:17	26.9	48.1	2618
45	11/20/2012	11:07:17	26.9	46.4	2623
46	11/20/2012	11:12:17	26.9	46	2605
47	11/20/2012	11:17:17	26.8	45.3	2598
48	11/20/2012	11:22:17	26.8	44.4	2600
49	11/20/2012	11:27:17	26.7	44.2	2579
50	11/20/2012	11:32:17	26.7	44	2563

ตารางที่ ก.13 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 20/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
51	11/20/2012	11:37:17	26.7	43.2	2566
52	11/20/2012	11:42:17	26.6	43	2537
53	11/20/2012	11:47:17	26.4	43	2536
54	11/20/2012	11:52:17	26.8	42.7	2530
55	11/20/2012	11:57:17	26.7	42.7	2502
56	11/20/2012	12:02:17	26.8	43.2	2501
57	11/20/2012	12:07:17	26.9	42.8	2442
58	11/20/2012	12:12:17	26.7	42.6	2364
59	11/20/2012	12:17:17	26.6	44.2	2341
60	11/20/2012	12:22:17	26.3	44.5	2293
61	11/20/2012	12:27:17	26.2	45.7	2228
62	11/20/2012	12:32:17	26	45.2	2172
63	11/20/2012	12:37:17	25.8	45.8	2149
64	11/20/2012	12:42:17	25.6	46.1	2115
65	11/20/2012	12:47:17	25.5	49.1	2087
66	11/20/2012	12:52:17	25.3	48.6	2049
67	11/20/2012	12:57:17	25.2	51.3	2011
68	11/20/2012	13:02:17	25.1	50.2	1980
69	11/20/2012	13:07:17	24.9	53	1955
70	11/20/2012	13:12:17	24.9	51.8	1922
71	11/20/2012	13:17:17	24.8	54.1	1902
72	11/20/2012	13:22:17	24.7	52.7	1873
73	11/20/2012	13:27:17	24.7	55	1849
74	11/20/2012	13:32:17	24.6	54.1	1821
75	11/20/2012	13:37:17	24.6	56.2	1773

ตารางที่ ก.13 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 20/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
76	11/20/2012	13:42:17	24.6	56	1702
77	11/20/2012	13:47:17	24.5	57.7	1659
78	11/20/2012	13:52:17	24.5	57.6	1619
79	11/20/2012	13:57:17	24.4	58.8	1574
80	11/20/2012	14:02:17	24.4	58.5	1535
81	11/20/2012	14:07:17	24.3	57.7	1451
82	11/20/2012	14:12:17	24.3	59.2	1438
83	11/20/2012	14:17:17	24.3	58	1417
84	11/20/2012	14:22:17	24.2	58.8	1396
85	11/20/2012	14:27:17	24.2	58.2	1372
86	11/20/2012	14:32:17	24.2	58	1349
87	11/20/2012	14:37:17	24.1	59.1	1320
88	11/20/2012	14:42:17	24.1	58.8	1300
89	11/20/2012	14:47:17	24.1	58.2	1281
90	11/20/2012	14:52:17	24.1	59.7	1255
91	11/20/2012	14:57:17	24.1	59.7	1229
92	11/20/2012	15:02:17	24.1	60.5	1206
93	11/20/2012	15:07:17	24	59.6	1177
94	11/20/2012	15:12:17	23.9	58.9	1132
95	11/20/2012	15:17:17	23.9	58.5	1066
96	11/20/2012	15:22:17	23.9	58	1010
97	11/20/2012	15:27:17	23.9	61	930
98	11/20/2012	15:32:17	23.8	61.1	870
99	11/20/2012	15:37:17	23.8	61.9	846
100	11/20/2012	15:42:17	23.8	61	837

ตารางที่ ๑.13 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 20/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
101	11/20/2012	15:47:17	23.8	62.8	834
102	11/20/2012	15:52:17	23.9	61.5	833
103	11/20/2012	15:57:17	23.9	62.6	840
104	11/20/2012	16:02:17	23.9	63.3	851
105	11/20/2012	16:07:17	23.8	61.7	849
106	11/20/2012	16:12:17	23.9	61.8	847
107	11/20/2012	16:17:17	23.9	62	842
108	11/20/2012	16:22:17	24.1	62.5	831

ตารางที่ ๑.14 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 25/1/2556

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	1/25/2013	7:19:28	28.9	71.8	546
2	1/25/2013	7:24:28	28.2	66.6	457
3	1/25/2013	7:29:28	-	-	-
4	1/25/2013	7:34:28	-	-	-
5	1/25/2013	7:39:28	-	-	-
6	1/25/2013	7:44:28	26.5	75.2	455
7	1/25/2013	7:49:28	26.6	77.6	449
8	1/25/2013	7:54:28	26.7	77.7	443
9	1/25/2013	7:59:28	26.9	77.1	448
10	1/25/2013	8:04:28	27	76.5	446
11	1/25/2013	8:09:28	27.1	74.7	444
12	1/25/2013	8:14:28	26.9	65.7	443
13	1/25/2013	8:19:28	26.8	58.8	444
14	1/25/2013	8:24:28	26.5	57.2	461
15	1/25/2013	8:29:28	26.4	57.4	557
16	1/25/2013	8:34:28	26.1	56.8	753
17	1/25/2013	8:39:28	25.9	59.7	965
18	1/25/2013	8:44:28	25.6	60.2	1152
19	1/25/2013	8:49:28	25.6	59.3	1388
20	1/25/2013	8:54:28	25.4	60.2	1542
21	1/25/2013	8:59:28	25.4	59.2	1739
22	1/25/2013	9:04:28	25.2	60.3	1911
23	1/25/2013	9:09:28	24.9	59.3	2057
24	1/25/2013	9:14:28	24.9	63.5	2228
25	1/25/2013	9:19:28	24.7	60.7	2404

ตารางที่ ๑.14 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 25/1/2556 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
26	1/25/2013	9:24:28	24.4	59.4	2542
27	1/25/2013	9:29:28	24.3	57.6	2711
28	1/25/2013	9:34:28	24.3	61.2	2871
29	1/25/2013	9:39:28	24.2	61.7	3017
30	1/25/2013	9:44:28	24.3	60.7	3168
31	1/25/2013	9:49:28	24.4	60.6	3319
32	1/25/2013	9:54:28	24.5	60	3454
33	1/25/2013	9:59:28	24.5	60.2	3570
34	1/25/2013	10:04:28	24.5	59.9	3690
35	1/25/2013	10:09:28	24.4	57.2	3810
36	1/25/2013	10:14:28	24.4	58.2	3932
37	1/25/2013	10:19:28	24.4	57.7	4015
38	1/25/2013	10:24:28	24.4	58.9	4049
39	1/25/2013	10:29:28	24.3	59.3	4139
40	1/25/2013	10:34:28	24.2	61.1	4216
41	1/25/2013	10:39:28	24.3	60.7	4338
42	1/25/2013	10:44:28	24.3	62.5	4403
43	1/25/2013	10:49:28	24.3	61.8	4523
44	1/25/2013	10:54:28	24.3	63.3	4593
45	1/25/2013	10:59:28	24.2	63.9	4080
46	1/25/2013	11:04:28	24.2	63.1	3466
47	1/25/2013	11:09:28	24.3	62.7	3413
48	1/25/2013	11:14:28	24.2	61.3	3149
49	1/25/2013	11:19:28	24.2	61	2550
50	1/25/2013	11:24:28	24.2	59.9	2141

ตารางที่ ๑.14 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 25/1/2556 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
51	1/25/2013	11:29:28	24.2	62.3	2061
52	1/25/2013	11:34:28	24.3	59.5	2106
53	1/25/2013	11:39:28	24.2	60.8	2122
54	1/25/2013	11:44:28	24.3	61.8	2136
55	1/25/2013	11:49:28	24.3	61.3	2099
56	1/25/2013	11:54:28	24.4	62.7	2036
57	1/25/2013	11:59:28	24.6	63.7	1926
58	1/25/2013	12:04:28	24.9	65.4	1719
59	1/25/2013	12:09:28	25.2	67.1	1549
60	1/25/2013	12:14:28	25.4	67.7	1458
61	1/25/2013	12:19:28	25.6	68.4	1345
62	1/25/2013	12:24:28	25.8	69	1244

ตารางที่ ๑.15 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 28/1/2556

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	1/28/2013	7:32:08	27.1	79	441
2	1/28/2013	7:37:08	27.7	72.7	446
3	1/28/2013	7:42:08	27.8	71.6	444
4	1/28/2013	7:47:08	27.9	70.9	443
5	1/28/2013	7:52:08	27.8	70.3	439
6	1/28/2013	7:57:08	27.7	60	434
7	1/28/2013	8:02:08	27.3	59.4	434
8	1/28/2013	8:07:08	27.1	61.4	433
9	1/28/2013	8:12:08	26.8	61.2	432
10	1/28/2013	8:17:08	26.6	60.8	434
11	1/28/2013	8:22:08	26.3	61	437
12	1/28/2013	8:27:08	26.2	61.2	443
13	1/28/2013	8:32:08	25.8	61.1	453
14	1/28/2013	8:37:08	25.7	61.5	544
15	1/28/2013	8:42:08	25.7	59.5	546
16	1/28/2013	8:47:08	25.6	61.6	605
17	1/28/2013	8:52:08	25.4	59.1	675
18	1/28/2013	8:57:08	25.3	61.6	740
19	1/28/2013	9:02:08	25.3	58.6	800
20	1/28/2013	9:07:08	25.2	60.1	839
21	1/28/2013	9:12:08	25.1	58.7	895
22	1/28/2013	9:17:08	25.1	57.3	960
23	1/28/2013	9:22:08	25	58.1	1026
24	1/28/2013	9:27:08	24.9	56.7	1067
25	1/28/2013	9:32:08	24.9	57.5	1128

ตารางที่ ๑.15 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 28/1/2556 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
26	1/28/2013	9:37:08	24.8	57.1	1168
27	1/28/2013	9:42:08	24.9	55.5	1238
28	1/28/2013	9:47:08	24.8	56.8	1295
29	1/28/2013	9:52:08	24.7	56	1352
30	1/28/2013	9:57:08	24.7	54.6	1415
31	1/28/2013	10:02:08	24.8	55.4	1462
32	1/28/2013	10:07:08	24.7	55.3	1502
33	1/28/2013	10:12:08	24.6	54.1	1534
34	1/28/2013	10:17:08	24.6	55.6	1596
35	1/28/2013	10:22:08	24.6	55.6	1632
36	1/28/2013	10:27:08	24.6	55.3	1634
37	1/28/2013	10:32:08	24.6	54.6	1655
38	1/28/2013	10:37:08	24.5	55.6	1666
39	1/28/2013	10:42:08	24.6	56.2	1731
40	1/28/2013	10:47:08	24.6	56.1	1795
41	1/28/2013	10:52:08	24.6	53.9	1862
42	1/28/2013	10:57:08	24.7	56.9	1894
43	1/28/2013	11:02:08	24.7	56.5	1974
44	1/28/2013	11:07:08	24.7	54.8	2050
45	1/28/2013	11:12:08	24.8	54.6	2113
46	1/28/2013	11:17:08	24.8	55.1	2179
47	1/28/2013	11:22:08	24.8	55.3	2226
48	1/28/2013	11:27:08	24.8	54.9	2276
49	1/28/2013	11:32:08	24.8	53.2	2326
50	1/28/2013	11:37:08	24.8	53.8	2387

ตารางที่ ๑.15 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 120 คน
ณ วันที่ 28/1/2556 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
51	1/28/2013	11:42:08	24.8	54.7	2385
52	1/28/2013	11:47:08	24.8	54.3	2435
53	1/28/2013	11:52:08	24.8	54.4	2457
54	1/28/2013	11:57:08	24.8	52.7	2498
55	1/28/2013	12:02:08	24.8	53.4	2552
56	1/28/2013	12:07:08	24.8	53.9	2577
57	1/28/2013	12:12:08	24.8	53.7	2599
58	1/28/2013	12:17:08	24.8	53.6	2627
59	1/28/2013	12:22:08	24.8	52.7	2656
60	1/28/2013	12:27:08	24.8	51.9	2671
61	1/28/2013	12:32:08	24.8	53.1	2681
62	1/28/2013	12:37:08	24.8	53.8	2644
63	1/28/2013	12:42:08	24.8	55	2488
64	1/28/2013	12:47:08	24.7	56.2	2447
65	1/28/2013	12:52:08	24.7	59.8	2436

ตารางที่ ๑.16 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 21/9/2555

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	09-21-2012	8:43:16	25.3	70.6	1269
2	09-21-2012	8:48:16	25.2	65.3	1492
3	09-21-2012	8:53:16	25.4	67.6	1600
4	09-21-2012	8:58:16	25.4	65.5	1772
5	09-21-2012	9:03:16	25.3	64.3	1940
6	09-21-2012	9:08:16	25.3	62.9	2092
7	09-21-2012	9:13:16	25.3	62.4	2278
8	09-21-2012	9:18:16	25.4	61.4	2428
9	09-21-2012	9:23:16	25.5	62.1	2515
10	09-21-2012	9:28:16	25.4	59.4	2655
11	09-21-2012	9:33:16	25.4	59.4	2820
12	09-21-2012	9:38:16	25.5	58.5	2947
13	09-21-2012	9:43:16	25.6	58.2	3066
14	09-21-2012	9:48:16	25.6	57.5	3210
15	09-21-2012	9:53:16	25.6	58.3	3324
16	09-21-2012	9:58:16	25.6	56.9	3427
17	09-21-2012	10:03:16	25.6	58.1	3598
18	09-21-2012	10:08:16	25.6	57.7	3746
19	09-21-2012	10:13:16	25.3	57.2	3458
20	09-21-2012	10:18:16	25.5	60.3	3293
21	09-21-2012	10:23:16	25.4	61.5	2945
22	09-21-2012	10:28:16	25.4	61.9	2741
23	09-21-2012	10:33:16	25.4	62	2564
24	09-21-2012	10:38:16	25.4	62.1	2458
25	09-21-2012	10:43:16	25.4	63.3	2390

ตารางที่ ๑.16 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 21/9/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
26	09-21-2012	10:48:16	25.4	62.1	2262
27	09-21-2012	10:53:16	25.4	61.7	2228
28	09-21-2012	10:58:16	25.4	62.8	2199
29	09-21-2012	11:03:16	25.3	60.7	2156
30	09-21-2012	11:08:16	25.4	62	2109
31	09-21-2012	11:13:16	25.3	59.9	2122
32	09-21-2012	11:18:16	25.4	61.5	2193
33	09-21-2012	11:23:16	25.3	58.8	2259
34	09-21-2012	11:28:16	25.3	59.2	2389
35	09-21-2012	11:33:16	25.3	57.1	2537
36	09-21-2012	11:38:16	25.3	55.9	2664
37	09-21-2012	11:43:16	25.4	55.7	2800
38	09-21-2012	11:48:16	25.4	54.9	2908
39	09-21-2012	11:53:16	25.4	54	2958
40	09-21-2012	11:58:16	25.6	54.9	3036
41	09-21-2012	12:03:16	25.5	53.4	3150
42	09-21-2012	12:08:16	25.6	52.8	3181
43	09-21-2012	12:13:16	25.6	51.9	3251
44	09-21-2012	12:18:16	25.6	51.3	3288
45	09-21-2012	12:23:16	25.8	51	3344
46	09-21-2012	12:28:16	25.8	53.2	2942
47	09-21-2012	12:33:16	25.7	56.2	2608
48	09-21-2012	12:38:16	25.6	56.7	2471
49	09-21-2012	12:43:16	25.4	57	2402
50	09-21-2012	12:48:16	25.4	58.3	2333

ตารางที่ ๑.16 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 21/9/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
51	09-21-2012	12:53:16	25.4	56.7	2266
52	09-21-2012	12:58:16	25.4	58.5	2200
53	09-21-2012	13:03:16	25.4	58.4	2126
54	09-21-2012	13:08:16	25.3	57.1	2058
55	09-21-2012	13:13:16	25.3	58.3	1983
56	09-21-2012	13:18:16	25.3	58.8	1939
57	09-21-2012	13:23:16	25.4	57.6	1854
58	09-21-2012	13:28:16	25.5	58.2	1812
59	09-21-2012	13:33:16	25.6	58.5	1755
60	09-21-2012	13:38:16	25.4	56.8	1689
61	09-21-2012	13:43:16	25.5	58.8	1661

ตารางที่ ๑.17 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 30/10/2555

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	10-30-2012	7:13:11	28.6	62.5	547
2	10-30-2012	7:18:11	28.3	55.5	561
3	10-30-2012	7:23:11	27.7	53.6	587
4	10-30-2012	7:28:11	27.3	52.2	571
5	10-30-2012	7:33:11	26.8	49.1	559
6	10-30-2012	7:38:11	26.5	47.1	550
7	10-30-2012	7:43:11	26.2	46.8	539
8	10-30-2012	7:48:11	26.1	45.5	567
9	10-30-2012	7:53:11	25.7	41.3	537
10	10-30-2012	7:58:11	25.2	40.4	537
11	10-30-2012	8:03:11	25	39	535
12	10-30-2012	8:08:11	24.9	39.6	534
13	10-30-2012	8:13:11	24.7	39.3	534
14	10-30-2012	8:18:11	24.7	39	557
15	10-30-2012	8:23:11	24.5	38.5	561
16	10-30-2012	8:28:11	24.6	39.3	571
17	10-30-2012	8:33:11	24.2	40.1	592
18	10-30-2012	8:38:11	24.1	39.7	613
19	10-30-2012	8:43:11	24.1	39.1	649
20	10-30-2012	8:48:11	23.8	40.3	700
21	10-30-2012	8:53:11	23.9	39.8	738
22	10-30-2012	8:58:11	23.8	40.7	791
23	10-30-2012	9:03:11	23.8	39.2	838
24	10-30-2012	9:08:11	23.7	40.2	890
25	10-30-2012	9:13:11	23.7	38.8	952

ตารางที่ ก.17 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 30/10/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
26	10-30-2012	9:18:11	23.8	39.9	1034
27	10-30-2012	9:23:11	23.6	39.6	1092
28	10-30-2012	9:28:11	23.7	39.6	1132
29	10-30-2012	9:33:11	23.6	38.6	1184
30	10-30-2012	9:38:11	23.4	40.2	1282
31	10-30-2012	9:43:11	23.6	39.1	1344
32	10-30-2012	9:48:11	23.6	38.2	1438
33	10-30-2012	9:53:11	23.6	40.2	1553
34	10-30-2012	9:58:11	23.8	39.3	1617
35	10-30-2012	10:03:11	23.6	38.6	1742
36	10-30-2012	10:08:11	23.6	38.5	1843
37	10-30-2012	10:13:11	23.6	38.2	1933
38	10-30-2012	10:18:11	23.4	38.2	2021
39	10-30-2012	10:23:11	23.6	40.9	2126
40	10-30-2012	10:28:11	23.6	39.9	2208
41	10-30-2012	10:33:11	23.7	39.7	2335
42	10-30-2012	10:38:11	23.6	39.9	2428
43	10-30-2012	10:43:11	23.7	40.2	2470
44	10-30-2012	10:48:11	23.8	40.2	2545
45	10-30-2012	10:53:11	23.8	40.5	2600
46	10-30-2012	10:58:11	23.7	41.1	2707
47	10-30-2012	11:03:11	23.9	41.3	2788
48	10-30-2012	11:08:11	23.9	41.5	2920
49	10-30-2012	11:13:11	23.9	40.8	3048
50	10-30-2012	11:18:11	24.1	41.3	3112

ตารางที่ ก.17 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 30/10/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
51	10-30-2012	11:23:11	24.3	43.8	3161
52	10-30-2012	11:28:11	24.5	45.7	2657
53	10-30-2012	11:33:11	24.6	44.4	2543
54	10-30-2012	11:38:11	24.5	45.4	2617
55	10-30-2012	11:43:11	24.7	44.1	2753
56	10-30-2012	11:48:11	24.7	44.7	2750
57	10-30-2012	11:53:11	24.8	44.4	2759
58	10-30-2012	11:58:11	24.7	43.2	2829
59	10-30-2012	12:03:11	24.6	42.4	2921
60	10-30-2012	12:08:11	24.7	42.3	2981
61	10-30-2012	12:13:11	24.6	41.4	3079
62	10-30-2012	12:18:11	24.7	41.1	3085
63	10-30-2012	12:23:11	24.6	41	3147
64	10-30-2012	12:28:11	24.7	40.6	3194
65	10-30-2012	12:33:11	24.6	39.9	3275
66	10-30-2012	12:38:11	24.6	39.9	3324
67	10-30-2012	12:43:11	24.6	40.5	3305
68	10-30-2012	12:48:11	24.6	40.4	3366
69	10-30-2012	12:53:11	24.7	44.4	2924
70	10-30-2012	12:58:11	24.7	45.8	2580
71	10-30-2012	13:03:11	24.6	45.6	2599
72	10-30-2012	13:08:11	24.7	45.9	2612
73	10-30-2012	13:13:11	24.8	46.8	2522
74	10-30-2012	13:18:11	24.9	47.2	2494
75	10-30-2012	13:23:11	25.1	48	2431

ตารางที่ ก.17 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 30/10/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
76	10-30-2012	13:28:11	25.2	49.2	2306
77	10-30-2012	13:33:11	25.3	49.6	2284
78	10-30-2012	13:38:11	25.5	55.2	1949
79	10-30-2012	13:43:11	25.2	50.8	1968
80	10-30-2012	13:48:11	24.8	46.8	1929
81	10-30-2012	13:53:11	24.4	44.2	1883
82	10-30-2012	13:58:11	24.1	42.2	1828
83	10-30-2012	14:03:11	23.8	43.9	1758
84	10-30-2012	14:08:11	23.4	42.6	1720
85	10-30-2012	14:13:11	23.4	42.9	1681
86	10-30-2012	14:18:11	23.2	44.2	1623
87	10-30-2012	14:23:11	23	42.5	1583
88	10-30-2012	14:28:11	22.9	43.1	1554
89	10-30-2012	14:33:11	22.7	44.1	1515
90	10-30-2012	14:38:11	22.5	43.9	1487
91	10-30-2012	14:43:11	22.6	44.3	1425
92	10-30-2012	14:48:11	22.4	44.8	1397
93	10-30-2012	14:53:11	22.2	45.5	1357
94	10-30-2012	14:58:11	22.2	45	1323
95	10-30-2012	15:03:11	22.2	44.5	1306
96	10-30-2012	15:08:11	22.2	45.2	1273
97	10-30-2012	15:13:11	22	45.7	1234
98	10-30-2012	15:18:11	21.8	45.6	1196
99	10-30-2012	15:23:11	21.9	44.4	1187
100	10-30-2012	15:28:11	21.8	44	1178

ตารางที่ ๑.17 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 30/10/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
101	10-30-2012	15:33:11	22	47.9	1170
102	10-30-2012	15:38:11	21.9	46.4	1163
103	10-30-2012	15:43:11	21.9	44.1	1155
104	10-30-2012	15:48:11	22.1	49	1129
105	10-30-2012	15:53:11	22	49.2	1127
106	10-30-2012	15:58:11	22.1	47.7	1268
107	10-30-2012	16:03:11	22.1	48.9	1379
108	10-30-2012	16:08:11	22.4	46.4	1513
109	10-30-2012	16:13:11	22.6	45	1656
110	10-30-2012	16:18:11	22.7	43.7	1772
111	10-30-2012	16:23:11	22.9	42.6	1866
112	10-30-2012	16:28:11	23.1	48.6	1625

ตารางที่ ๑.18 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 30/10/2555

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	10-30-2012	7:05:02	29	62.6	510
2	10-30-2012	7:10:02	28.7	50.7	512
3	10-30-2012	7:15:02	28.3	46.2	515
4	10-30-2012	7:20:02	27.7	42.5	516
5	10-30-2012	7:25:02	27.2	39.7	514
6	10-30-2012	7:30:02	26.7	39.1	515
7	10-30-2012	7:35:02	25.6	40.4	511
8	10-30-2012	7:40:02	25.4	42.4	510
9	10-30-2012	7:45:02	25.2	43	510
10	10-30-2012	7:50:02	24.8	43.8	508
11	10-30-2012	7:55:02	24.8	43	506
12	10-30-2012	8:00:02	24.6	43.9	505
13	10-30-2012	8:05:02	24.7	44	504
14	10-30-2012	8:10:02	24.1	44.3	504
15	10-30-2012	8:15:02	24.3	45.2	500
16	10-30-2012	8:20:02	24.2	44.4	497
17	10-30-2012	8:25:02	23.9	44.3	496
18	10-30-2012	8:30:02	24.1	44.5	496
19	10-30-2012	8:35:02	24.3	46.2	497
20	10-30-2012	8:40:02	24.4	46.4	508
21	10-30-2012	8:45:02	24.5	47.4	539
22	10-30-2012	8:50:02	24.7	47.4	582
23	10-30-2012	8:55:02	24.8	47.3	635
24	10-30-2012	9:00:02	24.9	47.2	701
25	10-30-2012	9:05:02	25.1	47.1	763

ตารางที่ ๑.18 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 30/10/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
26	10-30-2012	9:10:02	25.2	47	842
27	10-30-2012	9:15:02	25.4	47.1	924
28	10-30-2012	9:20:02	25.5	47	1014
29	10-30-2012	9:25:02	25.6	46.9	1109
30	10-30-2012	9:30:02	25.8	46.9	1167
31	10-30-2012	9:35:02	25.8	46.2	1261
32	10-30-2012	9:40:02	25.8	44.9	1330
33	10-30-2012	9:45:02	25.9	44	1396
34	10-30-2012	9:50:02	25.9	43.3	1469
35	10-30-2012	9:55:02	25.9	42.4	1537
36	10-30-2012	10:00:02	25.9	41.8	1610
37	10-30-2012	10:05:02	25.9	41.4	1676
38	10-30-2012	10:10:02	25.8	40.8	1763
39	10-30-2012	10:15:02	25.8	40.8	1816
40	10-30-2012	10:20:02	25.8	40.6	1876
41	10-30-2012	10:25:02	25.8	40.2	1941
42	10-30-2012	10:30:02	25.8	40.4	1987
43	10-30-2012	10:35:02	25.8	41.3	1967
44	10-30-2012	10:40:02	25.8	41.7	2011
45	10-30-2012	10:45:02	25.8	41.7	2047
46	10-30-2012	10:50:02	25.8	41.6	2103
47	10-30-2012	10:55:02	25.8	41.6	2144
48	10-30-2012	11:00:02	25.7	41.7	2174
49	10-30-2012	11:05:02	25.8	41.7	2215
50	10-30-2012	11:10:02	25.8	41.4	2259

ตารางที่ ๑.18 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 30/10/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
51	10-30-2012	11:15:02	25.8	41	2310
52	10-30-2012	11:20:02	25.8	40.7	2360
53	10-30-2012	11:25:02	25.7	40.5	2408
54	10-30-2012	11:30:02	25.6	40.1	2470
55	10-30-2012	11:35:02	25.7	40.4	2521
56	10-30-2012	11:40:02	25.6	40	2563
57	10-30-2012	11:45:02	25.6	40	2613
58	10-30-2012	11:50:02	25.6	40	2705
59	10-30-2012	11:55:02	25.7	40.2	2717
60	10-30-2012	12:00:02	25.7	40.1	2762
61	10-30-2012	12:05:02	25.8	40.4	2807
62	10-30-2012	12:10:02	25.8	40.8	2857
63	10-30-2012	12:15:02	25.9	40.6	2913
64	10-30-2012	12:20:02	25.9	40.3	2961
65	10-30-2012	12:25:02	25.9	40.7	3045
66	10-30-2012	12:30:02	25.8	40.9	2898
67	10-30-2012	12:35:02	25.8	40.3	2810
68	10-30-2012	12:40:02	25.9	43.5	2759
69	10-30-2012	12:45:02	26	46.1	2676
70	10-30-2012	12:50:02	26.1	47	2606
71	10-30-2012	12:55:02	26	45.8	2575
72	10-30-2012	13:00:02	26.1	45.9	2505
73	10-30-2012	13:05:02	26	44.9	2466
74	10-30-2012	13:10:02	26.1	45.4	2420
75	10-30-2012	13:15:02	26.1	44.3	2385

ตารางที่ ๑.18 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 30/10/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
76	10-30-2012	13:20:02	26	44.3	2402
77	10-30-2012	13:25:02	26.1	45.3	2322
78	10-30-2012	13:30:02	25.8	44.8	2359
79	10-30-2012	13:35:02	25.5	44.9	2410
80	10-30-2012	13:40:02	25.3	45.1	2451
81	10-30-2012	13:45:02	25.1	45.9	2518
82	10-30-2012	13:50:02	24.9	46.3	2555
83	10-30-2012	13:55:02	25	46.7	2588
84	10-30-2012	14:00:02	25	46.3	2629
85	10-30-2012	14:05:02	25	46	2692
86	10-30-2012	14:10:02	25	46	2723
87	10-30-2012	14:15:02	24.9	45.9	2754
88	10-30-2012	14:20:02	24.9	45.3	2817
89	10-30-2012	14:25:02	24.9	45.3	2865
90	10-30-2012	14:30:02	24.9	45.1	2892
91	10-30-2012	14:35:02	24.9	44.8	2936
92	10-30-2012	14:40:02	24.9	44.6	2968
93	10-30-2012	14:45:02	24.9	44.8	2981
94	10-30-2012	14:50:02	24.8	44.8	2953
95	10-30-2012	14:55:02	24.8	46	2810
96	10-30-2012	15:00:02	24.4	46.1	2870
97	10-30-2012	15:05:02	24.6	46	2949
98	10-30-2012	15:10:02	24.6	46.1	2966
99	10-30-2012	15:15:02	24.5	46.1	2867
100	10-30-2012	15:20:02	24.4	45.6	2870

ตารางที่ ๑.18 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 30/10/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
101	10-30-2012	15:25:02	24.4	45.2	2860
102	10-30-2012	15:30:02	24.5	44.4	2875
103	10-30-2012	15:35:02	24.6	44	2881
104	10-30-2012	15:40:02	24.4	43.5	2903
105	10-30-2012	15:45:02	24.5	43.1	2915
106	10-30-2012	15:50:02	24.3	42.8	2917
107	10-30-2012	15:55:02	24.4	42.9	2925
108	10-30-2012	16:00:02	24.5	42.8	2929
109	10-30-2012	16:05:02	24.4	42.6	2956
110	10-30-2012	16:10:02	24.4	42.6	2974
111	10-30-2012	16:15:02	24.4	42.2	3024
112	10-30-2012	16:20:02	24.3	42	3064
113	10-30-2012	16:25:02	24.3	41.4	3102
114	10-30-2012	16:30:02	24	41.6	3162
115	10-30-2012	16:35:02	24.1	42.2	3057
116	10-30-2012	16:40:02	24.1	42.4	3022
117	10-30-2012	16:45:02	24.3	42.7	3016
118	10-30-2012	16:50:02	24.6	42.5	3002
119	10-30-2012	16:55:02	24.8	42.7	2979

ตารางที่ ๑.19 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 31/10/2555

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	10-31-2012	7:18:38	28.7	69.4	464
2	10-31-2012	7:23:38	28.6	63.2	467
3	10-31-2012	7:28:38	28.4	66.1	456
4	10-31-2012	7:33:38	27.7	56.2	437
5	10-31-2012	7:38:38	27.1	56.1	434
6	10-31-2012	7:43:38	26.7	56.1	429
7	10-31-2012	7:48:38	26.4	55.7	428
8	10-31-2012	7:53:38	26.2	56.2	429
9	10-31-2012	7:58:38	26	55.3	428
10	10-31-2012	8:03:38	25.8	55.7	427
11	10-31-2012	8:08:38	25.7	55.4	441
12	10-31-2012	8:13:38	25.6	53.3	448
13	10-31-2012	8:18:38	25.4	53.5	455
14	10-31-2012	8:23:38	25.2	54.1	455
15	10-31-2012	8:28:38	25.1	54.4	498
16	10-31-2012	8:33:38	25.1	54	547
17	10-31-2012	8:38:38	25	54.3	688
18	10-31-2012	8:43:38	25	55	759
19	10-31-2012	8:48:38	24.9	55.1	848
20	10-31-2012	8:53:38	24.8	53.2	994
21	10-31-2012	8:58:38	24.8	53	1055
22	10-31-2012	9:03:38	24.8	51.3	1174
23	10-31-2012	9:08:38	24.7	50.3	1265
24	10-31-2012	9:13:38	24.7	47.7	1374
25	10-31-2012	9:18:38	24.6	49.7	1432

ตารางที่ ก.19 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 31/10/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
26	10-31-2012	9:23:38	24.6	53.4	1335
27	10-31-2012	9:28:38	24.7	53.9	1213
28	10-31-2012	9:33:38	24.6	58.3	1055
29	10-31-2012	9:38:38	24.6	58.3	952
30	10-31-2012	9:43:38	24.6	57.1	853
31	10-31-2012	9:48:38	24.6	58.6	794
32	10-31-2012	9:53:38	24.6	58.5	737
33	10-31-2012	9:58:38	24.6	57.6	690
34	10-31-2012	10:03:38	24.6	59.4	647
35	10-31-2012	10:08:38	24.6	59.7	611
36	10-31-2012	10:13:38	24.5	59.6	592
37	10-31-2012	10:18:38	24.5	60.6	580
38	10-31-2012	10:23:38	24.6	59.3	600
39	10-31-2012	10:28:38	24.5	56.7	677
40	10-31-2012	10:33:38	24.6	58	783
41	10-31-2012	10:38:38	24.6	57.9	921
42	10-31-2012	10:43:38	24.5	57	1111
43	10-31-2012	10:48:38	24.4	55.3	1273
44	10-31-2012	10:53:38	24.5	58.1	1430
45	10-31-2012	10:58:38	24.4	57	1577
46	10-31-2012	11:03:38	24.4	56.8	1690
47	10-31-2012	11:08:38	24.4	56	1820
48	10-31-2012	11:13:38	24.3	54.1	1927
49	10-31-2012	11:18:38	24.4	55.3	2036
50	10-31-2012	11:23:38	24.4	55.1	2156

ตารางที่ ๑.19 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 31/10/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
51	10-31-2012	11:28:38	24.4	56.1	2224
52	10-31-2012	11:33:38	24.4	54.7	2384
53	10-31-2012	11:38:38	24.4	53.6	2467
54	10-31-2012	11:43:38	24.5	54.8	2420
55	10-31-2012	11:48:38	24.6	56.9	2294
56	10-31-2012	11:53:38	24.6	58.4	1921
57	10-31-2012	11:58:38	24.6	58.7	1854
58	10-31-2012	12:03:38	24.6	60.7	1691
59	10-31-2012	12:08:38	24.6	63.6	1562
60	10-31-2012	12:13:38	24.6	61.2	1406
61	10-31-2012	12:18:38	24.6	62.8	1313
62	10-31-2012	12:23:38	24.6	60.2	1251
63	10-31-2012	12:28:38	24.6	61.9	1199
64	10-31-2012	12:33:38	24.5	59.1	1265
65	10-31-2012	12:38:38	24.3	57.1	1518
66	10-31-2012	12:43:38	24.3	58.4	1737
67	10-31-2012	12:48:38	24.3	55.9	1895
68	10-31-2012	12:53:38	24.3	57.3	2020
69	10-31-2012	12:58:38	24.2	53.6	2184
70	10-31-2012	13:03:38	24.3	56.9	2310
71	10-31-2012	13:08:38	24.3	58.2	2400
72	10-31-2012	13:13:38	24.2	55.8	2495
73	10-31-2012	13:18:38	24.2	55.6	2637
74	10-31-2012	13:23:38	24.3	54.4	2732
75	10-31-2012	13:28:38	24.2	51.3	2819

ตารางที่ ก.19 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 31/10/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
76	10-31-2012	13:33:38	24.2	50.5	2889
77	10-31-2012	13:38:38	24.2	52.3	2851
78	10-31-2012	13:43:38	24.2	52.8	2846
79	10-31-2012	13:48:38	24.1	52.3	2795
80	10-31-2012	13:53:38	24.1	57.4	2412
81	10-31-2012	13:58:38	24.2	57.3	2331
82	10-31-2012	14:03:38	24.2	58.2	2323
83	10-31-2012	14:08:38	24.2	59.5	2266
84	10-31-2012	14:13:38	24.3	55	2383
85	10-31-2012	14:18:38	24.3	55.2	2454
86	10-31-2012	14:23:38	24.4	54.7	2481
87	10-31-2012	14:28:38	24.4	56.1	2610
88	10-31-2012	14:33:38	24.3	54.8	2639
89	10-31-2012	14:38:38	24.3	55	2682
90	10-31-2012	14:43:38	24.4	54.5	2723
91	10-31-2012	14:48:38	24.4	53.2	2862
92	10-31-2012	14:53:38	24.4	52.6	2885
93	10-31-2012	14:58:38	24.4	54	2993
94	10-31-2012	15:03:38	24.3	53.3	3042
95	10-31-2012	15:08:38	24.3	52.8	3109
96	10-31-2012	15:13:38	24.3	53.1	3154
97	10-31-2012	15:18:38	24.3	52.5	3242
98	10-31-2012	15:23:38	24.3	51	3198
99	10-31-2012	15:28:38	24.3	52.1	3277
100	10-31-2012	15:33:38	24.3	52.6	3290

ตารางที่ ๑.19 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 5/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
101	10-31-2012	15:38:38	24.3	55	3188
102	10-31-2012	15:43:38	24.4	57.9	2590
103	10-31-2012	15:48:38	24.3	58.7	2378
104	10-31-2012	15:53:38	24.3	58.4	2443
105	10-31-2012	15:58:38	24.3	55.2	2467
106	10-31-2012	16:03:38	24.3	53.9	2535
107	10-31-2012	16:08:38	24.3	51.7	2608
108	10-31-2012	16:13:38	24.2	50.9	2663
109	10-31-2012	16:18:38	24.3	52.2	2739
110	10-31-2012	16:23:38	24.2	53.2	2812
111	10-31-2012	16:28:38	24.2	53.6	2872
112	10-31-2012	16:33:38	24.2	52	2930
113	10-31-2012	16:38:38	24.2	51.6	3005
114	10-31-2012	16:43:38	24.2	52.8	3075
115	10-31-2012	16:48:38	24.2	52.9	3129
116	10-31-2012	16:53:38	24.2	51.5	3180
117	10-31-2012	16:58:38	24.2	51	3239
118	10-31-2012	17:03:38	24.2	49.4	3293
119	10-31-2012	17:08:38	24.2	46.8	3333
120	10-31-2012	17:13:38	24.2	45.3	3394
121	10-31-2012	17:18:38	24.2	48.6	3370

ตารางที่ ก.20 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 5/11/2555

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
1	11/5/2012	7:14:40	27.5	62	1146
2	11/5/2012	7:19:40	27.9	52.9	1120
3	11/5/2012	7:24:40	27.7	46.4	1105
4	11/5/2012	7:29:40	27.2	42	1096
5	11/5/2012	7:34:40	26.8	39.4	1090
6	11/5/2012	7:39:40	26.2	37.1	1080
7	11/5/2012	7:44:40	25.8	36.6	1074
8	11/5/2012	7:49:40	25.4	37.7	1068
9	11/5/2012	7:54:40	25.1	37.6	1054
10	11/5/2012	7:59:40	25.2	40.9	1046
11	11/5/2012	8:04:40	24.8	38.1	1036
12	11/5/2012	8:09:40	24.7	43.6	1028
13	11/5/2012	8:14:40	24.6	40.9	1014
14	11/5/2012	8:19:40	24.3	40.3	1009
15	11/5/2012	8:24:40	24.2	39.6	995
16	11/5/2012	8:29:40	24.3	41.7	992
17	11/5/2012	8:34:40	24.3	43.1	984
18	11/5/2012	8:39:40	24.1	41.1	969
19	11/5/2012	8:44:40	24.1	42.9	964
20	11/5/2012	8:49:40	23.9	40.7	950
21	11/5/2012	8:54:40	23.9	41.5	947
22	11/5/2012	8:59:40	23.9	42.3	943
23	11/5/2012	9:04:40	23.8	41.3	940
24	11/5/2012	9:09:40	23.8	42.1	959
25	11/5/2012	9:14:40	23.9	44.3	1021

ตารางที่ ก.20 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 5/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
26	11/5/2012	9:19:40	23.9	44.6	1070
27	11/5/2012	9:24:40	24	44.3	1126
28	11/5/2012	9:29:40	24	43.7	1181
29	11/5/2012	9:34:40	24.1	43.8	1253
30	11/5/2012	9:39:40	24.2	43.3	1322
31	11/5/2012	9:44:40	24.2	43.2	1403
32	11/5/2012	9:49:40	24.2	43	1445
33	11/5/2012	9:54:40	24.2	42.7	1501
34	11/5/2012	9:59:40	24.3	43.1	1569
35	11/5/2012	10:04:40	24.4	42.8	1642
36	11/5/2012	10:09:40	24.4	42.6	1751
37	11/5/2012	10:14:40	24.4	42.4	1843
38	11/5/2012	10:19:40	24.4	42	1929
39	11/5/2012	10:24:40	24.5	42	1995
40	11/5/2012	10:29:40	24.5	41.9	2075
41	11/5/2012	10:34:40	24.6	41.9	2151
42	11/5/2012	10:39:40	24.6	41.8	2220
43	11/5/2012	10:44:40	24.6	41.8	2284
44	11/5/2012	10:49:40	24.6	41.7	2353
45	11/5/2012	10:54:40	24.6	41.4	2413
46	11/5/2012	10:59:40	24.6	41.5	2453
47	11/5/2012	11:04:40	24.6	41.1	2520
48	11/5/2012	11:09:40	24.6	41.4	2552
49	11/5/2012	11:14:40	-	-	-
50	11/5/2012	11:19:40	24.6	42.1	2648

ตารางที่ ก.20 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 5/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
51	11/5/2012	11:24:40	24.8	46.1	2673
52	11/5/2012	11:29:40	24.8	45.4	2707
53	11/5/2012	11:34:40	24.9	44.2	2787
54	11/5/2012	11:39:40	24.9	43	2856
55	11/5/2012	11:44:40	24.9	42.2	2918
56	11/5/2012	11:49:40	24.9	41.5	2963
57	11/5/2012	11:54:40	24.9	40.9	3001
58	11/5/2012	11:59:40	24.8	40.3	3030
59	11/5/2012	12:04:40	24.9	40.6	3089
60	11/5/2012	12:09:40	24.9	40	3135
61	11/5/2012	12:14:40	24.8	39.7	3162
62	11/5/2012	12:19:40	24.8	39.8	3164
63	11/5/2012	12:24:40	24.8	39.6	3199
64	11/5/2012	12:29:40	24.8	39.3	3241
65	11/5/2012	12:34:40	24.8	39.1	3119
66	11/5/2012	12:39:40	24.7	38.7	3047
67	11/5/2012	12:44:40	24.6	38.4	2989
68	11/5/2012	12:49:40	24.4	38	2939
69	11/5/2012	12:54:40	24.3	37.6	2886
70	11/5/2012	12:59:40	24.2	37.6	2827
71	11/5/2012	13:04:40	24.1	37.7	2770
72	11/5/2012	13:09:40	24	37.7	2702
73	11/5/2012	13:14:40	23.9	37.9	2653
74	11/5/2012	13:19:40	23.8	37.9	2620
75	11/5/2012	13:24:40	23.8	38	2570

ตารางที่ ก.20 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 5/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
76	11/5/2012	13:29:40	23.7	37.9	2542
77	11/5/2012	13:34:40	23.7	38.4	2528
78	11/5/2012	13:39:40	23.7	38.6	2513
79	11/5/2012	13:44:40	23.7	38.7	2486
80	11/5/2012	13:49:40	23.7	38.7	2475
81	11/5/2012	13:54:40	23.6	38.6	2452
82	11/5/2012	13:59:40	23.6	38.4	2444
83	11/5/2012	14:04:40	23.6	38.4	2427
84	11/5/2012	14:09:40	23.4	38.3	2415
85	11/5/2012	14:14:40	23.4	37.9	2408
86	11/5/2012	14:19:40	23.3	37.9	2407
87	11/5/2012	14:24:40	23.3	38.1	2396
88	11/5/2012	14:29:40	23.2	38.1	2373
89	11/5/2012	14:34:40	23.2	38.1	2353
90	11/5/2012	14:39:40	23.2	38.1	2344
91	11/5/2012	14:44:40	23.2	38.3	2340
92	11/5/2012	14:49:40	23.3	40.6	2334
93	11/5/2012	14:54:40	23.3	40.8	2313
94	11/5/2012	14:59:40	23.3	40.3	2292
95	11/5/2012	15:04:40	23.2	40	2260
96	11/5/2012	15:09:40	23.2	39.9	2221
97	11/5/2012	15:14:40	23.2	39.5	2189
98	11/5/2012	15:19:40	23.2	39.5	2164
99	11/5/2012	15:24:40	23.2	41.9	2100
100	11/5/2012	15:29:40	23.2	41.9	2051

ตารางที่ ก.20 ข้อมูลการตรวจวัดก๊าซคาร์บอนไดออกไซด์ในห้องเรียนขนาดความจุ 150 คน
ณ วันที่ 5/11/2555 (ต่อ)

No.	Date	Time	Temp.(C)	RH (%)	CO2 (ppm)
101	11/5/2012	15:34:40	23.2	41.2	2008
102	11/5/2012	15:39:40	23.2	40.5	1969
103	11/5/2012	15:44:40	23.1	40.1	1921
104	11/5/2012	15:49:40	23.1	41.5	1892
105	11/5/2012	15:54:40	23.2	43	1861
106	11/5/2012	15:59:40	23.2	42.4	1829
107	11/5/2012	16:04:40	23.1	41.3	1795
108	11/5/2012	16:09:40	23.2	42.6	1759
109	11/5/2012	16:14:40	23.2	42.8	1732