

REFERENCES

- Agyenim, F. Kinght, I. and Rhodes, M. 2010. Design and Experimental Testing of Performance of an Outdoor LiBr/H₂O Solar Thermal Absorption Cooling System with Cold Store, *Solar Energy*, 84: 735-744.
- American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE). 2001. Refrigerants, Atlanta, America.
- Burapha, M. and Kiatsiriroat, T. 2008. Simplified Model of Solar Water Heating with Heat Pump Assisted, *The journal of industrial technology*, 2: 15-23.
- Chaiyat, N. and Chaichana, C. 2008. Conf. Drying Room from Geothermal Energy, In: *Proceeding of Seminar on Heat and Mass Transfer in Thermal Equipments*, 8: 87-91.
- Chaiyat, N. and Kiatsiriroat, T. 2010. Recovering and Upgrading Waste Heat of Air-Conditioner by Combining R-123 Vapor Compression Heat Pump, *Conf. Heat and Mass Transfer in Thermal Equipments, Thailand*, 9: 1-5.
- Chaiyat, N, and Kiatsiriroat, T. Experimental Study and a Simplified Model of a 10 kW_{th} Solar-Absorption Heat Transformer, *Conf. Heat and Mass Transfer in Thermal Equipments, Thailand*, 10: 1-5.
- Duffie, J.A. and Beckman, W.A. 1980. *Solar engineering of thermal processes*, English.
- Feuerecker, G. Scharfe, J. Greiter, I. Frank, C. and Alfeld, G. 1993. Measurement of thermophysical properties of LiBr-solutions at high temperatures and concentrations, *International Absorption Heat Pump Conference ASME*, 31: 493-499.
- Florida Solar Energy Center. 2004. *Solar Collector Test Report No. 00100*.




- Kaita, Y. 2000. Thermodynamic properties of lithium bromide-water solutions at high temperatures, *Int J of Refrigeration*, 24: 374-390.
- Keith, E. Herold, R.R. and Sanford, A.K. 1996. *Absorption Chillers and Heat Pumps*, America.
- Khairulin, R.A. Gruzdev, V.A. Stankus, S.V. and Verba, O.I. 2006. Experimental study of the density of aqueous solutions of lithium bromide at temperature of up to 250 in the range of mass concentrations from 30 to 65 %. *Thermophysics and Aeromechanics*, 13: 575-583.
- Kiatsiriroat, T. Bhattacharya, S. and Wibulswas, P. 1986. Upgrading Heat by a Reversed Absorption Heat Pump. *Appl Therm Eng*, 25: 175-186.
- Krunghai Bank Public Company Limited. 2010. Minimum Retail Rate (MRR), Online, <http://www.ktb.co.th>, July.
- NIST (National Institute of Standards and Technology), Inc. (REFPROP Version 7). 2000. *Thermodynamic Properties of Refrigerants and Refrigerant Mixtures Software*, America.
- Provincial Electricity Authority. 2010. The rate of electricity cost, Online, <http://www.pea.co.th/>, July.
- RETScreen Data. 2010. NASA Surface meteorology and Solar Energy, Online, <http://eosweb.larc.nasa.gov/sse/RETScreen/>, July.
- Rivara, W. Cerezo, J. and Martines, H. 2009. Energy and Exergy Analysis of an Experimental Single-Stage Heat Transformer Operating with the Water/Lithium Bromide Mixture, *Energy Research*, 34: 1121-1131.
- Sanguantrakarnkul, P. 2006. Projection of a Solar Water Heating System for Abattoir, M. Eng. thesis, Chiang Mai University, Thailand.
- Sencan, A. Yakut, K.A. and Kalogirou, S.A. 2005. Exergy Analysis of Lithium Bromide/Water Absorption System. *Renewable Energy*, 30: 645-657.



- Sotsil, S.S. and Rosenberg, J.R. 2009. Improvement of recovery energy in the absorption heat transformer process using water-CarrolTM for steam Generation. Int. Conf. Chemical & Process Engineering, Italy, 9.
- Sozen, A. 2003. Effect of Irreversibilities on Performance of an Absorption Heat Transformer Used to Increase Solar Pond's Temperature, Renewable Energy, 29: 501-515.
- Thai Meteorological Department. 2010. The ambient temperature at Chiang Mai, Online, <http://www.tmd.go.th/thailand.php>, July.
- Wongratanaphisan, T. Kiatsiriroat, T. and Vorayos, N. 2003. Solar ethanol distillation, Conf. Research Result Seminar on Renewable Energy. Thailand.
- Xuehu, Ma. Jiabin, Chen. Songping, Li. Qingyun, Sha. Aiming, Liang. Wei, Li. Jiayan, Zhang. Guojun, Zheng. and Zhihao, Feng. 2002. Application of absorption heat transformer to recover waste heat from a synthetic rubber plant. Appl Therm Eng, 25: 797-806.

APPENDICES

APPENDIX A Temperature Profiles of Main Components in the AHT Cycle



The temperature profiles of generator, condenser, evaporator, absorber and heat exchanger in the AHT system are used to calculate the entering and leaving temperature of working fluid in the AHT cycle are as follows:





APPENDIX B Temperature Profiles of Main Components in the VCHP Cycle

The temperature profiles of condenser and evaporator in the VCHP system are used to calculate the entering and leaving temperature of working fluid in the VCHP cycle are as follows:



APPENDIX C Properties of Lithium Bromide-Water Solutions

Enthalpy-Concentration and Temperature for Lithium Bromide-Water Solutions, (ASHRAE, 2001).

For Concentration $x < 40$ %LiBr

Solution temperature range $15 < t < 165$ °C

$$h = 21.4817157 - 2.38366711X + 3.90458186t + 0.03625001X^2 + 5.25010607 \times 10^{-4}t^2 - 0.0369249939tX, \text{ kJ/kg}$$

For Concentration $40 \leq x < 70$ %LiBr

Solution temperature range $15 < t < 165$ °C

$$h = \sum_0^4 A_n X^n + t \sum_0^4 B_n X^n + t^2 \sum_0^4 C_n X^n, \text{ kJ/kg}$$

Where

$$A_0 = -2024.33$$

$$B_0 = 18.2829$$

$$C_0 = -3.7008214 \text{ E-2}$$

$$A_1 = 163.309$$

$$B_1 = -1.1691757$$

$$C_1 = 2.8877666 \text{ E-3}$$

$$A_2 = -4.88161$$

$$B_2 = 3.248041 \text{ E-2}$$

$$C_2 = -8.1313015 \text{ E-5}$$

$$A_3 = 6.302948 \text{ E-2}$$

$$B_3 = -4.034184 \text{ E-4}$$

$$C_3 = 9.9116628 \text{ E-7}$$

$$A_4 = -2.913705 \text{ E-4}$$

$$B_4 = 1.8520569 \text{ E-6}$$

$$C_4 = -4.4441207 \text{ E-9}$$

Solution Temperature-Refrigerant Temperature and Saturation Pressure, (ASHRAE, 2001).

For Refrigerant $-15 < t' < 110$ °C

Solution temperature $5 < t < 175$ °C

Concentration $45 < X < 70$ %LiBr

$$t = \sum_0^3 B_n X^n + t' \sum_0^3 A_n X^n, \text{ °C}$$

$$t' = (t - \sum_0^3 B_n X^n) / \sum_0^3 A_n X^n, \text{ °C}$$

$$\log P = C + D/T' + E/T'^2, P = \text{kPa}; T' = \text{K}$$

$$T' = \frac{-2E}{D + [D^2 - 4E(C - \log P)]^{0.5}}$$

Where

$$A_0 = -2.00755$$

$$B_0 = 124.937$$

$$C = 7.05$$

$$A_1 = 0.16976$$

$$B_1 = -7.71649$$

$$D = -1596.49$$

$$A_2 = -3.133362 \text{ E-3}$$


$$B_2 = 0.152286$$

$$E = -104095.5$$

$$A_3 = 1.97668 \text{ E-5}$$

$$B_3 = -7.9509 \text{ E-4}$$

Equilibrium Chart for Aqueous Lithium Bromide Solutions, (ASHRAE, 2001).



Density of Lithium Bromide-Water Solutions, (Khairulin et al., 2006).

For Solution temperature $t < 250 \text{ }^\circ\text{C}$

Concentration $30 < X < 65 \text{ \%LiBr}$

$$\rho(t, m) = \rho_0(t)[1 + d_0(t)m + d_1(t)m^{1.5} + d_2(t)m^2], \text{ kg / m}^3$$

$$m = w / M_s(1 - w), \text{ mole / kg}$$

$$d_j(t) = \sum_{i=0}^4 C_{ji} t^i$$

$$\rho_0(t) = \text{Density of pure water, kg / m}^3$$

$$M_s = 0.086845, \text{ kg / mole}$$



Table C.1 The value of Coefficients C_{ji}

j/i	0	1	2	3	4
0	6.9979 E-2	-9.36591 E-5	1.1770035 E-6	-2.829722 E-9	7.963374 E-12
1	-7.30855 E-3	1.78947 E-5	-3.458841 E-8	-8.88725 E-10	1.085224 E-12
2	1.811867 E-4	-1.9292 E-6	-1.565022 E-8	2.082693 E-10	-3.761121 E-13

Heat Capacity of Lithium Bromide-Water Solutions, (Kaita, 2000).

For Solution temperature $40 < t < 210$ °C

Concentration $40 < X < 65$ %LiBr

$$C_p = (A_0 + A_1X) + (B_0 + B_1X)t, \text{ kJ/kg} \cdot ^\circ\text{C}$$

Where

$$A_0 = 3.462023$$

$$B_0 = 1.3499 \text{ E-}3$$

$$A_1 = -2.679895 \text{ E-}2$$

$$B_1 = -6.55 \text{ E-}6$$

Entropy of Lithium Bromide-Water Solutions, (Feuerecker, 1993).

For Solution temperature $40 < t < 210$ °C

Concentration $40 < X < 65$ %LiBr

$$S = \sum_{i=0}^3 \sum_{j=0}^3 B_{ij} X^j T^i, \text{ kJ/kg} \cdot \text{K}$$

Table C.2 The value of Coefficients B_{ij}

i	B_{i0}	B_{i1}	B_{i2}	B_{i3}
0	5.127558 E-01	-1.393954 E-02	2.924145 E-05	9.035697 E-07
1	1.226780 E-02	-9.156820 E-05	1.820453 E-08	-7.991806 E-10
2	-1.364895 E-05	1.068904 E-07	-1.381109 E-09	1.529784 E-11
3	1.021501 E-08	0	0	0

**APPENDIX D Data of the Solar Radiation and the Ambient Temperature of
Chiang Mai, Thailand**

Table D.1 The average solar radiation of Chiang Mai, Thailand, (RETScreen Data, 2010).

Month	Jan	Feb	Mar	Apr	May	Jun
I_T (MJ/m ² · d)	17.82	20.34	21.71	22.36	19.69	16.88
Month	Jul	Aug	Sep	Oct	Nov	Dec
I_T (MJ/m ² · d)	15.66	15.23	15.77	15.73	15.84	16.45




Figure D.1 The ambient temperature of Chiang Mai, Thailand, (Thai Meteorological Department, 2010).

APPENDIX E Experimental Procedures and Results

The constructed absorption heat transformer system are tested its thermal performances to upgrade heat from the installed flat-plate solar collectors. The details of the positions of the measuring sensors and the testing procedures are given as follows:

Experimental Procedures and the Data Records of solar-AHT

Figure E.1 shows the measuring positions of the sensors for the solar-AHT with supplied heat from solar water heating system. The objective of this experiment is to find out the thermal performances of the heat transformer system. The details of the instruments and the testing procedure are shown in Table E.1-E.4 and the details of the data records are shown in Table E.5-E.10.




Figure E.1 Measuring positions of a solar-Absorption Heat Transformer (solar-AHT) in the experiment.

Experimental Procedures

Table E.1 Descriptions of the temperature records of the solar-AHT.

Temperature (°C)	Position	Frequency	Instrument
1. Hot water entering generator	Number 1		
2. Hot water leaving generator	Number 2		
3. Hot water entering evaporator	Number 3		
4. Hot water leaving evaporator	Number 4		
5. Cooling water entering condenser	Number 5		
6. Cooling water leaving condenser	Number 6		
7. Useful water entering absorber	Number 7		
8. Useful water leaving absorber	Number 8		
9. Useful water in storage tank	Number 9	Record	1. Computer
10. Useful water entering storage tank	Number 10	continuously	2. Data logger
11. Useful water leaving storage tank	Number 11	every 5 min	3. Thermo
12. Refrigerant leaving condenser	Number 12	for 1.5 h.	couple
13. Refrigerant entering evaporator	Number 13		
14. Weak solution leaving absorber	Number 14		
15. Weak solution entering generator	Number 15		
16. Strong solution leaving generator	Number 16		
17. Strong solution entering absorber	Number 17		
18. Hot water entering solar collectors	Number 18		
19. Hot water leaving solar collectors	Number 19		
20. Hot water leaving hot water tank	Number 20		

Table E.2 Descriptions of the pressure records.

Pressure (cmHg)	Position	Frequency	Instrument
1. Refrigerant entering condenser	Number 1	Record	
2. Refrigerant leaving evaporator	Number 2	continuously	Pressure gage
		every 5 min	
		for 1 h.	

Table E.3 Descriptions of water flow rate records.

Flow rate (l/s)	Position	Frequency	Instrument
1. Water leaving generator	Number 1	Record continuously every day.	Flow meter
2. Water leaving evaporator	Number 2		
3. Water leaving condenser	Number 3		
4. Water leaving absorber	Number 4		
5. Water leaving storage tank	Number 5		
6. Water leaving solar collector	Number 6		

Table E.4 Descriptions of the electric power records.

Parameters	Position	Frequency	Instrument
1. Power (kW)	Power supply of the AHT system	Record continuously every 5 min for 1 h.	Power logger

Data records

Table E.5 The electrical consumption and pressure of the AHT on 14/10/2010.

Time	T _{HW,i}	T _{CW,i}	T _{UG,o}	P _H	P _L	W ₁	W ₂	W ₃	W _{AHT}
	(°C)	(°C)	(°C)	(cmHg)	(cmHg)	(kW)	(kW)	(kW)	(kW)
11:02:00	66.2	26.8	62.1	-63	-70	0.647	0.669	0.72	2.036
11:06:00	66.2	26.8	62.5	-63	-70	0.712	0.665	0.731	2.108
11:10:00	66.1	27.1	63.1	-62	-70	0.71	0.71	0.782	2.202
11:19:00	65.8	26.7	66.6	-62	-70	0.712	0.708	0.782	2.202
11:24:00	65.6	26.8	67.5	-61	-70	0.723	0.704	0.784	2.211
11:30:00	65.6	26.9	68.7	-60	-70	0.69	0.686	0.771	2.147
11:36:00	66.2	26.7	69.4	-60	-70	0.718	0.786	0.718	2.222
11:41:00	66	26.5	70.6	-60	-70	0.769	0.702	0.749	2.22
11:53:00	66.4	26.8	71.8	-59	-70	0.753	0.72	0.761	2.234
12:13:00	68.1	27	74.2	-58	-70	0.702	0.716	0.774	2.192
12:30:00	69.5	26.7	75.7	-57	-70	0.714	0.712	0.739	2.165
13:45:00	74.9	27.6	83.4	-52	-70	0.712	0.71	0.755	2.177
Average	67.2	26.9	-	-	-	0.714	0.707	0.756	2.176



Hot water leaving the AHT condenser

Bigger volume 75.71 liter

Time	Record time	Volume flow rate			Density*	Mass flow rate
	(s)	(liter/s)	(liter/min)	(m ³ /h)	(kg/m ³)	(kg/s)
21/9/2010	60	1.2618	75.7082	2.3017	992.22	1.2520
21/9/2010	60	1.2618	75.7082	2.3017	992.22	1.2520
21/9/2010	60	1.2618	75.7082	2.3017	992.22	1.2520
Average	60.00	1.2618	75.7082	2.3017	992.2164	1.2520

Note : * at water temperature around 40 Celcius

Hot water leaving the AHT absorber

Bigger volume 75.71 liter

Time	Record time	Volume flow rate			Density*	Mass flow rate
	(s)	(liter/s)	(liter/min)	(m ³ /h)	(kg/m ³)	(kg/s)
21/9/2010	195	0.3882	23.2948	0.7082	961.89	0.3735
21/9/2010	195	0.3882	23.2948	0.7082	961.89	0.3735
21/9/2010	195	0.3882	23.2948	0.7082	961.89	0.3735
Average	195.00	0.3882	23.2948	0.7082	961.8879	0.3735

Note : * at water temperature around 95 Celcius

Volume of upgraded water in storage tank

Glycol-Water (140/60) 200.00 liter

Hot water leaving the storage tank

Bigger volume 19.50 liter

Time	Record time	Volume flow rate			Density*	Mass flow rate
	(s)	(liter/s)	(liter/min)	(m ³ /h)	(kg/m ³)	(kg/s)
8/10/2010	1243	0.0157	0.9413	0.0286	961.89	0.0151

Note : * at water temperature around 95 Celcius

Table E.7 The data record of the solar-AHT on 15/10/2010 (Non-used hot water in tank).

Time	T1	T2	T3	T4	T5	T6	T7	T8
	(°C)							
13:45:12	71.5	60.9	71.7	56.4	26.1	27.2	59.3	67.6
13:50:12	72.6	61.6	72.9	58.5	27	28.4	59.7	69.5
13:55:12	73.9	62.3	74.2	60	27.4	29	63.6	71.3
14:00:12	74.5	62.5	74.6	61.9	27.2	30.1	67.4	74
14:05:12	75.2	63	75.3	63.3	27	29.9	68.8	75.4
14:10:12	75.7	62.6	75.8	63.4	27.3	29.8	70.9	76.4
14:15:12	75.9	62.9	76.1	64.7	27.3	29.8	73.3	78.3
14:20:12	76.3	62.8	76.5	64.4	27.2	30.2	74.2	78.8
14:25:12	76.9	63.2	77	65.8	27.4	30.2	75.8	80.2
14:30:12	77.1	63.3	77.3	66.9	27.2	30.1	77.1	81.3
14:35:12	77.6	63.6	77.7	68.5	27.2	30.2	77.9	81.8
14:40:12	78.2	63.9	78.3	67.1	27	29.7	79.2	82.5
14:45:12	78.3	64.3	78.5	69.7	27	29.7	80.2	83.2
14:50:12	78.4	63.5	78.6	67	27.2	30.3	80.6	83.6
14:55:12	78.4	63.4	78.6	68.5	27.4	30.4	81.5	84.8
15:00:12	78.8	64.1	79	68.3	27.5	30.5	81.9	85.1
15:05:12	78.6	64.8	78.9	70.8	26.8	29.5	82.6	85
15:10:12	78.4	64.4	78.5	67.5	26.7	29.7	83.3	85.5
15:15:12	78.2	64.5	78.4	68.5	26.6	29.7	83.4	86.5
15:20:12	78.1	64.6	78.3	65	26.5	30.1	83.5	86.2
15:25:12	78	64.8	78.1	68.2	26.9	30	84.6	87.5

Table E.7 The data record of the solar-AHT on 15/10/2010 (Non-used hot water in tank, Continued).

Time	T9	T10	T11	T12	T13	T14	T15	T16
	(°C)							
13:45:12	65.5	38.4	40.8	36	60.7	31.3	71	52.8
13:50:12	70.3	41.1	42	36.3	61.5	31.7	73.2	55.6
13:55:12	72.6	42.1	41.8	33.6	61.9	32.2	75.1	57.3
14:00:12	74.5	41.9	41.1	34	62	32.2	77.1	58.8
14:05:12	77.2	42.9	41	33	62.3	32.3	78.3	60.2
14:10:12	78.6	43.9	41.1	34.6	61.8	36.5	79.2	60.9
14:15:12	80.1	45	40.7	34.7	62.2	36.2	80.6	62.1
14:20:12	81.8	46.6	40.8	34.3	62.2	37.5	80.9	62
14:25:12	82.8	47.3	40.5	35.1	62.7	37	82.3	63.5
14:30:12	84.2	47.1	38.2	32	63.2	36.5	83.1	64.3
14:35:12	85.3	46.9	38	34.5	63.6	36	83.5	64.5
14:40:12	85.9	47.2	37.2	32.8	64.2	35.6	84.1	65.3
14:45:12	86.8	47.1	37.9	32.1	64.7	35.2	84.7	65
14:50:12	87.1	48.9	37.2	32.7	64	35.7	84.8	65.1
14:55:12	87.9	49.5	38.1	33.7	63.7	35.5	86.3	66.3
15:00:12	89	49.7	38.6	34.5	64.5	35.3	86.4	66.2
15:05:12	89.3	49.5	35	31.7	65.2	35	86.1	65.5
15:10:12	89.5	50.3	32.7	32.1	64.7	34.6	86.6	66
15:15:12	90.2	50.9	32	32	64.5	34.4	87.9	67.2
15:20:12	91.2	50.1	31.4	30	65	35.5	87	64.7
15:25:12	91.5	51.5	30.9	30.2	65.2	35	88.8	66.7

Table E.8 The data record of the solar-AHT on 15/10/2010 (Non-used hot water in tank).

Time	T17	T18	T19	T20	T21	T22	I_T
	(°C)	(°C)	(°C)	(°C)	(°C)	(°C)	(W/m ²)
13:45:12	58.30	65.10	62.70	58.10	61.60	59.40	1,020.81
13:50:12	59.00	66.80	63.80	58.80	63.40	60.40	1,109.98
13:55:12	59.40	67.90	64.70	59.90	64.10	61.40	954.78
14:00:12	59.50	69.20	65.20	60.50	64.40	61.90	1,025.69
14:05:12	59.70	69.80	65.60	61.20	64.90	62.70	1,008.28
14:10:12	59.20	70.30	65.50	61.70	65.10	63.00	984.08
14:15:12	59.90	71.20	66.10	62.30	65.10	63.20	619.53
14:20:12	59.80	71.40	66.30	62.70	66.20	63.70	650.11
14:25:12	60.30	72.50	67.10	63.30	66.30	64.20	897.88
14:30:12	60.60	73.20	67.50	63.50	64.30	64.20	554.35
14:35:12	61.20	73.80	68.30	63.90	65.60	64.80	713.38
14:40:12	61.60	74.20	68.70	64.40	66.20	65.10	506.58
14:45:12	62.10	74.60	69.10	64.60	66.70	65.50	617.41
14:50:12	61.40	74.80	69.10	65.00	66.30	65.90	314.01
14:55:12	61.00	75.60	69.40	65.10	67.60	66.00	792.99
15:00:12	61.70	75.90	69.80	65.40	67.50	66.50	453.50
15:05:12	62.50	75.90	70.10	64.80	65.10	66.20	136.94
15:10:12	62.10	76.30	70.40	63.60	63.40	65.80	104.67
15:15:12	62.00	77.10	70.60	62.40	62.00	65.60	86.84
15:20:12	62.30	78.00	72.50	61.00	60.50	65.40	82.80
15:25:12	62.60	79.30	73.10	59.80	59.40	65.20	79.41

Table E.9 The data record of the solar-AHT on 15/10/2010 (Used hot water in tank).

Time	T1	T2	T3	T4	T5	T6	T7	T8
	(°C)							
15:36:55	77.9	65.5	78.1	67.8	26.5	29.4	80.9	86.6
15:37:55	77.9	65.6	78.1	67.5	26.5	29.4	80.8	86.5
15:38:55	77.9	65.7	78.1	67.7	26.4	29.3	80.7	86.5
15:39:55	77.8	65.7	78.1	67.5	26.3	29.3	80.5	86.3
15:40:55	77.8	65.7	78	67.7	26.3	29.2	80.3	86.2
15:41:55	77.9	65.8	78.1	67.8	26.3	29.1	80.2	86.1
15:42:55	77.9	65.8	78.1	67.6	26.2	29	80.1	86
15:43:55	77.9	65.8	78	67.4	26.2	29	79.7	85.9
15:44:55	77.7	65.8	77.9	67.2	26.1	28.9	79.6	85.7
15:45:55	77.8	65.9	78	67.1	26.1	28.9	79.5	85.5
15:46:55	77.8	66	78	67.2	26.2	29	79.3	85.3
15:47:55	77.8	66.1	78	67.5	26.1	28.9	79.2	85.2
15:48:55	77.8	66.1	78	66.5	26.1	29.1	79.1	85
15:52:55	77.6	65.6	77.9	66.1	26.2	29.1	78.6	84.5
15:53:55	77.5	65.6	77.8	66.4	26.2	29.1	78.6	84.7
15:54:55	77.6	65.6	77.8	66.6	26.2	29	78.5	84.6
15:55:55	77.5	65.6	77.8	66.5	26.2	29	78.3	84.6
15:56:55	77.5	65.7	77.8	66.7	26.1	29	78.1	84.5
15:57:55	77.5	65.7	77.8	66.8	26.2	29	78	84.5
15:58:55	77.4	65.8	77.7	66.6	26.2	29	77.8	84.4
15:59:55	77.3	65.8	77.6	66.7	26.1	29	77.7	84.4

Table E.9 The data record of the solar-AHT on 15/10/2010 (Used hot water in tank, Continued).

Time	T9	T10	T11	T12	T13	T14	T15	T16
	(°C)							
15:36:55	90.2	29.9	83.7	29.2	65.6	36.6	88.2	66.3
15:37:55	90.3	29.9	83.6	29.1	65.5	36.4	88.2	66.5
15:38:55	89.5	29.9	83.5	30.9	65.7	36.3	88.2	66.3
15:39:55	89.8	30	83.2	30	65.6	36.2	88	66.2
15:40:55	89.1	30.1	83.2	28.6	65.7	36	88	66.2
15:41:55	90	30.1	83.1	30.2	65.7	35.9	87.9	66.2
15:42:55	89.7	30.1	83	29.6	65.7	35.7	87.8	66
15:43:55	89.6	30.1	82.9	29.7	65.7	35.5	87.7	66.1
15:44:55	89.5	30.1	82.9	31.4	65.8	35.4	87.5	65.8
15:45:55	89.4	30.1	82.6	29.8	65.8	35.2	87.4	65.9
15:46:55	88.9	30.3	82.8	30.8	66.3	35.5	87.5	65.8
15:47:55	90.2	31	83	29.9	67.2	36.2	88	65.7
15:48:55	90.1	31.1	83	33.7	67.2	37.7	87.8	65.5
15:52:55	89	31.3	82.5	35.3	66.8	38.1	87.4	64.3
15:53:55	89.5	31.2	82.3	33.7	66.9	38	87.5	64.5
15:54:55	89.5	31.6	82.5	29.9	67.4	38.5	87.8	64.8
15:55:55	88.7	31.2	82.3	33.1	66.7	37.7	87.5	64.8
15:56:55	89.6	31.6	82.3	31.8	67.5	38.2	87.8	64.8
15:57:55	89.2	31.6	82.3	31.4	67.5	38.1	87.7	64.9
15:58:55	88.9	31.5	82.2	32.2	67.4	37.8	87.6	64.8
15:59:55	88.7	31.4	82.1	32.6	67.4	37.6	87.4	64.8

Table E.10 The data record of the solar-AHT on 15/10/2010 (Used hot water in tank, Continued).

Time	T17	T18	T19	T20	T21	T22	I _T
	(°C)	(°C)	(°C)	(°C)	(°C)	(°C)	(W/m ²)
15:36:55	62.80	78.10	72.00	56.90	56.60	65.00	35.24
15:37:55	62.90	78.10	71.90	56.90	56.40	65.00	35.03
15:38:55	62.80	78.00	71.90	56.60	56.20	65.00	35.46
15:39:55	62.90	78.00	71.80	56.50	56.00	65.00	35.88
15:40:55	63.00	77.90	71.80	56.20	55.80	65.00	36.94
15:41:55	63.10	77.90	71.80	56.00	55.50	65.00	38.00
15:42:55	63.00	77.70	71.70	55.70	55.30	65.00	39.07
15:43:55	63.10	77.70	71.80	55.60	55.10	65.00	40.76
15:44:55	62.70	77.40	71.40	55.10	54.70	64.80	42.25
15:45:55	62.60	77.30	71.40	55.10	54.60	64.80	43.74
15:46:55	62.90	77.30	71.50	54.80	54.40	64.90	45.01
15:47:55	62.90	77.30	71.40	54.70	54.20	64.90	46.71
15:48:55	63.00	77.00	71.20	54.60	54.00	64.90	47.77
15:52:55	62.50	76.60	71.00	53.70	53.30	64.80	52.65
15:53:55	62.50	76.70	71.10	53.60	53.00	64.80	54.78
15:54:55	62.80	76.80	71.10	53.40	53.00	64.80	56.48
15:55:55	62.70	76.60	71.10	53.10	52.60	64.70	58.39
15:56:55	62.80	76.70	71.00	52.90	52.50	64.70	60.30
15:57:55	62.80	76.70	71.00	52.80	52.30	64.70	62.21
15:58:55	62.90	76.60	71.10	52.60	52.10	64.70	63.91
15:59:55	62.80	76.60	71.00	52.40	51.90	64.70	65.82

Experimental Procedures and the Data Records of solar-CAHT

Figure E.2 shows the measuring positions of the sensors for the solar-CAHT with supplied heat from solar water heating system. The details of the instruments and the testing procedure are shown in Table E.11-E.15 and the details of the data records are shown in Table E.16-E.20.




Figure E.2 Measuring positions of a solar-Compression/Absorption Heat Transformer (solar-CAHT) in the experiment.



Experimental Procedures

Table E.11 Descriptions of the temperature records of the solar-CAHT.

Temperature (°C)	Position	Frequency	Instrument
1. Hot water entering generator	Number 1		
2. Hot water leaving generator	Number 2		
3. Hot water entering evaporator	Number 3		
4. Hot water leaving evaporator	Number 4		
5. Cooling water entering condenser	Number 5		
6. Cooling water leaving condenser	Number 6		
7. Useful water entering absorber	Number 7		
8. Useful water leaving absorber	Number 8		
9. Useful water in storage tank	Number 9		
10. Useful water entering storage tank	Number 10		
11. Useful water leaving storage tank	Number 11		
12. Ambient temperature	Number 12		
13. Refrigerant leaving generator	Number 13	Record continuously every 5 min for 1.5 h.	1. Computer 2. Data logger 3. Thermo couple
14. Refrigerant leaving condenser	Number 14		
15. Refrigerant entering absorber	Number 15		
16. Refrigerant entering evaporator	Number 16		
17. Strong solution leaving generator	Number 17		
18. Strong solution entering absorber	Number 18		
19. Weak solution entering generator	Number 19		
20. Hot water entering solar collectors	Number 20		
21. Hot water leaving solar collectors	Number 21		
22. Hot water leaving hot water tank	Number 22		
23. R-134A entering compressor _{r,1}	Number 23		
24. R-134A entering economizer _r	Number 24		
25. R-134A entering PRV _{r,1}	Number 25		
26. R-134A entering evaporator _r	Number 26		
27. R-123 entering compressor _{r,2}	Number 27		
R-123 entering condenser _r	Number 28		

Table E.11 Descriptions of the temperature records of the solar-CAHT, Continued.

Temperature (°C)	Position	Frequency	Instrument
28. R-123 entering PRV _{r2}	Number 29	Record continuously	1. Computer
29. R-123 entering economizer _r	Number 30	every 5 min for 1.5 h.	2. Data logger 3. Thermo couple

Table E.12 Descriptions of the pressure records.

Pressure (cmHg)	Position	Frequency	Instrument
1. Refrigerant entering condenser	Number 1	Record continuously every 5 min for 1 h.	Pressure gage
2. Refrigerant leaving evaporator	Number 2		
3. R-134A entering compressor _{r1}	Number 3		
4. R-134A leaving compressor _{r1}	Number 4		
5. R-123 entering compressor _{r2}	Number 5		
6. R-134A leaving compressor _{r2}	Number 6		

Table E.13 Descriptions of water flow rate records.

Flow rate (l/s)	Position	Frequency	Instrument
1. Water leaving generator	Number 1	Record continuously every day.	Flow meter
2. Water leaving evaporator	Number 2		
3. Water leaving condenser	Number 3		
4. Water leaving absorber	Number 4		
5. Water leaving storage tank	Number 5		
6. Water leaving solar collector	Number 6		

Table E.14 Descriptions of the electric power records of the AHT and the VCHP.

Parameters	Position	Frequency	Instrument
1. Power of the AHT (kW) 2. Power of the VCHP (kW)	Power supply of the AHT and the VCHP system	Record continuously every 5 min for 1 h.	Power logger

Data records

Table E.15 The electrical consumption and pressure of the AHT on 18/10/2010.

Time	$T_{HW,i}$	$T_{CW,i}$	$T_{UG,o}$	P_H	P_L	W_1	W_2	W_3	W_{AHT}
	(°C)	(°C)	(°C)	(cmHg)	(cmHg)	(kW)	(kW)	(kW)	(kW)
11:52:00	66.1	22.2	49.2	-66	-70	0.727	0.757	0.804	2.288
11:55:00	65.5	22.9	52.1	-65	-70	0.735	0.749	0.81	2.294
11:58:00	65	23.2	53.3	-65	-70	0.743	0.751	0.814	2.308
12:03:00	64.1	23.3	54.3	-65	-70	0.704	0.743	0.802	2.249
12:08:00	63.7	23.3	57.5	-65	-70	0.704	0.708	0.78	2.192
12:13:00	63.6	23.3	60.2	-65	-70	0.637	0.674	0.72	2.031
12:27:00	64.3	23.7	63.3	-63	-70	0.686	0.706	0.743	2.135
12:35:00	64.9	24.4	64.5	-62	-70	0.645	0.671	0.737	2.053
12:48:00	65.7	24.5	67.3	-60	-70	0.674	0.694	0.741	2.109
13:12:00	67.2	24.7	70.6	-59	-70	0.635	0.647	0.704	1.986
13:36:00	68.3	24.3	72.3	-58	-70	0.698	0.723	0.765	2.186
13:58:00	69.6	24.7	74.3	-56	-70	0.68	0.702	0.729	2.111
Average	65.7	23.7	-	-	-	0.689	0.71	0.762	2.162

Table E.16 The electrical consumption and pressure of the VCHP on 7/12/2010.

Time	T _{UG,i} (°C)	T _{CW,i} (°C)	T _{UG,i} -T _{CW,i} (PSI)	P _{H,R-134a} (PSI)	P _{L,R-134a} (PSI)	P _{H,R-123} (PSI)	P _{L,R-123} (PSI)	W _{VCHP} (kW)
12:21:00	52.9	25.5	27.4	210	43	54	12	2.721
12:43:00	57	25	32	213	43	58	12	2.757
13:05:00	61.4	25.7	35.7	216	43	63	13	2.799
13:14:00	62.9	25.8	37.1	220	43	65	13	2.788
13:33:00	66.2	25.8	40.4	223	44	70	13	2.864
13:43:00	67.4	26.3	41.1	225	44	72	14	2.879
14:07:00	70.8	26	44.8	227	44	77	14	2.968
14:26:00	73.1	26.3	46.8	231	44	81	14	2.976
14:48:00	75.2	26.3	48.9	235	44	84	17	2.936
15:05:00	76.7	26.5	50.2	237	44	87	17	3.03
15:24:00	78.3	26.2	52.1	240	44	90	18	3.048
15:47:00	80.2	26.2	54	245	44	94	19	3.1
Average	-	26	-	-	-	-	-	2.906

Hot water leaving the AHT condenser

Bigger volume 75.71 liter

Time	Record time	Volume flow rate			Density*	Mass flow rate
	(s)	(liter/s)	(liter/min)	(m ³ /h)	(kg/m ³)	(kg/s)
7/12/2010	96	0.7886	47.3177	1.4386	997.05	0.7863
7/12/2010	96	0.7886	47.3177	1.4386	997.05	0.7863
7/12/2010	97	0.7805	46.8298	1.4237	997.05	0.7782
Average	96.33	0.7859	47.1550	1.4336	997.0476	0.7836

Note : * at water temperature around 40 Celcius

Hot water leaving the AHT absorber

Bigger volume 75.71 liter

Time	Record time	Volume flow rate			Density*	Mass flow rate
	(s)	(liter/s)	(liter/min)	(m ³ /h)	(kg/m ³)	(kg/s)
7/12/2010	195	0.3882	23.2948	0.7082	961.89	0.3735
7/12/2010	195	0.3882	23.2948	0.7082	961.89	0.3735
7/12/2010	195	0.3882	23.2948	0.7082	961.89	0.3735
Average	195.00	0.3882	23.2948	0.7082	961.8879	0.3735

Note : * at water temperature around 95 Celcius

Volume of upgraded water in storage tank

Glycol-Water (140/60) 200.00 liter

Hot water leaving the storage tank

Bigger volume 19.50 liter

Time	Record time	Volume flow rate			Density*	Mass flow rate
	(s)	(liter/s)	(liter/min)	(m ³ /h)	(kg/m ³)	(kg/s)
7/12/2010	882	0.0221	1.3265	0.0403	961.89	0.0213

Note : * at water temperature around 95 Celcius

Hot water leaving the upgraded water tank (Loop of condenser_r and tank)

Bigger volume 75.71 liter

Time	Record time	Volume flow rate			Density*	Mass flow rate
	(s)	(liter/s)	(liter/min)	(m ³ /hr)	(kg/m ³)	(kg/s)
7/12/2553	95	0.7969	47.8157	1.4537	971.79	0.7744

Note : * at water temperature around 80 Celcius

Table E.18 The data record of the solar- CAHT on 7/12/2010 (Non-used hot water in tank).

Time	T1	T2	T3	T4	T5	T6	T7	T8
	(°C)							
14:00:12	74.50	62.50	74.60	61.90	27.20	30.10	67.40	74.00
14:05:12	75.20	63.00	75.30	63.30	27.00	29.90	68.80	75.40
14:10:12	75.70	62.60	75.80	63.40	27.30	29.80	70.90	76.40
14:15:12	75.90	62.90	76.10	64.70	27.30	29.80	73.30	78.30
14:20:12	76.30	62.80	76.50	64.40	27.20	30.20	74.20	78.80
14:25:12	76.90	63.20	77.00	65.80	27.40	30.20	75.80	80.20
14:30:12	77.10	63.30	77.30	66.90	27.20	30.10	77.10	81.30
14:35:12	77.60	63.60	77.70	68.50	27.20	30.20	77.90	81.80
14:40:12	78.20	63.90	78.30	67.10	27.00	29.70	79.20	82.50
14:45:12	78.30	64.30	78.50	69.70	27.00	29.70	80.20	83.20
14:50:12	78.40	63.50	78.60	67.00	27.20	30.30	80.60	83.60
14:55:12	78.40	63.40	78.60	68.50	27.40	30.40	81.50	84.80
15:00:12	78.80	64.10	79.00	68.30	27.50	30.50	81.90	85.10
15:05:12	78.60	64.80	78.90	70.80	26.80	29.50	82.60	85.00
15:10:12	78.40	64.40	78.50	67.50	26.70	29.70	83.30	85.50
15:15:12	78.20	64.50	78.40	68.50	26.60	29.70	83.40	86.50
15:20:12	78.10	64.60	78.30	65.00	26.50	30.10	83.50	86.20
15:25:12	78.00	64.80	78.10	68.20	26.90	30.00	84.60	87.50
15:30:12	77.90	65.00	78.10	68.40	26.80	29.90	84.70	87.80
15:35:12	77.90	65.20	78.10	68.50	26.70	29.80	84.80	88.00
15:40:12	78.00	65.30	78.10	68.50	26.80	29.80	84.80	88.20

Table E.18 The data record of the solar- CAHT on 7/12/2010 (Non-used hot water in tank, Continued).

Time	T9	T10	T11	T12	T13	T14	T15	T16
	(°C)							
14:00:12	74.50	41.90	41.10	34.00	62.00	32.20	77.10	58.80
14:05:12	77.20	42.90	41.00	33.00	62.30	32.30	78.30	60.20
14:10:12	78.60	43.90	41.10	34.60	61.80	36.50	79.20	60.90
14:15:12	80.10	45.00	40.70	34.70	62.20	36.20	80.60	62.10
14:20:12	81.80	46.60	40.80	34.30	62.20	37.50	80.90	62.00
14:25:12	82.80	47.30	40.50	35.10	62.70	37.00	82.30	63.50
14:30:12	84.20	47.10	38.20	32.00	63.20	36.50	83.10	64.30
14:35:12	85.30	46.90	38.00	34.50	63.60	36.00	83.50	64.50
14:40:12	85.90	47.20	37.20	32.80	64.20	35.60	84.10	65.30
14:45:12	86.80	47.10	37.90	32.10	64.70	35.20	84.70	65.00
14:50:12	87.10	48.90	37.20	32.70	64.00	35.70	84.80	65.10
14:55:12	87.90	49.50	38.10	33.70	63.70	35.50	86.30	66.30
15:00:12	89.00	49.70	38.60	34.50	64.50	35.30	86.40	66.20
15:05:12	89.30	49.50	35.00	31.70	65.20	35.00	86.10	65.50
15:10:12	89.50	50.30	32.70	32.10	64.70	34.60	86.60	66.00
15:15:12	90.20	50.90	32.00	32.00	64.50	34.40	87.90	67.20
15:20:12	91.20	50.10	31.40	30.00	65.00	35.50	87.00	64.70
15:25:12	91.50	51.50	30.90	30.20	65.20	35.00	88.80	66.70
15:30:12	91.50	50.90	31.00	29.80	65.40	34.90	89.10	66.80
15:35:12	91.60	50.80	30.70	29.80	65.30	34.90	89.20	67.10
15:40:12	91.80	51.60	30.70	29.50	65.40	34.90	89.30	67.30

Table E.18 The data record of the solar- CAHT on 7/12/2010 (Non-used hot water in tank).

Time	T17	T18	T19	T20	T21	T22	I_T
	(°C)	(°C)	(°C)	(°C)	(°C)	(°C)	(W/m ²)
14:00:12	59.50	69.20	65.20	60.50	64.40	61.90	1,025.69
14:05:12	59.70	69.80	65.60	61.20	64.90	62.70	1,008.28
14:10:12	59.20	70.30	65.50	61.70	65.10	63.00	984.08
14:15:12	59.90	71.20	66.10	62.30	65.10	63.20	619.53
14:20:12	59.80	71.40	66.30	62.70	66.20	63.70	650.11
14:25:12	60.30	72.50	67.10	63.30	66.30	64.20	897.88
14:30:12	60.60	73.20	67.50	63.50	64.30	64.20	554.35
14:35:12	61.20	73.80	68.30	63.90	65.60	64.80	713.38
14:40:12	61.60	74.20	68.70	64.40	66.20	65.10	506.58
14:45:12	62.10	74.60	69.10	64.60	66.70	65.50	617.41
14:50:12	61.40	74.80	69.10	65.00	66.30	65.90	314.01
14:55:12	61.00	75.60	69.40	65.10	67.60	66.00	792.99
15:00:12	61.70	75.90	69.80	65.40	67.50	66.50	453.50
15:05:12	62.50	75.90	70.10	64.80	65.10	66.20	136.94
15:10:12	62.10	76.30	70.40	63.60	63.40	65.80	104.67
15:15:12	62.00	77.10	70.60	62.40	62.00	65.60	86.84
15:20:12	62.30	78.00	72.50	61.00	60.50	65.40	82.80
15:25:12	62.60	79.30	73.10	59.80	59.40	65.20	79.41
15:30:12	62.60	78.80	72.50	59.50	59.00	65.20	77.07
15:35:12	62.60	79.00	72.50	59.30	58.80	65.20	73.25
15:40:12	62.80	79.10	72.60	59.10	58.60	65.20	68.15

Table E.18 The data record of the solar- CAHT on 7/12/2010 (Non-used hot water in tank).

Time	T1r	T2r	T3r	T4r	T5r	T6r	T7r	T8r
	(°C)	(°C)	(°C)	(°C)	(°C)	(°C)	(°C)	(°C)
14:00:12	25.90	89.20	57.50	10.50	82.50	114.70	69.50	45.70
14:05:12	25.70	88.80	57.40	10.10	82.20	114.60	69.90	46.00
14:10:12	25.80	89.10	57.60	10.40	82.50	115.40	69.80	46.00
14:15:12	25.80	88.80	57.60	10.30	82.30	114.90	69.90	46.10
14:20:12	25.70	89.40	57.60	10.20	82.60	114.90	69.80	46.40
14:25:12	26.00	89.20	57.80	10.40	83.10	115.10	70.00	46.20
14:30:12	26.20	89.70	57.80	10.50	82.60	114.80	69.60	46.30
14:35:12	26.30	89.70	58.10	10.60	83.20	115.60	70.00	46.60
14:40:12	26.20	89.70	57.80	10.50	83.10	115.60	70.10	46.50
14:45:12	26.50	90.10	58.20	10.60	83.30	115.70	70.40	46.60
14:50:12	26.50	90.00	58.20	10.80	83.40	115.60	70.30	46.50
14:55:12	26.20	90.10	58.20	10.70	83.40	115.70	70.30	46.50
15:00:12	26.50	89.90	58.20	10.60	83.40	115.50	69.90	46.50
15:05:12	26.00	89.70	57.90	10.40	83.20	115.00	70.30	46.60
15:10:12	26.10	90.10	58.20	10.80	83.20	115.30	70.70	46.50
15:15:12	25.70	89.20	58.10	10.50	82.30	114.80	70.20	46.40
15:20:12	26.20	89.60	58.10	10.70	83.20	115.10	70.10	46.50
15:25:12	26.30	90.10	58.20	10.80	83.30	115.90	70.40	46.40
15:30:12	26.30	89.60	58.00	10.60	83.00	115.20	69.80	46.50
15:35:12	26.50	90.10	58.20	10.70	83.10	115.40	70.20	46.50
15:40:12	26.50	90.10	58.10	10.60	83.20	115.80	70.10	46.60



Table E.19 The data record of the solar- CAHT on 7/12/2010 (Used hot water in tank).

Time	T1	T2	T3	T4	T5	T6	T7	T8
	(°C)							
15:45:55	77.9	65.70	78.10	67.70	26.40	29.30	80.70	86.50
15:46:55	77.8	65.70	78.10	67.50	26.30	29.30	80.50	86.30
15:47:55	77.8	65.70	78.00	67.70	26.30	29.20	80.30	86.20
15:48:55	77.9	65.80	78.10	67.80	26.30	29.10	80.20	86.10
15:49:55	77.90	65.80	78.10	67.60	26.20	29.00	80.10	86.00
15:50:55	77.90	65.80	78.00	67.40	26.20	29.00	79.70	85.90
15:51:55	77.70	65.80	77.90	67.20	26.10	28.90	79.60	85.70
15:52:55	77.80	65.90	78.00	67.10	26.10	28.90	79.50	85.50
15:53:55	77.80	66.00	78.00	67.20	26.20	29.00	79.30	85.30
15:54:55	77.80	66.10	78.00	67.50	26.10	28.90	79.20	85.20
15:55:55	77.80	66.10	78.00	66.50	26.10	29.10	79.10	85.00
15:56:55	77.60	65.60	77.90	66.10	26.20	29.10	78.60	84.50
15:57:55	77.50	65.60	77.80	66.40	26.20	29.10	78.60	84.70
15:58:55	77.60	65.60	77.80	66.60	26.20	29.00	78.50	84.60
15:59:55	77.50	65.60	77.80	66.50	26.20	29.00	78.30	84.60
16:00:55	77.50	65.70	77.80	66.70	26.10	29.00	78.10	84.50
16:01:55	77.50	65.70	77.80	66.80	26.20	29.00	78.00	84.50
16:02:55	77.40	65.80	77.70	66.60	26.20	29.00	77.80	84.40
16:03:55	77.30	65.80	77.60	66.70	26.10	29.00	77.70	84.40
16:04:55	77.20	65.80	77.50	66.40	26.10	28.90	77.70	84.20
16:05:55	77.4	65.50	77.70	66.00	25.90	28.80	76.80	83.60

Table E.19 The data record of the solar- CAHT on 7/12/2010 (Used hot water in tank,
Continued).

Time	T9	T10	T11	T12	T13	T14	T15	T16
	(°C)							
15:45:55	89.50	29.90	83.50	30.90	65.70	36.30	88.20	66.30
15:46:55	89.80	30.00	83.20	30.00	65.60	36.20	88.00	66.20
15:47:55	89.10	30.10	83.20	28.60	65.70	36.00	88.00	66.20
15:48:55	90.00	30.10	83.10	30.20	65.70	35.90	87.90	66.20
15:49:55	89.70	30.10	83.00	29.60	65.70	35.70	87.80	66.00
15:50:55	89.60	30.10	82.90	29.70	65.70	35.50	87.70	66.10
15:51:55	89.50	30.10	82.90	31.40	65.80	35.40	87.50	65.80
15:52:55	89.40	30.10	82.60	29.80	65.80	35.20	87.40	65.90
15:53:55	88.90	30.30	82.80	30.80	66.30	35.50	87.50	65.80
15:54:55	90.20	31.00	83.00	29.90	67.20	36.20	88.00	65.70
15:55:55	90.10	31.10	83.00	33.70	67.20	37.70	87.80	65.50
15:56:55	89.00	31.30	82.50	35.30	66.80	38.10	87.40	64.30
15:57:55	89.50	31.20	82.30	33.70	66.90	38.00	87.50	64.50
15:58:55	89.50	31.60	82.50	29.90	67.40	38.50	87.80	64.80
15:59:55	88.70	31.20	82.30	33.10	66.70	37.70	87.50	64.80
16:00:55	89.60	31.60	82.30	31.80	67.50	38.20	87.80	64.80
16:01:55	89.20	31.60	82.30	31.40	67.50	38.10	87.70	64.90
16:02:55	88.90	31.50	82.20	32.20	67.40	37.80	87.60	64.80
16:03:55	88.70	31.40	82.10	32.60	67.40	37.60	87.40	64.80
16:04:55	89.50	40.60	79.10	32.20	67.30	37.50	87.30	64.80
16:05:55	86.40	30.00	79.30	28.10	66.50	35.70	85.80	63.90

Table E.19 The data record of the solar-CAHT on 7/12/2010 (Used hot water in tank, Continued).

Time	T17	T18	T19	T20	T21	T22	I _T
	(°C)	(°C)	(°C)	(°C)	(°C)	(°C)	(W/m ²)
15:45:55	62.80	78.00	71.90	56.60	56.20	65.00	35.46
15:46:55	62.90	78.00	71.80	56.50	56.00	65.00	35.88
15:47:55	63.00	77.90	71.80	56.20	55.80	65.00	36.94
15:48:55	63.10	77.90	71.80	56.00	55.50	65.00	38.00
15:49:55	63.00	77.70	71.70	55.70	55.30	65.00	39.07
15:50:55	63.10	77.70	71.80	55.60	55.10	65.00	40.76
15:51:55	62.70	77.40	71.40	55.10	54.70	64.80	42.25
15:52:55	62.60	77.30	71.40	55.10	54.60	64.80	43.74
15:53:55	62.90	77.30	71.50	54.80	54.40	64.90	45.01
15:54:55	62.90	77.30	71.40	54.70	54.20	64.90	46.71
15:55:55	63.00	77.00	71.20	54.60	54.00	64.90	47.77
15:56:55	62.50	76.60	71.00	53.70	53.30	64.80	52.65
15:57:55	62.50	76.70	71.10	53.60	53.00	64.80	54.78
15:58:55	62.80	76.80	71.10	53.40	53.00	64.80	56.48
15:59:55	62.70	76.60	71.10	53.10	52.60	64.70	58.39
16:00:55	62.80	76.70	71.00	52.90	52.50	64.70	60.30
16:01:55	62.80	76.70	71.00	52.80	52.30	64.70	62.21
16:02:55	62.90	76.60	71.10	52.60	52.10	64.70	63.91
16:03:55	62.80	76.60	71.00	52.40	51.90	64.70	65.82
16:04:55	62.80	76.50	71.00	52.20	51.70	64.60	67.73
16:05:55	62.20	75.80	70.40	47.80	46.80	64.40	80.47

Table E.19 The data record of the solar-CAHT on 7/12/2010 (Used hot water in tank, Continued).

Time	T1r	T2r	T3r	T4r	T5r	T6r	T7r	T8r
	(°C)	(°C)	(°C)	(°C)	(°C)	(°C)	(°C)	(°C)
15:45:55	29.30	90.40	57.80	11.20	84.50	114.60	65.20	45.40
15:46:55	28.00	90.50	57.60	11.00	83.80	114.70	65.20	45.20
15:47:55	27.20	90.30	57.40	11.00	84.00	114.70	65.50	45.20
15:48:55	26.20	89.00	57.10	10.50	82.50	114.00	65.30	44.80
15:49:55	25.80	89.00	56.80	10.50	82.80	114.20	65.90	45.00
15:50:55	25.70	88.60	56.60	10.40	82.30	113.80	66.20	44.90
15:51:55	25.30	88.40	56.30	10.00	81.90	113.60	65.80	44.90
15:52:55	24.90	88.00	56.20	9.90	80.90	113.80	65.20	44.80
15:53:55	24.70	87.70	56.10	10.00	80.80	113.30	66.10	44.50
15:54:55	24.40	87.40	55.90	9.80	80.50	113.10	66.00	44.60
15:55:55	24.10	87.20	55.80	9.70	79.90	113.00	65.40	44.60
15:56:55	26.50	87.70	56.10	10.20	80.10	112.20	65.30	44.70
15:57:55	26.60	87.50	55.90	10.00	79.70	111.80	65.40	44.60
15:58:55	27.50	88.40	56.30	10.40	80.40	112.50	64.70	44.80
15:59:55	27.80	88.50	56.50	10.60	80.70	111.80	65.40	44.80
16:00:55	27.80	88.80	56.60	10.70	81.40	112.30	65.30	44.70
16:01:55	28.00	88.90	56.60	10.50	81.10	112.70	65.00	44.70
16:02:55	27.40	89.00	56.50	10.50	81.50	112.50	65.20	44.60
16:03:55	26.50	88.50	56.20	10.20	81.40	113.20	65.30	44.70
16:04:55	25.00	87.60	55.80	9.80	80.50	112.40	65.40	44.80
16:05:55	25.80	87.60	55.90	10.20	80.30	112.20	65.00	44.30

APPENDIX F The Calculation Results of the Data Records

The calculation results of the solar-AHT

Table F.1 The calculation results of the solar-AHT from data recorder on 15/10/2010
(Non-used water in tank).

Time	$\rho_{\text{Gly-Water}}$	$C_{p\text{Gly-Water}}$	Q_{ST}	$T_{\text{GHW,bulk}}$	$\Delta T_{\text{HW,G}}$	$C_{p\text{HW,G}}$	$\rho_{\text{HW,G}}$
	(kg/m ³)	(kJ/kg-K)	(kW)	(°C)	(°C)	(kJ/kg-K)	(kg/m ³)
13:45:12	1073.31	3.26	15.15	66.2	10.6	4.19	979.86
13:50:12	1072.51	3.28	11.9	67.1	11	4.19	979.36
13:55:12	1072.11	3.28	8.96	68.1	11.6	4.19	978.81
14:00:12	1071.77	3.29	7.57	68.5	12	4.19	978.58
14:05:12	1071.29	3.3	7.3	69.1	12.2	4.19	978.24
14:10:12	1071.03	3.31	6.54	69.15	13.1	4.19	978.22
14:15:12	1070.75	3.31	6.07	69.4	13	4.19	978.07
14:20:12	1070.43	3.32	5.79	69.55	13.5	4.19	977.99
14:25:12	1070.24	3.32	5.38	70.05	13.7	4.19	977.71
14:30:12	1069.97	3.33	5.16	70.2	13.8	4.19	977.62
14:35:12	1069.76	3.33	4.92	70.6	14	4.19	977.39
14:40:12	1069.64	3.34	4.61	71.05	14.3	4.19	977.13
14:45:12	1069.47	3.34	4.41	71.3	14	4.19	976.99
14:50:12	1069.41	3.34	4.13	70.95	14.9	4.19	977.19
14:55:12	1069.25	3.34	3.98	70.9	15	4.19	977.22
15:00:12	1069.03	3.35	3.89	71.45	14.7	4.19	976.9
15:05:12	1068.97	3.35	3.7	71.7	13.8	4.19	976.76
15:10:12	1068.93	3.35	3.51	71.4	14	4.19	976.93
15:15:12	1068.79	3.35	3.41	71.35	13.7	4.19	976.96
15:20:12	1068.59	3.36	3.36	71.35	13.5	4.19	976.96
15:25:12	1068.52	3.36	3.23	71.4	13.2	4.19	976.93

Table F.1 The calculation results of the solar-AHT from data recorder on 15/10/2010
(Non-used water in tank, Continued).

Time	Q_G	$TE_{HW,bulk}$	$\Delta T_{HW,E}$	$C_{PHW,E}$	$\rho_{PHW,E}$	Q_E
	(kW)	(°C)	(°C)	(kJ/kg-K)	(kg/m ³)	(kW)
13:45:12	10.24	64.05	15.3	4.19	981.03	12.73
13:50:12	10.62	65.7	14.4	4.19	980.14	11.98
13:55:12	11.2	67.1	14.2	4.19	979.36	11.8
14:00:12	11.58	68.25	12.7	4.19	978.72	10.55
14:05:12	11.77	69.3	12	4.19	978.13	9.96
14:10:12	12.64	69.6	12.4	4.19	977.96	10.29
14:15:12	12.54	70.4	11.4	4.19	977.51	9.46
14:20:12	13.02	70.45	12.1	4.19	977.48	10.04
14:25:12	13.21	71.4	11.2	4.19	976.93	9.29
14:30:12	13.31	72.1	10.4	4.19	976.52	8.62
14:35:12	13.5	73.1	9.2	4.19	975.94	7.63
14:40:12	13.78	72.7	11.2	4.19	976.17	9.29
14:45:12	13.49	74.1	8.8	4.19	975.35	7.29
14:50:12	14.36	72.8	11.6	4.19	976.12	9.62
14:55:12	14.46	73.55	10.1	4.19	975.67	8.37
15:00:12	14.17	73.65	10.7	4.19	975.62	8.87
15:05:12	13.3	74.85	8.1	4.19	974.9	6.71
15:10:12	13.49	73	11	4.19	976	9.12
15:15:12	13.2	73.45	9.9	4.19	975.73	8.21
15:20:12	13.01	71.65	13.3	4.19	976.79	11.03
15:25:12	12.72	73.15	9.9	4.19	975.91	8.21

Table F.1 The calculation results of the solar-AHT from data recorder on 15/10/2010
(Non-used water in tank, Continued).

Time	$T_{C_{w,bulk}}$	$\Delta T_{C_{w,c}}$	$C_{p_{c,w,c}}$	$\rho_{H_{w,c}}$	Q_c	$T_{A_{UG,bulk}}$
	(°C)	(°C)	(kJ/kg-K)	(kg/m ³)	(kW)	(°C)
13:45:12	26.65	1.1	4.18	996.57	6.94	63.45
13:50:12	27.7	1.4	4.18	996.28	8.83	64.6
13:55:12	28.2	1.6	4.18	996.14	10.09	67.45
14:00:12	28.65	2.9	4.18	996.01	18.28	70.7
14:05:12	28.45	2.9	4.18	996.06	18.28	72.1
14:10:12	28.55	2.5	4.18	996.03	15.76	73.65
14:15:12	28.55	2.5	4.18	996.03	15.76	75.8
14:20:12	28.7	3	4.18	995.99	18.91	76.5
14:25:12	28.8	2.8	4.18	995.96	17.65	78
14:30:12	28.65	2.9	4.18	996.01	18.28	79.2
14:35:12	28.7	3	4.18	995.99	18.91	79.85
14:40:12	28.35	2.7	4.18	996.09	17.02	80.85
14:45:12	28.35	2.7	4.18	996.09	17.02	81.7
14:50:12	28.75	3.1	4.18	995.98	19.54	82.1
14:55:12	28.9	3	4.18	995.93	18.91	83.15
15:00:12	29	3	4.18	995.9	18.91	83.5
15:05:12	28.15	2.7	4.18	996.15	17.03	83.8
15:10:12	28.2	3	4.18	996.14	18.92	84.4
15:15:12	28.15	3.1	4.18	996.15	19.55	84.95
15:20:12	28.3	3.6	4.18	996.11	22.7	84.85
15:25:12	28.45	3.1	4.18	996.06	19.55	86.05

Table F.1 The calculation results of the solar-AHT from data recorder on 15/10/2010
(Non-used water in tank, Continued).

Time	$\Delta T_{UG,A}$	$C_{pUG,A}$	$\rho_{UG,A}$	Q_A	HR_{UG}	$EER_{solar-AHT}$
	(°C)	(kJ/kg-K)	(kg/m ³)	(kW)	(-)	(-)
13:45:12	8.3	3.25	1073.65	11.24	0.49	5.33
13:50:12	9.8	3.25	1073.46	13.29	0.59	6.3
13:55:12	7.7	3.26	1072.99	10.47	0.46	4.97
14:00:12	6.6	3.28	1072.44	9	0.41	4.27
14:05:12	6.6	3.28	1072.2	9.02	0.41	4.28
14:10:12	5.5	3.29	1071.92	7.53	0.33	3.57
14:15:12	5	3.3	1071.54	6.86	0.31	3.25
14:20:12	4.6	3.3	1071.41	6.31	0.27	2.99
14:25:12	4.4	3.31	1071.14	6.05	0.27	2.87
14:30:12	4.2	3.31	1070.92	5.78	0.26	2.74
14:35:12	3.9	3.31	1070.8	5.37	0.25	2.55
14:40:12	3.3	3.32	1070.61	4.55	0.2	2.16
14:45:12	3	3.32	1070.45	4.14	0.2	1.96
14:50:12	3	3.32	1070.37	4.14	0.17	1.96
14:55:12	3.3	3.33	1070.17	4.56	0.2	2.16
15:00:12	3.2	3.33	1070.11	4.42	0.19	2.1
15:05:12	2.4	3.33	1070.05	3.32	0.17	1.57
15:10:12	2.2	3.33	1069.93	3.04	0.13	1.44
15:15:12	3.1	3.33	1069.83	4.29	0.2	2.03
15:20:12	2.7	3.33	1069.85	3.74	0.16	1.77
15:25:12	2.9	3.34	1069.61	4.02	0.19	1.91

Table F.1 The calculation results of the AHT from data recorder on 15/10/2010 (Non-used water in tank, Continued).

Time	P _{Low}		P _{High}		X _{max}	X _{min}	h ₁
	(kPa)	(PSI)	(kPa)	(PSI)	(%LiBr)	(%LiBr)	(kJ/kg)
13:45:12	4.82	0.7	14.87	2.16	52.97	44.97	2610.05
13:50:12	4.93	0.72	17.01	2.47	53.16	44.43	2611.44
13:55:12	5.07	0.74	18.43	2.67	53.07	44.47	2612.14
14:00:12	5.07	0.74	19.76	2.87	53.12	44.7	2612.31
14:05:12	5.1	0.74	21.09	3.06	53.22	44.51	2612.83
14:10:12	6.44	0.93	21.78	3.16	50.33	44.59	2611.96
14:15:12	6.33	0.92	23	3.34	50.75	44.65	2612.66
14:20:12	6.79	0.99	22.9	3.32	49.91	44.9	2612.66
14:25:12	6.61	0.96	24.5	3.55	50.52	44.76	2613.53
14:30:12	6.44	0.93	25.4	3.68	51.12	44.72	2614.39
14:35:12	6.26	0.91	25.63	3.72	51.66	44.83	2615.08
14:40:12	6.13	0.89	26.56	3.85	52.24	44.67	2616.12
14:45:12	5.99	0.87	26.21	3.8	52.75	45.23	2616.99
14:50:12	6.16	0.89	26.32	3.82	52.07	45.22	2615.78
14:55:12	6.09	0.88	27.76	4.03	52.02	45.33	2615.26
15:00:12	6.03	0.87	27.64	4.01	52.58	45.46	2616.64
15:05:12	5.93	0.86	26.79	3.89	53.14	45.73	2617.85
15:10:12	5.8	0.84	27.4	3.97	53.11	45.71	2616.99
15:15:12	5.73	0.83	28.88	4.19	53.13	45.7	2616.64
15:20:12	6.09	0.88	25.86	3.75	52.73	46.77	2617.5
15:25:12	5.93	0.86	28.25	4.1	53.14	46.54	2617.85

Table F.1 The calculation results of the AHT from data recorder on 15/10/2010 (Non-used water in tank, Continued).

Time	h_2	m'_{ref}	m'_5	m'_8	ρ_2	v_2	ρ_5
	(kJ/kg)	(kg/s)	(kg/s)	(kg/s)	(kg/m ³)	(m ³ /kg)	(kg/m ³)
13:45:12	131.17	0.0028	0.0157	0.0185	995.21	0.001	1143.99
13:50:12	132.84	0.0036	0.0181	0.0217	995.08	0.001	1143.5
13:55:12	134.93	0.0041	0.0211	0.0251	994.92	0.001	1143.32
14:00:12	134.93	0.0074	0.0392	0.0466	994.92	0.001	1143.25
14:05:12	135.35	0.0074	0.0377	0.0451	994.89	0.001	1143.06
14:10:12	152.9	0.0064	0.0498	0.0562	993.47	0.001	1143.92
14:15:12	151.65	0.0064	0.0469	0.0533	993.57	0.001	1143.69
14:20:12	157.08	0.0077	0.069	0.0767	993.11	0.001	1143.72
14:25:12	154.99	0.0072	0.0558	0.063	993.29	0.001	1143.44
14:30:12	152.9	0.0074	0.0519	0.0593	993.47	0.001	1143.11
14:35:12	150.81	0.0077	0.0504	0.0581	993.64	0.001	1142.81
14:40:12	149.14	0.0069	0.0407	0.0476	993.78	0.001	1142.36
14:45:12	147.47	0.0069	0.0415	0.0484	993.92	0.001	1141.94
14:50:12	149.56	0.0079	0.0523	0.0602	993.75	0.001	1142.51
14:55:12	148.72	0.0077	0.052	0.0596	993.82	0.001	1142.68
15:00:12	147.89	0.0077	0.0489	0.0566	993.89	0.001	1142.1
15:05:12	146.63	0.0069	0.0425	0.0494	993.99	0.001	1141.54
15:10:12	144.96	0.0077	0.0473	0.0549	994.13	0.001	1141.82
15:15:12	144.13	0.0079	0.0486	0.0565	994.2	0.001	1141.92
15:20:12	148.72	0.0092	0.0722	0.0813	993.82	0.001	1141.78
15:25:12	146.63	0.0079	0.0558	0.0637	993.99	0.001	1141.54

Table F.1 The calculation results of the AHT from data recorder on 15/10/2010 (Non-used water in tank, Continued).

Time	v_s	W_P	W_{SP}	COP_{AHT}	$(T_{A,i}-T_E)/(T_{G,i}-T_C)$
	(m ³ /kg)	(W)	(W)	(-)	(-)
13:45:12	0.0009	0.00035	0.00173	0.49	0.16
13:50:12	0.0009	0.00054	0.00239	0.59	0.10
13:55:12	0.0009	0.00068	0.00307	0.46	0.15
14:00:12	0.0009	0.00136	0.00629	0.41	0.20
14:05:12	0.0009	0.00148	0.00659	0.41	0.20
14:10:12	0.0009	0.00124	0.00835	0.33	0.26
14:15:12	0.0009	0.00134	0.00854	0.31	0.28
14:20:12	0.0009	0.00156	0.01215	0.27	0.31
14:25:12	0.0009	0.00162	0.01091	0.27	0.31
14:30:12	0.0009	0.00177	0.01076	0.26	0.32
14:35:12	0.0009	0.00187	0.01067	0.25	0.32
14:40:12	0.0009	0.00177	0.00910	0.20	0.33
14:45:12	0.0009	0.00175	0.00917	0.20	0.35
14:50:12	0.0009	0.00201	0.01154	0.17	0.36
14:55:12	0.0009	0.00209	0.01231	0.20	0.35
15:00:12	0.0009	0.00208	0.01157	0.19	0.36
15:05:12	0.0009	0.00181	0.00972	0.17	0.39
15:10:12	0.0009	0.00208	0.01118	0.13	0.39
15:15:12	0.0009	0.00230	0.01232	0.20	0.37
15:20:12	0.0009	0.00229	0.01561	0.16	0.44
15:25:12	0.0009	0.00222	0.01364	0.19	0.42

Table F.2 The calculation results of the AHT from data recorder on 15/10/2010 (Used water in tank).

Time	$\rho_{UF,bulk}$	$C_{pUF,bulk}$	Q_{ST}	$T_{G_{HW,bulk}}$	$\Delta T_{HW,G}$	$C_{p_{HW,G}}$
	(kg/m ³)	(kJ/kg-K)	(kW)	(°C)	(°C)	(kJ/kg-K)
15:36:55	984.77	4.18	4.19	71.7	12.4	4.19
15:37:55	984.8	4.18	4.18	71.75	12.3	4.19
15:38:55	984.82	4.18	4.18	71.8	12.2	4.19
15:39:55	984.87	4.18	4.15	71.75	12.1	4.19
15:40:55	984.85	4.18	4.14	71.75	12.1	4.19
15:41:55	984.87	4.18	4.13	71.85	12.1	4.19
15:42:55	984.9	4.18	4.12	71.85	12.1	4.19
15:43:55	984.92	4.18	4.11	71.85	12.1	4.19
15:44:55	984.92	4.18	4.11	71.75	11.9	4.19
15:45:55	985	4.18	4.09	71.85	11.9	4.19
15:46:55	984.9	4.18	4.09	71.9	11.8	4.19
15:47:55	984.68	4.18	4.05	71.95	11.7	4.19
15:48:55	984.65	4.18	4.04	71.95	11.7	4.19
15:52:55	984.73	4.18	3.99	71.6	12	4.19
15:53:55	984.8	4.18	3.98	71.55	11.9	4.19
15:54:55	984.65	4.18	3.97	71.6	12	4.19
15:55:55	984.8	4.18	3.98	71.55	11.9	4.19
15:56:55	984.7	4.18	3.95	71.6	11.8	4.19
15:57:55	984.7	4.18	3.95	71.6	11.8	4.19
15:58:55	984.75	4.18	3.95	71.6	11.6	4.19
15:59:55	984.8	4.18	3.95	71.55	11.5	4.19

Table F.2 The calculation results of the AHT from data recorder on 15/10/2010 (Used water in tank).

Time	$\rho_{HW,G}$	Q_G	$TE_{HW,bulk}$	$\Delta T_{HW,E}$	$C_{p_{HW,E}}$	$\rho_{HW,E}$	Q_E
	(kg/m ³)	(kW)	(°C)	(°C)	(kJ/kg-K)	(kg/m ³)	(kW)
15:36:55	976.76	11.95	72.95	10.3	4.19	976.03	8.54
15:37:55	976.73	11.85	72.8	10.6	4.19	976.12	8.79
15:38:55	976.7	11.76	72.9	10.4	4.19	976.06	8.62
15:39:55	976.73	11.66	72.8	10.6	4.19	976.12	8.79
15:40:55	976.73	11.66	72.85	10.3	4.19	976.09	8.54
15:41:55	976.67	11.66	72.95	10.3	4.19	976.03	8.54
15:42:55	976.67	11.66	72.85	10.5	4.19	976.09	8.7
15:43:55	976.67	11.66	72.7	10.6	4.19	976.17	8.79
15:44:55	976.73	11.47	72.55	10.7	4.19	976.26	8.87
15:45:55	976.67	11.47	72.55	10.9	4.19	976.26	9.04
15:46:55	976.64	11.37	72.6	10.8	4.19	976.23	8.95
15:47:55	976.61	11.27	72.75	10.5	4.19	976.14	8.71
15:48:55	976.61	11.27	72.25	11.5	4.19	976.44	9.54
15:52:55	976.81	11.56	72	11.8	4.19	976.58	9.79
15:53:55	976.84	11.47	72.1	11.4	4.19	976.52	9.45
15:54:55	976.81	11.56	72.2	11.2	4.19	976.47	9.29
15:55:55	976.84	11.47	72.15	11.3	4.19	976.49	9.37
15:56:55	976.81	11.37	72.25	11.1	4.19	976.44	9.2
15:57:55	976.81	11.37	72.3	11	4.19	976.41	9.12
15:58:55	976.81	11.18	72.15	11.1	4.19	976.49	9.21
15:59:55	976.84	11.08	72.15	10.9	4.19	976.49	9.04

Table F.2 The calculation results of the AHT from data recorder on 15/10/2010 (Used water in tank).

Time	$T_{CW, bulk, C}$	$\Delta T_{CW, C}$	$C_{pCW, C}$	$\rho_{HW, C}$	Q_C	$T_{UG, bulk, A}$
	(°C)	(°C)	(kJ/kg-K)	(kg/m ³)	(kW)	(°C)
15:36:55	27.95	2.9	4.18	996.21	15.24	83.75
15:37:55	27.95	2.9	4.18	996.21	15.24	83.65
15:38:55	27.85	2.9	4.18	996.23	15.24	83.6
15:39:55	27.8	3	4.18	996.25	15.77	83.4
15:40:55	27.75	2.9	4.18	996.26	15.24	83.25
15:41:55	27.7	2.8	4.18	996.28	14.72	83.15
15:42:55	27.6	2.8	4.18	996.31	14.72	83.05
15:43:55	27.6	2.8	4.18	996.31	14.72	82.8
15:44:55	27.5	2.8	4.18	996.33	14.72	82.65
15:45:55	27.5	2.8	4.18	996.33	14.72	82.5
15:46:55	27.6	2.8	4.18	996.31	14.72	82.3
15:47:55	27.5	2.8	4.18	996.33	14.72	82.2
15:48:55	27.6	3	4.18	996.31	15.77	82.05
15:52:55	27.65	2.9	4.18	996.29	15.24	81.55
15:53:55	27.65	2.9	4.18	996.29	15.24	81.65
15:54:55	27.6	2.8	4.18	996.31	14.72	81.55
15:55:55	27.6	2.8	4.18	996.31	14.72	81.45
15:56:55	27.55	2.9	4.18	996.32	15.24	81.3
15:57:55	27.6	2.8	4.18	996.31	14.72	81.25
15:58:55	27.6	2.8	4.18	996.31	14.72	81.1
15:59:55	27.55	2.9	4.18	996.32	15.24	81.05

Table F.2 The calculation results of the AHT from data recorder on 15/10/2010 (Used water in tank).

Time	$\Delta T_{UG,A}$	$C_{pUG,A}$	$\rho_{UG,G}$	Q_A	HR_{UG}	HR_{ST}	EER_{AHT}
	(°C)	(kJ/kg-K)	(kg/m ³)	(kW)	(-)	(-)	(-)
15:36:55	5.7	3.33	1070.06	7.88	0.38	0.17	3.74
15:37:55	5.7	3.33	1070.08	7.88	0.38	0.16	3.74
15:38:55	5.8	3.33	1070.09	8.02	0.39	0.16	3.8
15:39:55	5.8	3.33	1070.13	8.02	0.39	0.16	3.8
15:40:55	5.9	3.33	1070.16	8.15	0.4	0.17	3.87
15:41:55	5.9	3.33	1070.17	8.15	0.4	0.16	3.87
15:42:55	5.9	3.32	1070.19	8.15	0.4	0.16	3.87
15:43:55	6.2	3.32	1070.24	8.56	0.42	0.16	4.06
15:44:55	6.1	3.32	1070.27	8.42	0.41	0.16	3.99
15:45:55	6	3.32	1070.3	8.28	0.4	0.16	3.93
15:46:55	6	3.32	1070.34	8.28	0.41	0.16	3.93
15:47:55	6	3.32	1070.36	8.28	0.41	0.17	3.93
15:48:55	5.9	3.32	1070.38	8.14	0.39	0.15	3.86
15:52:55	5.9	3.32	1070.48	8.14	0.38	0.14	3.86
15:53:55	6.1	3.32	1070.46	8.42	0.4	0.14	3.99
15:54:55	6.1	3.32	1070.48	8.41	0.4	0.16	3.99
15:55:55	6.3	3.32	1070.5	8.69	0.42	0.15	4.12
15:56:55	6.4	3.32	1070.53	8.83	0.43	0.15	4.19
15:57:55	6.5	3.32	1070.54	8.96	0.44	0.15	4.25
15:58:55	6.6	3.32	1070.56	9.1	0.45	0.15	4.32
15:59:55	6.7	3.32	1070.57	9.24	0.46	0.15	4.38

Table F.2 The calculation results of the AHT from data recorder on 15/10/2010 (Used water in tank).

Time	P _{Low}		P _{High}		X _{max}	X _{min}	h ₁
	(kPa)	(PSI)	(kPa)	(PSI)	(%LiBr)	(%LiBr)	(kJ/kg)
15:36:55	6.47	0.94	27.76	4.03	52.38	46.45	2618.54
15:37:55	6.4	0.93	28.01	4.06	52.45	46.32	2618.37
15:38:55	6.37	0.92	27.76	4.03	52.62	46.45	2618.71
15:39:55	6.33	0.92	27.64	4.01	52.63	46.4	2618.54
15:40:55	6.26	0.91	27.64	4.01	52.8	46.4	2618.71
15:41:55	6.23	0.9	27.64	4.01	52.86	46.34	2618.71
15:42:55	6.16	0.89	27.4	3.97	52.98	46.41	2618.71
15:43:55	6.09	0.88	27.52	3.99	53.11	46.29	2618.71
15:44:55	6.06	0.88	27.15	3.94	53.22	46.36	2618.88
15:45:55	5.99	0.87	27.27	3.96	53.34	46.24	2618.88
15:46:55	6.09	0.88	27.15	3.94	53.42	46.36	2619.75
15:47:55	6.33	0.92	27.03	3.92	53.48	46.71	2621.3
15:48:55	6.87	1	26.79	3.89	52.58	46.73	2621.3
15:52:55	7.02	1.02	25.4	3.68	52.12	47.26	2620.61
15:53:55	6.98	1.01	25.63	3.72	52.23	47.19	2620.78
15:54:55	7.17	1.04	25.97	3.77	52.2	47.17	2621.64
15:55:55	6.87	1	25.97	3.77	52.31	47	2620.43
15:56:55	7.06	1.02	25.97	3.77	52.44	47.17	2621.81
15:57:55	7.02	1.02	26.09	3.78	52.5	47.05	2621.81
15:58:55	6.91	1	25.97	3.77	52.62	47.06	2621.64
15:59:55	6.83	0.99	25.97	3.77	52.75	46.94	2621.64

Table F.2 The calculation results of the AHT from data recorder on 15/10/2010 (Used water in tank).

Time	h_2	m'_{ref}	m'_s	m'_g	ρ_2	v_2	ρ_s
	(kJ/kg)	(kg/s)	(kg/s)	(kg/s)	(kg/m ³)	(m ³ /kg)	(kg/m ³)
15:36:55	153.32	0.0062	0.0484	0.0546	993.43	0.001	1141.56
15:37:55	152.49	0.0062	0.0467	0.0529	993.5	0.001	1141.6
15:38:55	152.07	0.0062	0.0465	0.0527	993.54	0.001	1141.44
15:39:55	151.65	0.0064	0.0476	0.054	993.57	0.001	1141.49
15:40:55	150.81	0.0062	0.0448	0.0509	993.64	0.001	1141.38
15:41:55	150.4	0.006	0.0424	0.0483	993.68	0.001	1141.36
15:42:55	149.56	0.006	0.0421	0.0481	993.75	0.001	1141.32
15:43:55	148.72	0.006	0.0404	0.0464	993.82	0.001	1141.28
15:44:55	148.31	0.006	0.0403	0.0462	993.85	0.001	1141.18
15:45:55	147.47	0.006	0.0388	0.0447	993.92	0.001	1141.13
15:46:55	148.72	0.006	0.0391	0.0451	993.82	0.001	1140.83
15:47:55	151.65	0.006	0.0411	0.0471	993.57	0.001	1140.32
15:48:55	157.92	0.0064	0.0511	0.0575	993.03	0.001	1140.64
15:52:55	159.59	0.0062	0.0602	0.0664	992.89	0.001	1140.98
15:53:55	159.17	0.0062	0.058	0.0642	992.92	0.001	1140.9
15:54:55	161.26	0.006	0.0561	0.0621	992.74	0.001	1140.63
15:55:55	157.92	0.006	0.0529	0.0589	993.03	0.001	1140.99
15:56:55	160.01	0.0062	0.0554	0.0616	992.85	0.001	1140.51
15:57:55	159.59	0.006	0.0516	0.0576	992.89	0.001	1140.49
15:58:55	158.34	0.006	0.0506	0.0565	993	0.001	1140.51
15:59:55	157.5	0.0062	0.05	0.0562	993.07	0.001	1140.47

Table F.2 The calculation results of the AHT from data recorder on 15/10/2010 (Used water in tank).

Time	v_s	W_p	W_{SP}	COP_{AHT}	$(T_{A,i}-T_E)/(T_{G,i}-T_C)$
	(m^3/kg)	(W)	(W)	(-)	(-)
15:36:55	0.0009	0.00166	0.01129	0.38	0.35
15:37:55	0.0009	0.00168	0.01105	0.38	0.34
15:38:55	0.0009	0.00166	0.01090	0.39	0.35
15:39:55	0.0009	0.00171	0.01111	0.39	0.34
15:40:55	0.0009	0.00166	0.01048	0.40	0.34
15:41:55	0.0009	0.00161	0.00994	0.40	0.33
15:42:55	0.0009	0.00159	0.00979	0.40	0.33
15:43:55	0.0009	0.00161	0.00949	0.42	0.32
15:44:55	0.0009	0.00158	0.00930	0.41	0.33
15:45:55	0.0009	0.00159	0.00904	0.40	0.32
15:46:55	0.0009	0.00158	0.00902	0.41	0.32
15:47:55	0.0009	0.00155	0.00933	0.41	0.32
15:48:55	0.0009	0.00161	0.01117	0.39	0.34
15:52:55	0.0009	0.00143	0.01213	0.38	0.36
15:53:55	0.0009	0.00145	0.01184	0.40	0.36
15:54:55	0.0009	0.00142	0.01156	0.40	0.35
15:55:55	0.0009	0.00144	0.01107	0.42	0.34
15:56:55	0.0009	0.00147	0.01149	0.43	0.34
15:57:55	0.0009	0.00143	0.01079	0.44	0.33
15:58:55	0.0009	0.00143	0.01057	0.45	0.33
15:59:55	0.0009	0.00149	0.01048	0.46	0.32

The calculation results of the solar-CAHT

Table F.3 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Non-used water in tank).

Time	$\rho_{\text{Gly-Water}}$	$C_{p\text{Gly-Water}}$	Q_{ST}	$T_{\text{GHW,bulk}}$	$\Delta T_{\text{HW,G}}$	$C_{p\text{HW,G}}$	$\rho_{\text{HW,G}}$
	(kg/m ³)	(kJ/kg-K)	(kW)	(°C)	(°C)	(kJ/kg-K)	(kg/m ³)
14:00:12	1071.77	3.29	7.57	68.50	12.00	4.19	978.58
14:05:12	1071.29	3.30	7.30	69.10	12.20	4.19	978.24
14:10:12	1071.03	3.31	6.54	69.15	13.10	4.19	978.22
14:15:12	1070.75	3.31	6.07	69.40	13.00	4.19	978.07
14:20:12	1070.43	3.32	5.79	69.55	13.50	4.19	977.99
14:25:12	1070.24	3.32	5.38	70.05	13.70	4.19	977.71
14:30:12	1069.97	3.33	5.16	70.20	13.80	4.19	977.62
14:35:12	1069.76	3.33	4.92	70.60	14.00	4.19	977.39
14:40:12	1069.64	3.34	4.61	71.05	14.30	4.19	977.13
14:45:12	1069.47	3.34	4.41	71.30	14.00	4.19	976.99
14:50:12	1069.41	3.34	4.13	70.95	14.90	4.19	977.19
14:55:12	1069.25	3.34	3.98	70.90	15.00	4.19	977.22
15:00:12	1069.03	3.35	3.89	71.45	14.70	4.19	976.90
15:05:12	1068.97	3.35	3.70	71.70	13.80	4.19	976.76
15:10:12	1068.93	3.35	3.51	71.40	14.00	4.19	976.93
15:15:12	1068.79	3.35	3.41	71.35	13.70	4.19	976.96
15:20:12	1068.59	3.36	3.36	71.35	13.50	4.19	976.96
15:25:12	1068.52	3.36	3.23	71.40	13.20	4.19	976.93
15:30:12	1068.52	3.36	3.20	71.45	12.90	4.19	976.90
15:35:12	1068.50	3.36	3.18	71.55	12.70	4.19	976.84
15:40:12	1068.46	3.36	3.17	71.65	12.70	4.19	976.79

Table F.3 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Non-used water in tank, Continued).

Time	Q_G	$T_{E_{HW, bulk}}$	$\Delta T_{HW, E}$	$C_{p_{HW, E}}$	$\rho_{HW, E}$	Q_E
	(kW)	(°C)	(°C)	(kJ/kg-K)	(kg/m ³)	(kW)
14:00:12	11.58	68.25	12.70	4.19	978.72	10.55
14:05:12	11.77	69.30	12.00	4.19	978.13	9.96
14:10:12	12.64	69.60	12.40	4.19	977.96	10.29
14:15:12	12.54	70.40	11.40	4.19	977.51	9.46
14:20:12	13.02	70.45	12.10	4.19	977.48	10.04
14:25:12	13.21	71.40	11.20	4.19	976.93	9.29
14:30:12	13.31	72.10	10.40	4.19	976.52	8.62
14:35:12	13.50	73.10	9.20	4.19	975.94	7.63
14:40:12	13.78	72.70	11.20	4.19	976.17	9.29
14:45:12	13.49	74.10	8.80	4.19	975.35	7.29
14:50:12	14.36	72.80	11.60	4.19	976.12	9.62
14:55:12	14.46	73.55	10.10	4.19	975.67	8.37
15:00:12	14.17	73.65	10.70	4.19	975.62	8.87
15:05:12	13.30	74.85	8.10	4.19	974.90	6.71
15:10:12	13.49	73.00	11.00	4.19	976.00	9.12
15:15:12	13.20	73.45	9.90	4.19	975.73	8.21
15:20:12	13.01	71.65	13.30	4.19	976.79	11.03
15:25:12	12.72	73.15	9.90	4.19	975.91	8.21
15:30:12	12.43	73.25	9.70	4.19	975.85	8.04
15:35:12	12.24	73.30	9.60	4.19	975.82	7.96
15:40:12	12.24	73.30	9.60	4.19	975.82	7.96



Table F.3 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Non-used water in tank, Continued).

Time	$T_{CW,bulk}$	$\Delta T_{CW,C}$	$C_{pCW,C}$	$\rho_{HW,C}$	Q_C	$T_{AUG,bulk}$
	(°C)	(°C)	(kJ/kg-K)	(kg/m ³)	(kW)	(°C)
14:00:12	28.65	2.90	4.18	996.01	18.28	70.70
14:05:12	28.45	2.90	4.18	996.06	18.28	72.10
14:10:12	28.55	2.50	4.18	996.03	15.76	73.65
14:15:12	28.55	2.50	4.18	996.03	15.76	75.80
14:20:12	28.70	3.00	4.18	995.99	18.91	76.50
14:25:12	28.80	2.80	4.18	995.96	17.65	78.00
14:30:12	28.65	2.90	4.18	996.01	18.28	79.20
14:35:12	28.70	3.00	4.18	995.99	18.91	79.85
14:40:12	28.35	2.70	4.18	996.09	17.02	80.85
14:45:12	28.35	2.70	4.18	996.09	17.02	81.70
14:50:12	28.75	3.10	4.18	995.98	19.54	82.10
14:55:12	28.90	3.00	4.18	995.93	18.91	83.15
15:00:12	29.00	3.00	4.18	995.90	18.91	83.50
15:05:12	28.15	2.70	4.18	996.15	17.03	83.80
15:10:12	28.20	3.00	4.18	996.14	18.92	84.40
15:15:12	28.15	3.10	4.18	996.15	19.55	84.95
15:20:12	28.30	3.60	4.18	996.11	22.70	84.85
15:25:12	28.45	3.10	4.18	996.06	19.55	86.05
15:30:12	28.35	3.10	4.18	996.09	19.55	86.25
15:35:12	28.25	3.10	4.18	996.12	19.55	86.40
15:40:12	28.30	3.00	4.18	996.11	18.92	86.50

Table F.3 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Non-used water in tank, Continued).

Time	$\Delta T_{UG,A}$	$C_{pUG,A}$	$\rho_{UG,A}$	Q_A	HR_{UG}	$EER_{solar-CAHT}$
	(°C)	(kJ/kg-K)	(kg/m ³)	(kW)	(-)	(-)
14:00:12	6.60	3.28	1072.44	9.00	0.41	4.27
14:05:12	6.60	3.28	1072.20	9.02	0.41	4.28
14:10:12	5.50	3.29	1071.92	7.53	0.33	3.57
14:15:12	5.00	3.30	1071.54	6.86	0.31	3.25
14:20:12	4.60	3.30	1071.41	6.31	0.27	2.99
14:25:12	4.40	3.31	1071.14	6.05	0.27	2.87
14:30:12	4.20	3.31	1070.92	5.78	0.26	2.74
14:35:12	3.90	3.31	1070.80	5.37	0.25	2.55
14:40:12	3.30	3.32	1070.61	4.55	0.20	2.16
14:45:12	3.00	3.32	1070.45	4.14	0.20	1.96
14:50:12	3.00	3.32	1070.37	4.14	0.17	1.96
14:55:12	3.30	3.33	1070.17	4.56	0.20	2.16
15:00:12	3.20	3.33	1070.11	4.42	0.19	2.10
15:05:12	2.40	3.33	1070.05	3.32	0.17	1.57
15:10:12	2.20	3.33	1069.93	3.04	0.13	1.44
15:15:12	3.10	3.33	1069.83	4.29	0.20	2.03
15:20:12	2.70	3.33	1069.85	3.74	0.16	1.77
15:25:12	2.90	3.34	1069.61	4.02	0.19	1.91
15:30:12	3.10	3.34	1069.57	4.30	0.21	2.04
15:35:12	3.20	3.34	1069.54	4.44	0.22	2.10
15:40:12	3.40	3.34	1069.52	4.71	0.23	2.24

Table F.3 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Non-used water in tank, Continued).

Time	P _{Low}		P _{High}		X _{max}	X _{min}	h ₁
	(kPa)	(PSI)	(kPa)	(PSI)	(%LiBr)	(%LiBr)	(kJ/kg)
14:00:12	5.07	0.74	19.76	2.87	53.12	44.7	2575.48
14:05:12	5.10	0.74	21.09	3.06	53.22	44.51	2575.30
14:10:12	6.44	0.93	21.78	3.16	50.33	44.59	2575.48
14:15:12	6.33	0.92	23.00	3.34	50.75	44.65	2574.76
14:20:12	6.79	0.99	22.90	3.32	49.91	44.9	2574.94
14:25:12	6.61	0.96	24.50	3.55	50.52	44.76	2574.40
14:30:12	6.44	0.93	25.40	3.68	51.12	44.72	2570.29
14:35:12	6.26	0.91	25.63	3.72	51.66	44.83	2569.93
14:40:12	6.13	0.89	26.56	3.85	52.24	44.67	2568.50
14:45:12	5.99	0.87	26.21	3.80	52.75	45.23	2569.75
14:50:12	6.16	0.89	26.32	3.82	52.07	45.22	2568.50
14:55:12	6.09	0.88	27.76	4.03	52.02	45.33	2570.11
15:00:12	6.03	0.87	27.64	4.01	52.58	45.46	2571.01
15:05:12	5.93	0.86	26.79	3.89	53.14	45.73	2564.55
15:10:12	5.80	0.84	27.40	3.97	53.11	45.71	2560.41
15:15:12	5.73	0.83	28.88	4.19	53.13	45.7	2559.15
15:20:12	6.09	0.88	25.86	3.75	52.73	46.77	2558.07
15:25:12	5.93	0.86	28.25	4.10	53.14	46.54	2557.17
15:30:12	5.89	0.85	28.38	4.12	53.31	46.65	2557.35
15:35:12	5.89	0.85	28.76	4.17	53.25	46.52	2556.81
15:40:12	5.89	0.85	29.01	4.21	53.31	46.45	2556.81

Table F.3 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Non-used water in tank, Continued).

Time	h_2	m'_{ref}	m'_5	m'_8	ρ_2	v_2	ρ_5
	(kJ/kg)	(kg/s)	(kg/s)	(kg/s)	(kg/m ³)	(m ³ /kg)	(kg/m ³)
14:00:12	142.45	0.0017	0.0091	0.0108	994.33	0.0010	1153.48
14:05:12	138.27	0.0017	0.0088	0.0105	994.66	0.0010	1153.49
14:10:12	144.96	0.0017	0.0134	0.0151	994.13	0.0010	1154.04
14:15:12	145.38	0.0017	0.0126	0.0143	994.09	0.0010	1154.20
14:20:12	143.71	0.0017	0.0154	0.0171	994.23	0.0010	1154.18
14:25:12	147.05	0.0017	0.0134	0.0151	993.96	0.0010	1154.30
14:30:12	134.09	0.0017	0.0120	0.0137	994.99	0.0010	1155.25
14:35:12	144.54	0.0017	0.0113	0.0130	994.16	0.0010	1155.25
14:40:12	137.44	0.0017	0.0101	0.0119	994.73	0.0010	1155.46
14:45:12	134.51	0.0017	0.0103	0.0120	994.95	0.0010	1155.01
14:50:12	137.02	0.0017	0.0113	0.0131	994.76	0.0010	1155.50
14:55:12	141.20	0.0017	0.0117	0.0134	994.43	0.0010	1155.13
15:00:12	144.54	0.0017	0.0110	0.0127	994.16	0.0010	1154.76
15:05:12	132.84	0.0017	0.0106	0.0123	995.08	0.0010	1156.10
15:10:12	134.51	0.0017	0.0106	0.0124	994.95	0.0010	1157.06
15:15:12	134.09	0.0017	0.0106	0.0123	994.99	0.0010	1157.33
15:20:12	125.73	0.0017	0.0135	0.0152	995.61	0.0010	1157.71
15:25:12	126.57	0.0017	0.0121	0.0138	995.55	0.0010	1157.77
15:30:12	124.90	0.0017	0.0120	0.0138	995.67	0.0010	1157.66
15:35:12	124.90	0.0017	0.0119	0.0136	995.67	0.0010	1157.81
15:40:12	123.64	0.0017	0.0116	0.0134	995.76	0.0010	1157.78

Table F.3 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Non-used water in tank, Continued).

Time	v_5	W_p	W_{SP}	COP_{CAHT}	$(T_{A,i}-T_E)/(T_{G,i}-T_C)$
	(m ³ /kg)	(W)	(W)	(-)	(-)
14:00:12	0.0009	0.00015	0.00013	0.41	0.20
14:05:12	0.0009	0.00016	0.00014	0.41	0.20
14:10:12	0.0009	0.00015	0.00013	0.33	0.26
14:15:12	0.0009	0.00017	0.00014	0.31	0.28
14:20:12	0.0009	0.00016	0.00014	0.27	0.31
14:25:12	0.0009	0.00018	0.00015	0.27	0.31
14:30:12	0.0009	0.00019	0.00016	0.26	0.32
14:35:12	0.0009	0.00019	0.00017	0.25	0.32
14:40:12	0.0009	0.00021	0.00018	0.20	0.33
14:45:12	0.0009	0.00020	0.00017	0.20	0.35
14:50:12	0.0009	0.00020	0.00017	0.17	0.36
14:55:12	0.0009	0.00022	0.00019	0.20	0.35
15:00:12	0.0009	0.00022	0.00019	0.19	0.36
15:05:12	0.0009	0.00021	0.00018	0.17	0.39
15:10:12	0.0009	0.00022	0.00019	0.13	0.39
15:15:12	0.0009	0.00023	0.00020	0.20	0.37
15:20:12	0.0009	0.00020	0.00017	0.16	0.44
15:25:12	0.0009	0.00022	0.00019	0.19	0.42
15:30:12	0.0009	0.00023	0.00019	0.21	0.42
15:35:12	0.0009	0.00023	0.00020	0.22	0.41
15:40:12	0.0009	0.00023	0.00020	0.23	0.41

Table F.3 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Non-used water in tank, Continued).

Time	$T_{UG,o}-T_{CW,o}$	$T_{bulk,CW}$	ΔT_{CW}	C_{pCW}	ρ_{CW}	Q_{CW}
	(°C)	(°C)	(°C)	(kJ/kg-°C)	(kg/m ³)	(kW)
14:00:12	45.20	24.15	1.70	4.1820	997.22	5.57
14:05:12	45.50	24.40	1.60	4.1819	997.16	5.24
14:10:12	45.60	24.20	1.60	4.1819	997.21	5.24
14:15:12	45.60	24.55	1.70	4.1818	997.12	5.57
14:20:12	45.80	24.45	1.70	4.1818	997.14	5.57
14:25:12	45.70	24.45	1.70	4.1818	997.14	5.57
14:30:12	45.40	24.90	1.60	4.1816	997.03	5.24
14:35:12	45.00	25.25	1.50	4.1815	996.94	4.91
14:40:12	45.20	25.15	1.30	4.1815	996.96	4.26
14:45:12	45.10	25.10	1.60	4.1816	996.98	5.24
14:50:12	45.20	25.00	1.60	4.1816	997.00	5.24
14:55:12	45.10	25.10	1.60	4.1816	996.98	5.24
15:00:12	45.30	25.00	1.60	4.1816	997.00	5.24
15:05:12	45.80	24.70	1.60	4.1817	997.08	5.24
15:10:12	46.00	24.55	1.50	4.1818	997.12	4.92
15:15:12	46.00	24.45	1.30	4.1818	997.14	4.26
15:20:12	45.50	24.70	1.60	4.1817	997.08	5.24
15:25:12	45.30	24.85	1.50	4.1817	997.04	4.92
15:30:12	45.30	25.00	1.40	4.1816	997.00	4.59
15:35:12	45.20	25.00	1.60	4.1816	997.00	5.24
15:40:12	45.20	25.10	1.60	4.1816	996.98	5.24

Table F.3 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Non-used water in tank, Continued).

Time	$T_{\text{bulk,UG}}$	ΔT_{UG}	$C_{p\text{UG}}$	ρ_{UG}	Q_{UG}	$C_{p\text{UG,Tank}}$
	(°C)	(°C)	(kJ/kg-°C)	(kg/m ³)	(kW)	(kJ/kg-°C)
14:00:12	72.50	4.60	4.1917	976.29	7.55	4.1903
14:05:12	73.00	4.60	4.1920	976.00	7.55	4.1906
14:10:12	72.95	4.70	4.1920	976.03	7.72	4.1906
14:15:12	73.30	4.60	4.1922	975.82	7.55	4.1908
14:20:12	73.50	4.80	4.1924	975.70	7.88	4.1909
14:25:12	73.25	4.50	4.1922	975.85	7.39	4.1908
14:30:12	73.30	4.40	4.1922	975.82	7.22	4.1909
14:35:12	73.30	4.60	4.1922	975.82	7.55	4.1908
14:40:12	73.25	4.50	4.1922	975.85	7.39	4.1908
14:45:12	73.30	4.60	4.1922	975.82	7.55	4.1908
14:50:12	73.35	4.70	4.1923	975.79	7.72	4.1908
14:55:12	73.35	4.70	4.1923	975.79	7.72	4.1908
15:00:12	73.40	4.60	4.1923	975.76	7.55	4.1909
15:05:12	73.60	4.60	4.1924	975.65	7.55	4.1910
15:10:12	73.60	4.60	4.1924	975.65	7.55	4.1910
15:15:12	73.45	4.70	4.1923	975.73	7.72	4.1909
15:20:12	73.35	4.70	4.1923	975.79	7.72	4.1908
15:25:12	73.25	4.70	4.1922	975.85	7.72	4.1908
15:30:12	73.30	4.60	4.1922	975.82	7.55	4.1908
15:35:12	73.35	4.70	4.1923	975.79	7.72	4.1908
15:40:12	73.40	4.60	4.1923	975.76	7.55	4.1909

Table F.3 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Non-used water in tank, Continued).

Time	$\rho_{UG,Tank}$	$Q_{UG,Tank}$	$T_{UG,o}-T_{CW,o}$	W_{Comp}	EER_{VCHP}
	(kJ/kg-°C)	(kW)	(°C)	(kW)	(-)
14:00:12	974.93	0	45.20	2.96	2.56
14:05:12	974.64	1.36	45.50	2.96	2.55
14:10:12	974.64	0.54	45.60	2.96	2.61
14:15:12	974.46	0.73	45.60	2.96	2.55
14:20:12	974.28	0.61	45.80	2.96	2.66
14:25:12	974.52	0.44	45.70	2.96	2.50
14:30:12	974.52	0.41	45.40	2.96	2.44
14:35:12	974.46	0.31	45.00	2.95	2.56
14:40:12	974.52	0.30	45.20	2.96	2.50
14:45:12	974.46	0.29	45.10	2.95	2.56
14:50:12	974.40	0.29	45.20	2.96	2.61
14:55:12	974.40	0.28	45.10	2.95	2.61
15:00:12	974.40	0.31	45.30	2.96	2.55
15:05:12	974.28	0.35	45.80	2.96	2.55
15:10:12	974.28	0.34	46.00	2.96	2.55
15:15:12	974.34	0.27	46.00	2.96	2.60
15:20:12	974.40	0.23	45.50	2.96	2.61
15:25:12	974.46	0.19	45.30	2.96	2.61
15:30:12	974.46	0.22	45.30	2.96	2.55
15:35:12	974.40	0.21	45.20	2.96	2.61
15:40:12	974.40	0.24	45.20	2.96	2.56

Table F.4 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Used water in tank).

Time	$\rho_{\text{PUF,bulk}}$	$C_{\text{PUF,bulk}}$	Q_{ST}	$T_{\text{G}_{\text{HW,bulk}}}$	$\Delta T_{\text{HW,G}}$	$C_{\text{PHW,G}}$
	(kg/m ³)	(kJ/kg-K)	(kW)	(°C)	(°C)	(kJ/kg-K)
15:45:55	1068.93	3.35	3.28	71.80	12.20	4.19
15:46:55	1068.87	3.35	3.32	71.75	12.10	4.19
15:47:55	1069.01	3.35	3.40	71.75	12.10	4.19
15:48:55	1068.83	3.35	3.30	71.85	12.10	4.19
15:49:55	1068.89	3.35	3.33	71.85	12.10	4.19
15:50:55	1068.91	3.35	3.32	71.85	12.10	4.19
15:51:55	1068.93	3.35	3.21	71.75	11.90	4.19
15:52:55	1068.95	3.35	3.29	71.85	11.90	4.19
15:53:55	1069.05	3.35	3.24	71.90	11.80	4.19
15:54:55	1068.79	3.35	3.32	71.95	11.70	4.19
15:55:55	1068.81	3.35	3.08	71.95	11.70	4.19
15:56:55	1069.03	3.35	2.94	71.60	12.00	4.19
15:57:55	1068.93	3.35	3.03	71.55	11.90	4.19
15:58:55	1068.93	3.35	3.28	71.60	12.00	4.19
15:59:55	1069.09	3.35	3.07	71.55	11.90	4.19
16:00:55	1068.91	3.35	3.15	71.60	11.80	4.19
16:01:55	1068.99	3.35	3.17	71.60	11.80	4.19
16:02:55	1069.05	3.35	3.12	71.60	11.60	4.19
16:03:55	1069.09	3.35	3.09	71.55	11.50	4.19
16:04:55	1068.93	3.35	2.93	71.50	11.40	4.19
16:05:55	1069.54	3.34	3.77	71.45	11.90	4.19

Table F.4 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Used water in tank, Continued).

Time	$\rho_{HW,G}$	Q_G	$TE_{HW,bulk}$	$\Delta T_{HW,E}$	$C_{p_{HW,E}}$	$\rho_{HW,E}$	Q_E
	(kg/m ³)	(kW)	(°C)	(°C)	(kJ/kg-K)	(kg/m ³)	(kW)
15:45:55	976.70	11.76	72.90	10.40	4.19	976.06	8.62
15:46:55	976.73	11.66	72.80	10.60	4.19	976.12	8.79
15:47:55	976.73	11.66	72.85	10.30	4.19	976.09	8.54
15:48:55	976.67	11.66	72.95	10.30	4.19	976.03	8.54
15:49:55	976.67	11.66	72.85	10.50	4.19	976.09	8.70
15:50:55	976.67	11.66	72.70	10.60	4.19	976.17	8.79
15:51:55	976.73	11.47	72.55	10.70	4.19	976.26	8.87
15:52:55	976.67	11.47	72.55	10.90	4.19	976.26	9.04
15:53:55	976.64	11.37	72.60	10.80	4.19	976.23	8.95
15:54:55	976.61	11.27	72.75	10.50	4.19	976.14	8.71
15:55:55	976.61	11.27	72.25	11.50	4.19	976.44	9.54
15:56:55	976.81	11.56	72.00	11.80	4.19	976.58	9.79
15:57:55	976.84	11.47	72.10	11.40	4.19	976.52	9.45
15:58:55	976.81	11.56	72.20	11.20	4.19	976.47	9.29
15:59:55	976.84	11.47	72.15	11.30	4.19	976.49	9.37
16:00:55	976.81	11.37	72.25	11.10	4.19	976.44	9.20
16:01:55	976.81	11.37	72.30	11.00	4.19	976.41	9.12
16:02:55	976.81	11.18	72.15	11.10	4.19	976.49	9.21
16:03:55	976.84	11.08	72.15	10.90	4.19	976.49	9.04
16:04:55	976.87	10.99	71.95	11.10	4.19	976.61	9.21
16:05:55	976.90	11.47	71.85	11.70	4.19	976.67	9.70

Table F.4 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Used water in tank, Continued).

Time	$T_{CW,bulk,C}$	$\Delta T_{CW,C}$	$C_{pCW,C}$	$\rho_{HW,C}$	Q_C	$T_{UG,bulk,A}$
	(°C)	(°C)	(kJ/kg-K)	(kg/m ³)	(kW)	(°C)
15:45:55	27.85	2.90	4.18	996.23	15.24	83.60
15:46:55	27.80	3.00	4.18	996.25	15.77	83.40
15:47:55	27.75	2.90	4.18	996.26	15.24	83.25
15:48:55	27.70	2.80	4.18	996.28	14.72	83.15
15:49:55	27.60	2.80	4.18	996.31	14.72	83.05
15:50:55	27.60	2.80	4.18	996.31	14.72	82.80
15:51:55	27.50	2.80	4.18	996.33	14.72	82.65
15:52:55	27.50	2.80	4.18	996.33	14.72	82.50
15:53:55	27.60	2.80	4.18	996.31	14.72	82.30
15:54:55	27.50	2.80	4.18	996.33	14.72	82.20
15:55:55	27.60	3.00	4.18	996.31	15.77	82.05
15:56:55	27.65	2.90	4.18	996.29	15.24	81.55
15:57:55	27.65	2.90	4.18	996.29	15.24	81.65
15:58:55	27.60	2.80	4.18	996.31	14.72	81.55
15:59:55	27.60	2.80	4.18	996.31	14.72	81.45
16:00:55	27.55	2.90	4.18	996.32	15.24	81.30
16:01:55	27.60	2.80	4.18	996.31	14.72	81.25
16:02:55	27.60	2.80	4.18	996.31	14.72	81.10
16:03:55	27.55	2.90	4.18	996.32	15.24	81.05
16:04:55	27.50	2.80	4.18	996.33	14.72	80.95
16:05:55	27.35	2.90	4.18	996.38	15.24	80.20

Table F.4 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Used water in tank, Continued).

Time	$\Delta T_{UG,A}$	$C_{PUG,A}$	$\rho_{UG,G}$	Q_A	HR_{UG}	HR_{ST}	EER_{CAHT}
	(°C)	(kJ/kg-K)	(kg/m ³)	(kW)	(-)	(-)	(-)
15:45:55	5.80	3.33	1070.09	8.02	0.39	0.16	3.80
15:46:55	5.80	3.33	1070.13	8.02	0.39	0.16	3.80
15:47:55	5.90	3.33	1070.16	8.15	0.40	0.17	3.87
15:48:55	5.90	3.33	1070.17	8.15	0.40	0.16	3.87
15:49:55	5.90	3.32	1070.19	8.15	0.40	0.16	3.87
15:50:55	6.20	3.32	1070.24	8.56	0.42	0.16	4.06
15:51:55	6.10	3.32	1070.27	8.42	0.41	0.16	3.99
15:52:55	6.00	3.32	1070.30	8.28	0.40	0.16	3.93
15:53:55	6.00	3.32	1070.34	8.28	0.41	0.16	3.93
15:54:55	6.00	3.32	1070.36	8.28	0.41	0.17	3.93
15:55:55	5.90	3.32	1070.38	8.14	0.39	0.15	3.86
15:56:55	5.90	3.32	1070.48	8.14	0.38	0.14	3.86
15:57:55	6.10	3.32	1070.46	8.42	0.40	0.14	3.99
15:58:55	6.10	3.32	1070.48	8.41	0.40	0.16	3.99
15:59:55	6.30	3.32	1070.50	8.69	0.42	0.15	4.12
16:00:55	6.40	3.32	1070.53	8.83	0.43	0.15	4.19
16:01:55	6.50	3.32	1070.54	8.96	0.44	0.15	4.25
16:02:55	6.60	3.32	1070.56	9.10	0.45	0.15	4.32
16:03:55	6.70	3.32	1070.57	9.24	0.46	0.15	4.38
16:04:55	6.50	3.32	1070.59	8.96	0.44	0.14	4.25
16:05:55	6.80	3.31	1070.73	9.37	0.44	0.18	4.44

Table F.4 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Used water in tank, Continued).

Time	P _{Low}		P _{High}		X _{max}	X _{min}	h ₁
	(kPa)	(PSI)	(kPa)	(PSI)	(%LiBr)	(%LiBr)	(kJ/kg)
15:45:55	6.37	0.92	27.76	4.03	52.62	46.45	2648.85
15:46:55	6.33	0.92	27.64	4.01	52.63	46.4	2648.35
15:47:55	6.26	0.91	27.64	4.01	52.8	46.4	2648.35
15:48:55	6.23	0.90	27.64	4.01	52.86	46.34	2648.18
15:49:55	6.16	0.89	27.40	3.97	52.98	46.41	2648.02
15:50:55	6.09	0.88	27.52	3.99	53.11	46.29	2647.85
15:51:55	6.06	0.88	27.15	3.94	53.22	46.36	2647.85
15:52:55	5.99	0.87	27.27	3.96	53.34	46.24	2647.35
15:53:55	6.09	0.88	27.15	3.94	53.42	46.36	2647.68
15:54:55	6.33	0.92	27.03	3.92	53.48	46.71	2648.02
15:55:55	6.87	1.00	26.79	3.89	52.58	46.73	2648.02
15:56:55	7.02	1.02	25.40	3.68	52.12	47.26	2647.19
15:57:55	6.98	1.01	25.63	3.72	52.23	47.19	2646.85
15:58:55	7.17	1.04	25.97	3.77	52.2	47.17	2647.19
15:59:55	6.87	1.00	25.97	3.77	52.31	47	2646.85
16:00:55	7.06	1.02	25.97	3.77	52.44	47.17	2646.85
16:01:55	7.02	1.02	26.09	3.78	52.5	47.05	2646.85
16:02:55	6.91	1.00	25.97	3.77	52.62	47.06	2646.69
16:03:55	6.83	0.99	25.97	3.77	52.75	46.94	2646.52
16:04:55	6.79	0.99	25.97	3.77	52.75	46.88	2641.51
16:05:55	6.16	0.89	24.95	3.62	53.41	46.59	2641.84

Table F.4 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Used water in tank, Continued).

Time	h_2	m'_{ref}	m'_s	m'_g	ρ_2	v_2	ρ_5
	(kJ/kg)	(kg/s)	(kg/s)	(kg/s)	(kg/m ³)	(m ³ /kg)	(kg/m ³)
15:45:55	129.50	0.0017	0.0125	0.0142	995.33	0.0010	1131.26
15:46:55	125.73	0.0017	0.0123	0.0140	995.61	0.0010	1131.44
15:47:55	119.88	0.0017	0.0120	0.0136	996.02	0.0010	1131.39
15:48:55	126.57	0.0017	0.0118	0.0134	995.55	0.0010	1131.43
15:49:55	124.06	0.0017	0.0117	0.0134	995.73	0.0010	1131.45
15:50:55	124.48	0.0017	0.0112	0.0129	995.70	0.0010	1131.46
15:51:55	131.59	0.0017	0.0112	0.0129	995.18	0.0010	1131.42
15:52:55	124.90	0.0017	0.0108	0.0125	995.67	0.0010	1131.55
15:53:55	129.08	0.0017	0.0109	0.0126	995.36	0.0010	1131.40
15:54:55	125.32	0.0017	0.0114	0.0131	995.64	0.0010	1131.26
15:55:55	141.20	0.0017	0.0133	0.0150	994.43	0.0010	1131.58
15:56:55	147.89	0.0017	0.0163	0.0179	993.89	0.0010	1132.00
15:57:55	141.20	0.0017	0.0156	0.0173	994.43	0.0010	1132.09
15:58:55	125.32	0.0017	0.0155	0.0172	995.64	0.0010	1131.98
15:59:55	138.69	0.0017	0.0148	0.0164	994.63	0.0010	1132.07
16:00:55	133.26	0.0017	0.0149	0.0166	995.05	0.0010	1132.04
16:01:55	131.59	0.0017	0.0143	0.0160	995.18	0.0010	1132.02
16:02:55	134.93	0.0017	0.0141	0.0158	994.92	0.0010	1132.04
16:03:55	136.60	0.0017	0.0135	0.0151	994.79	0.0010	1132.06
16:04:55	134.93	0.0017	0.0133	0.0150	994.92	0.0010	1133.83
16:05:55	117.79	0.0017	0.0113	0.0130	996.16	0.0010	1133.48

Table F.4 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Used water in tank, Continued).

Time	v_5	W_P	W_{SP}	COP_{AHT}	$(T_{A,i}-T_E)/(T_{G,i}-T_C)$
	(m^3/kg)	(W)	(W)	(-)	(-)
15:45:55	0.0009	0.00021	0.00019	0.47	0.35
15:46:55	0.0009	0.00021	0.00019	0.48	0.34
15:47:55	0.0009	0.00021	0.00019	0.49	0.34
15:48:55	0.0009	0.00022	0.00019	0.49	0.33
15:49:55	0.0009	0.00021	0.00019	0.49	0.33
15:50:55	0.0009	0.00022	0.00019	0.51	0.32
15:51:55	0.0009	0.00021	0.00019	0.51	0.33
15:52:55	0.0009	0.00021	0.00019	0.50	0.32
15:53:55	0.0009	0.00021	0.00019	0.50	0.32
15:54:55	0.0009	0.00021	0.00018	0.50	0.32
15:55:55	0.0009	0.00020	0.00018	0.50	0.34
15:56:55	0.0009	0.00018	0.00016	0.49	0.36
15:57:55	0.0009	0.00019	0.00016	0.51	0.36
15:58:55	0.0009	0.00019	0.00017	0.50	0.35
15:59:55	0.0009	0.00019	0.00017	0.52	0.34
16:00:55	0.0009	0.00019	0.00017	0.53	0.34
16:01:55	0.0009	0.00019	0.00017	0.54	0.33
16:02:55	0.0009	0.00019	0.00017	0.56	0.33
16:03:55	0.0009	0.00019	0.00017	0.57	0.32
16:04:55	0.0009	0.00019	0.00017	0.56	0.32
16:05:55	0.0009	0.00019	0.00017	0.56	0.31

Table F.4 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Used water in tank, Continued).

Time	$T_{UG,o}-T_{CW,o}$	$T_{bulk,cw}$	ΔT_{cw}	$C_{p,cw}$	ρ_{cw}	Q_{cw}
	(°C)	(°C)	(°C)	(kJ/kg-°C)	(kg/m ³)	(kW)
15:45:55	37.50	27.95	1.50	4.1806	996.21	4.91
15:46:55	38.70	26.80	1.40	4.1809	996.53	4.58
15:47:55	39.90	25.65	1.30	4.1813	996.83	4.26
15:48:55	40.60	24.90	1.40	4.1816	997.03	4.59
15:49:55	40.90	24.50	1.60	4.1818	997.13	5.24
15:50:55	41.50	24.00	1.40	4.1820	997.25	4.59
15:51:55	41.90	23.70	1.60	4.1822	997.33	5.24
15:52:55	42.30	23.20	1.40	4.1824	997.45	4.59
15:53:55	42.60	22.85	1.50	4.1826	997.53	4.92
15:54:55	42.80	22.70	1.40	4.1827	997.57	4.59
15:55:55	42.90	22.55	1.30	4.1828	997.60	4.26
15:56:55	40.20	25.10	1.40	4.1816	996.98	4.59
15:57:55	39.70	25.35	1.30	4.1815	996.91	4.26
15:58:55	39.10	26.05	1.50	4.1812	996.73	4.91
15:59:55	38.60	26.35	1.30	4.1811	996.65	4.26
16:00:55	38.30	26.60	1.40	4.1810	996.58	4.58
16:01:55	38.40	26.55	1.30	4.1810	996.59	4.26
16:02:55	39.10	25.70	1.40	4.1813	996.82	4.59
16:03:55	39.80	25.00	1.60	4.1816	997.00	5.24
16:04:55	41.50	23.60	1.40	4.1822	997.35	4.59
16:05:55	41.00	24.20	1.20	4.1819	997.21	3.93

Table F.4 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Used water in tank, Continued).

Time	$T_{\text{bulk,UG}}$	ΔT_{UG}	$C_{p\text{UG}}$	ρ_{UG}	Q_{SP}	$T_{\text{UG,o}} - T_{\text{CW,o}}$
	(°C)	(°C)	(kJ/kg-°C)	(kg/m ³)	(kW)	(°C)
15:45:55	46.65	36.90	4.1807	989.47	6.99	37.50
15:46:55	46.90	36.60	4.1808	989.37	6.93	38.70
15:47:55	46.50	37.20	4.1807	989.54	7.04	39.90
15:48:55	46.60	36.60	4.1807	989.49	6.93	40.60
15:49:55	46.95	36.70	4.1808	989.34	6.95	40.90
15:50:55	46.75	36.70	4.1807	989.43	6.95	41.50
15:51:55	46.90	36.80	4.1808	989.37	6.97	41.90
15:52:55	46.60	36.80	4.1807	989.49	6.97	42.30
15:53:55	46.55	37.10	4.1807	989.52	7.03	42.60
15:54:55	46.35	37.70	4.1806	989.60	7.14	42.80
15:55:55	46.20	38.00	4.1806	989.67	7.20	42.90
15:56:55	46.15	37.90	4.1806	989.69	7.18	40.20
15:57:55	46.00	37.60	4.1806	989.75	7.12	39.70
15:58:55	46.10	37.60	4.1806	989.71	7.12	39.10
15:59:55	46.05	37.10	4.1806	989.73	7.03	38.60
16:00:55	46.10	37.00	4.1806	989.71	7.01	38.30
16:01:55	46.10	37.00	4.1806	989.71	7.01	38.40
16:02:55	46.20	36.60	4.1806	989.67	6.93	39.10
16:03:55	46.35	36.70	4.1806	989.60	6.95	39.80
16:04:55	46.50	36.60	4.1807	989.54	6.93	41.50
16:05:55	46.60	37.20	4.1807	989.49	7.04	41.00

Table F.4 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Used water in tank, Continued).

Time	W_{Comp}	COP_{VCHP}	$T_{bulk,UG}$	ΔT_{UG}	C_{pUG}
	(kW)	(-)	(°C)	(°C)	(kJ/kg-°C)
15:45:55	2.87	2.43	67.60	2.80	4.1889
15:46:55	2.89	2.40	67.60	2.80	4.1889
15:47:55	2.90	2.43	67.60	2.80	4.1889
15:48:55	2.91	2.38	67.55	2.70	4.1888
15:49:55	2.91	2.39	67.65	2.90	4.1889
15:50:55	2.92	2.38	67.60	2.80	4.1889
15:51:55	2.92	2.39	67.75	2.70	4.1889
15:52:55	2.92	2.38	67.55	2.70	4.1888
15:53:55	2.93	2.40	67.55	2.70	4.1888
15:54:55	2.93	2.44	67.55	2.70	4.1888
15:55:55	2.93	2.46	67.55	2.90	4.1888
15:56:55	2.90	2.47	67.40	2.80	4.1888
15:57:55	2.90	2.46	67.15	2.90	4.1886
15:58:55	2.89	2.46	67.30	2.80	4.1887
15:59:55	2.89	2.43	67.00	2.80	4.1885
16:00:55	2.88	2.43	66.90	2.60	4.1885
16:01:55	2.88	2.43	66.90	2.60	4.1885
16:02:55	2.89	2.40	66.90	2.80	4.1885
16:03:55	2.90	2.40	67.00	2.80	4.1885
16:04:55	2.92	2.38	67.05	2.50	4.1886
16:05:55	2.91	2.42	67.20	2.80	4.1886

Table F.4 The calculation results of the solar-CAHT from data recorder on 7/12/2010
(Used water in tank, Continued).

Time	ρ_{UG}	Q_{UG}	EER_{VCHP}
	(kg/m^3)	(kW)	(-)
15:45:55	979.09	9.15	3.18
15:46:55	979.09	9.15	3.17
15:47:55	979.09	9.15	3.16
15:48:55	979.11	8.82	3.04
15:49:55	979.06	9.48	3.26
15:50:55	979.09	9.15	3.14
15:51:55	979.00	8.82	3.02
15:52:55	979.11	8.82	3.02
15:53:55	979.11	8.82	3.01
15:54:55	979.11	8.82	3.01
15:55:55	979.11	9.48	3.23
15:56:55	979.20	9.15	3.15
15:57:55	979.34	9.48	3.27
15:58:55	979.25	9.15	3.17
15:59:55	979.42	9.15	3.17
16:00:55	979.48	8.50	2.95
16:01:55	979.48	8.50	2.95
16:02:55	979.48	9.15	3.17
16:03:55	979.42	9.15	3.16
16:04:55	979.39	8.17	2.80
16:05:55	979.31	9.15	3.14

APPENDIX G The Calculation of the Exergy Costing



The calculation results of the solar-AHT on April day

Investment cost (Cs)

$$\begin{aligned}
 &= \text{Cost of the absorption machine} + \text{Cost of solar collector} \\
 &\quad + \text{Cost of hot water tank} \\
 &= (200,000 \text{ Baht/unit}) + (35 \text{ units} \times 19,000 \text{ Baht/unit}) \\
 &\quad + (10,000 \text{ Baht/unit}) \\
 &= 200,000 \text{ Baht} + 665,000 \text{ Baht} + 10,000 \text{ Baht} \\
 &= 875,000 \text{ Baht}
 \end{aligned}$$

Cost of electrical power of operating time at 300 d/y and 8 h/d (AFC)

$$\begin{aligned}
 &= \text{The electrical power in Chapter 4 kW} \times \text{Operating time} \\
 &\quad \times \text{Cost of the electrical power} \\
 &= (2.11 \text{ kW}) \times (300 \text{ d/y}) \times (8 \text{ h/d}) \times 2.98 \text{ (Baht/kW.h)} \\
 &= 15,091 \text{ Baht}
 \end{aligned}$$

Salvage cost (SV, 10% of investment cost, Baht)

$$\begin{aligned}
 &= 875,000 \text{ Baht} \times 10\% \\
 &= 87,500 \text{ Baht}
 \end{aligned}$$

Annual maintenance cost of the system (AMC, 5% of investment cost, Baht)

$$\begin{aligned}
 &= 875,000 \text{ Baht} \times 5\% \\
 &= 43,750 \text{ Baht}
 \end{aligned}$$

Annual discount rate on loans (i)

$$= 6.45\%$$

Operation life of the system in consideration (N, year)

$$= 10 \text{ years}$$

Capital recovery factor (CRF = $\frac{i(1+i)^N}{(1+i)^N - 1}$)

$$\begin{aligned}
 &= \frac{0.0645(1+0.0645)^{10}}{(1+0.0645)^{10} - 1} \\
 &= 0.1388
 \end{aligned}$$

Sinking fund factor (SFF = $\frac{i}{(1+i)^N - 1}$)

$$= \frac{0.0645}{(1+0.0645)^{10} - 1}$$

$$= 0.0743$$

Annual cost ($AC = C_s(CRF) + AFC + AMC - SV(SFF)$, Baht/y)

$$= 875,000 \times 0.1388 + 15,091 + 43,750 - 87,500 \times 0.0743$$

$$= 173,773 \text{ Baht/y}$$

Exergy of the AHT absorber (Ex_A , From simulation in Chapter 5)

$$= 1.20 \text{ kW}$$

Exergy costing of the solar-AHT

$$= AC \text{ (Baht.y)} / Ex_A \text{ (kW)}$$

$$= \frac{173,773}{1.20} \text{ Baht/kW.y}$$

$$= 144,382 \text{ Baht/ kW.y}$$

The calculation results of the solar-CAHT on April day

Investment cost (Cs)

$$\begin{aligned}
 &= \text{Cost of the absorption machine} \\
 &\quad + \text{Cost of the absorption machine} \\
 &\quad + \text{Cost of solar collector} \\
 &\quad + \text{Cost of hot water tank} \\
 &= (200,000 \text{ Baht/unit}) + (150,000 \text{ Baht/unit}) \\
 &\quad + (18 \text{ units} \times 19,000 \text{ Baht/unit}) + (10,000 \text{ Baht/unit}) \\
 &= 200,000 \text{ Baht} + 150,000 \text{ Baht} + 342,000 \text{ Baht} \\
 &\quad + 10,000 \text{ Baht} \\
 &= 702,000 \text{ Baht}
 \end{aligned}$$

Cost of electrical power of operating time at 300 d/y and 8 h/d (AFC)

$$\begin{aligned}
 &= \text{The electrical power in Chapter 4 kW} \times \text{Operating time} \\
 &\quad \times \text{Cost of the electrical power} \\
 &= (2.11 + 3.02 \text{ kW}) \times (300 \text{ d/y}) \times (8 \text{ h/d}) \times 2.98 \\
 &\quad (\text{Baht/kW.h}) \\
 &= 36,690 \text{ Baht}
 \end{aligned}$$

Salvage cost (SV, 10% of investment cost, Baht)

$$\begin{aligned}
 &= 702,000 \text{ Baht} \times 10\% \\
 &= 70,200 \text{ Baht}
 \end{aligned}$$

Annual maintenance cost of the system (AMC, 5% of investment cost, Baht)

$$\begin{aligned}
 &= 702,000 \text{ Baht} \times 5\% \\
 &= 35,100 \text{ Baht}
 \end{aligned}$$

Annual discount rate on loans (i)

$$= 6.45\%$$

Operation life of the system in consideration (N, year)

$$= 10 \text{ years}$$

Capital recovery factor (CRF = $\frac{i(1+i)^N}{(1+i)^N - 1}$)

$$\begin{aligned}
 &= \frac{0.0645(1+0.0645)^{10}}{(1+0.0645)^{10} - 1} \\
 &= 0.1388
 \end{aligned}$$

$$\begin{aligned} \text{Sinking fund factor (SFF} &= \frac{i}{(1+i)^N - 1}) \\ &= \frac{0.0645}{(1 + 0.0645)^{10} - 1} \\ &= 0.0743 \end{aligned}$$

$$\begin{aligned} \text{Annual cost (AC} &= C_s(\text{CRF}) + \text{AFC} + \text{AMC} - \text{SV}(\text{SFF}), \text{ Baht/y)} \\ &= 702,000 \times 0.1388 + 36,690 + 35,100 - 70,200 \times 0.0743 \\ &= 163,998 \text{ Baht/y} \end{aligned}$$

$$\begin{aligned} \text{Exergy of the AHT absorber (Ex}_A, \text{ From simulation in Chapter 5)} \\ &= 1.72 \text{ kW} \end{aligned}$$

$$\begin{aligned} \text{Exergy costing of the solar-CAHT} \\ &= \text{AC (Baht.y)} / \text{Ex}_A \text{ (kW)} \\ &= \frac{163,998}{1.72} \text{ Baht/kW.y} \\ &= 95,264 \text{ Baht/ kW.y} \end{aligned}$$

APPENDIX H Publications

1. Improvement of an Absorption Heat Transformer Combined with Propane Vapor Compression Heat Pump in Industrial Process, International Conference on Green & Sustainable Innovation 2th, Le Meridien Chiang Rai Resort, Chiang Rai, Thailand, 2-4 December 2009.
2. Improvement of an Absorption Heat Transformer Performance for Upgrading Low Temperature Heat by Coupling with a Vapor Compression Heat Pump, Chiang Mai University Journal of Natural Sciences, Volume 10 No.2, 2011.
3. Upgrading of Low Temperature Solar Heat for Medium Temperature Applications by a Solar-Absorption Heat Transformer Assisting with a Vapor Compression Heat Pump, International Symposium on Low Carbon & Renewable Energy Technology 2010, Lotte Hotel, Jeju, Korea, 15-18 November 2010.
4. Experimental Study and a Simplified Model of a 10 kW_{th} Solar-Absorption Heat Transformer, Heat and Mass Transfer in Thermal Equipments 10th, Chiang Mai Grand View Hotel, Chiang Mai, Thailand, 10-11 March 2011.

**Improvement of an Absorption Heat Transformer Combined with Propane
Vapor Compression Heat Pump in Industrial Process**

 International Conference on Green and Sustainable Innovation	"Sufficiency and Sustainability through Life Cycle Thinking"
	December 2 nd – 4 th , 2009, Chiang Rai, Thailand Department of Mechanical Engineering, Chiang Mai University, Chiang Mai, Thailand 50200 Tel: +66-53-944146 Fax: +66-53-944145, E-mail: icgsi2009@eng.cmu.ac.th , http://icgsi.eng.cmu.ac.th

September 21, 2009.

Dear Author(s),

On behalf of the ICGSI 2009 Organizing Committee, we would like to thank you for submitting an abstract for the International Conference on Green and Sustainable Innovation: ICGSI-2009. We are pleased to confirm that your abstract entitled

"Improvement of an absorption heat transformer combined with propane vapor compression heat pump in industrial process"
 written by Nattaporn Chaiyat and Tanongkiat Kiatsiriroat

has been accepted for oral presentation at the conference. Therefore, we kindly invite you to submit your full paper by October 26, 2009 as MS Word 2003/XP and MS Word 2007 via the conference e-mail: icgsi2009@eng.cmu.ac.th. The instruction for submitting your full paper and the manuscript template are available either in the attached files or on our website: <http://icgsi.eng.cmu.ac.th>

Note that the registration is a prerequisite as soon as possible for final scheduling. Since there are many programs at the same time as ICGSI 2009, Chiang Rai will be hosting a big number of visitors. Therefore, early booking of hotel accommodation is strongly recommended. Please check our website for more information.

We are looking forward to receiving your full paper. If there is any question, please do not hesitate to contact us.

Your sincerely,



Professor Dr. Nobutaka Ito

Co-Chairman of the Organizing Committee
 ICGSI 2009
 Tel: (66)(53) 944146 ext. 431
 Fax: (66)(53) 944145
 Email: icgsi2009@eng.cmu.ac.th
 Address:
 ICGSI2009 Secretariat,
 Department of Mechanical Engineering
 Chiang Mai University, Chiang Mai, Thailand, 50200

**Improvement of an Absorption Heat Transformer Performance for Upgrading
Low Temperature Heat by Coupling with a Vapor Compression Heat Pump**



Chiang Mai University Journal of Natural sciences
Office of the University, Chiang Mai University, Chiang Mai 50200, Thailand.

Phone: 66-53-94-2676-7 Fax: 66-53-94-3600

E-mail: cmujour@chiangmai.ac.th

Website: <http://cmuj.chiangmai.ac.th>,

or <http://www.rac.oop.cmu.ac.th>

Ref: No.6392(11)/ ๕๖๓

September 9th, 2010

Professor Dr. Tanongkiat Kiatsirirot
Department of Mechanical Engineering
Faculty of Engineering
Chiang Mai University
Chiang Mai 50200

Dear Professor Dr. Tanongkiat Kiatsirirot:

Thank you for the manuscript entitled "**Improvement of an Absorption Heat Transformer Performance for Upgrading Low Temperature Heat by Coupling with a Vapor Compression Heat Pump**", which you submitted for possible publication in the Chiang Mai University Journal of Natural Sciences.

I am pleased to inform you that the Editorial Committee has now agreed to accept your revised manuscript for publication.

Thank you for choosing the CMU journal of Natural Sciences as your preferred medium for publication.

Yours sincerely,

Professor Chuckree Senthong, Ph.D.

Editor-in-Chief

Tel: 053 94 2676

Fax: 053 94 3600

E-mail: cmujour@chiangmai.ac.th

<http://cmuj.chiangmai.ac.th>

Upgrading of Low Temperature Solar Heat for Medium Temperature Applications by a Solar-Absorption Heat Transformer Assisting with a Vapor Compression Heat Pump

UPGRADING OF LOW TEMPERATURE SOLAR HEAT FOR MEDIUM TEMPERATURE APPLICATIONS BY A SOLAR-ABSORPTION HEAT TRANSFORMER ASSISTING WITH A VAPOR COMPRESSION HEAT PUMP

Nattaporn Chaiyat and Tanongkiat Kiatsiriroat*

Department of Mechanical Engineering, Chiang Mai University, Chiang Mai, 50200, Thailand

* Corresponding author: tanongkiat_k@yahoo.com

In tropical area, even solar radiation level is rather high but diffuse solar radiation component is also very significant thus only solar flat-plate solar collector could be competitive with conventional energy for heat generation with a temperature not over 70°C. For higher temperature applications, a technique to boost-up the temperature is needed.

This paper presents simulation results of a H₂O-LiBr absorption heat transformer (AHT) having a R123 vapor compression heat pump (VCHP) recovering heat at the AHT condenser which is transferred to the AHT evaporator. The heat capacity at the AHT absorber is 10 kW. The unit is used to upgrade heat from a solar hot water heater of which the heat is supplied by a set of flat-plate solar collectors in parallel connection each having an area of 2m² with $F_R(\tau\alpha)$ and $F_R U_L$ of 0.802 and 10.37W/m²·K, respectively. The weather data of Chiang Mai, Thailand are the input information for the calculation.

The AHT could be operated when the hot water temperature from the solar water heating system is over 70 °C. For the AHT with VCHP assisted, the number of the solar collectors is around 30 units which is about 50% of that without the VCHP. Moreover, the COP of the modified AHT is about 0.8 compared with 0.5 of the conventional AHT when the AHT absorber temperature is between 80-120°C. The total cost of the modified unit is also cheaper than the conventional one.

Keywords: Heat transformer, Absorption heat pump, Flat plate solar collector, Simulation

Experimental Study and a Simplified Model of a 10 kW_{th} Solar-Absorption Heat Transformer

Experimental Study and a Simplified Model of a 10 kW_{th} Solar-Absorption Heat Transformer

Nattaporn Chaiyat

Tanongkiat Kiatsirirot

Department of Mechanical Engineering,
 Chiang Mai University,
 Chiang Mai, Thailand

Experimental study of a 10 kW_{th} single-stage LiBr-water absorption heat transformer (AHT) to boost up low temperature heat from a solar hot water system having a set of flat-plate solar collectors was carried out. The solar heat could be upgraded for generating hot water up to 100 °C which was around 20 °C higher than that of the input heat. The COP_{AHT} and EER_{AHT} of the AHT were around 0.42 and 4.1, respectively. A simplified model to predict the system performances such as the COP_{AHT} and EER_{AHT} was also developed and the results agreed well with those from the experiments.

Introduction

In general, heat will transfer from a high temperature heat source to a lower temperature heat sink and if we want to reverse the heat direction, a heat driven machine is needed.

Absorption heat transformer (AHT) is one method for upgrading low temperature heat to a higher temperature level. Low temperature heat is absorbed at the AHT generator and the AHT evaporator and then the heat is delivered at the AHT absorber at a higher temperature, while the AHT condenser rejects heat at a lower temperature. Theoretical and experimental studies of the AHT have been reported by various literatures. Rivera et al [1] presented a single-stage and advanced AHT operating with water-LiBr and water-Carrol™ mixtures to increase the temperature of the useful heat produced by solar pond. The results showed that the single-stage and the double AHT increased solar pond's temperature until 50 °C at COP about 0.48 and 100 °C at COP about 0.33, respectively. Xuehu et al. [2] reported the test results of the first industrial-scale water-LiBr AHT in China to recover waste heat released from an organic vapor at 98 °C in a synthetic rubber plant. The recovered heat was used to heat hot water from 95 °C to 110 °C. The AHT system was operating with a heat rate of 5,000 kW with a mean COP of 0.47. The payback was approximately 2 years. Sotsil Silva Sotelo et al. [3] presented an AHT cycle operating with water-Carrol™ mixture which had a

higher solubility than aqueous Lithium Bromide mixture. It could be found that the coefficient of performance was higher and less crystallization risk was obtained compared with the water-Lithium Bromide solution.

The main objective of this work was to study thermal performance of a 10 kW_{th} single-stage LiBr-water absorption heat transformer (AHT) to boost up low temperature heat from a solar hot water system supplying heat from a set of flat-plate solar collectors. A simplified model to predict the system performances such as the COP_{AHT} and EER_{AHT} was also developed.

Solar-Absorption Heat Transformer

Fig. 1 shows a schematic sketch of a solar-absorption heat transformer (Solar-AHT). Solar heat from a solar hot water system is supplied to the generator and evaporator at a medium temperature (around 60-80 °C) and rejected heat at a lower temperature (around 35-45 °C) at the condenser. A higher temperature heat (around 80-110 °C) is obtained at the absorber.

At the generator, a binary liquid mixture consisting of a volatile component (absorbate) and a less volatile component (absorbent) is heated at a medium temperature. Part of the absorbate boils at a low pressure (P_C) and a generator temperature (T_G) at state 1. The vapor condenses in the condenser at a condenser temperature (T_C) to be liquid at state

CURRICULUM VITAE



Name – Surname Nattaporn Chaiyat

Date of Birth 25 April 1979

Educations

1. Master Degree: M.ENG Energy Engineering
Department: Energy Engineering Program, Faculty of
Engineering, Chiang Mai University.
Academic Year: 2007

2. Bachelor Degree : B.ENG Electrical Engineering
Department: Electrical Engineering Program, Faculty
of Engineering, Chiang Mai University.
Academic Year: 2002

