



The compressor produced heat which usually caused to stop compression and caused trembling to the case while it was working and error from incorrect reading of the indicator of constructed flowmeter.