

เอกสารอ้างอิง

1. รัฐมนตรี เกตุจุณพลด “การทดสอบ Fiberglass-Reinforced Plastic (FRP) Hot Stick” แผนกทดสอบอุปกรณ์ทางไฟฟ้า กองทดสอบอุปกรณ์ทางไฟฟ้า ฝ่ายบำรุงรักษาสายสั่ง การไฟฟ้าฝ่ายผลิตแห่งประเทศไทย
2. Department of Labor, OSHA, 29 CFR PARTS 1910; Federal Register, Vol.59, No. 20, January 31, 1994, Rules & Regulations.
3. IEEE Standard 978-1984, Guide for In-Service Maintenance & Electrical Testing of Live Line Tools
4. ASTM F711-89, Standard Specification for Fiberglass-Reinforced Plastic (FRP) Rod and Tube used in Live-Line Tools.
5. W. McDermid, J.C Bromley , D.J. Dodds, D.R. Swatek, “Investigation of the Flashover of a FRP Hot Stick While in Use for Live Line Work at 500 kV” , IEEE Transaction on Power Delivery, Vol.14,No. 3, July 1999 , pp 1158-1166
6. W. McDermid, J.C Bromley, D.R. Swatek, “FRP Hot Stick Flashover during EHV Live Line Work” , IEEE Transaction on Power Delivery,2003
7. M.V.K. Chari,et al, Field Elements in Electric and Magnetic Field Problems, Wiley , NY,1980
8. H.Singer, et al, “A Charge Simulation Method for the Calculation of High Voltage Fields,” IEEE Transactions on Power Apparatus and Systems, Vol. PAS-93, No 5, Sept./Oct. 1974, pp. 1660-1668.
9. J.N. Sheng, et al, Numerical Analysis of Electromagnetic Fields (in Chinese), Scientific Press, 1984
10. EPRI, Transmission Line Reference Book-345 kV and Above, 2nd edition, 1982.
11. Z.Yan. et al, “Prediction and Improvement of Electric Field Distortion in HVAC Substations, “Elec. Power System Research, Vol. 11 1986, p. 153
12. Z Yan, et al, “consideration of the Problem of Electrostatic Induction in the Construction of 500kV Substations” (in Chinese), J Xian Jiaotong University Vol 18(1). 1984, p 17.
13. EPRI “Live Working Guide for Overhead Lines, Version 3” Palo Alto, CA, 2004.